

October 21, 2005

LICENSEE: Nuclear Management Company, LLC

FACILITY: Monticello Nuclear Generating Plant

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON
OCTOBER 6, 2005, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND NUCLEAR MANAGEMENT COMPANY, LLC,
CONCERNING INFORMATION PERTAINING TO THE MONTICELLO
NUCLEAR GENERATING PLANT LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC) held a telephone conference call on October 6, 2005, to discuss and clarify the applicant's response to request for additional information (RAI), RAI 3.5.2.1.15-1, provided in a letter dated September 16, 2005, concerning the Monticello Nuclear Generating Plant license renewal application. The conference call was useful in clarifying the applicant's response. On the basis of the discussion, the applicant plans to submit a written response.

Enclosure 1 provides a listing of the meeting participants. Enclosure 2 contains a listing of the issues discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Daniel J. Merzke, Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket No.: 50-263

Enclosures: As stated

cc w/encls: See next page

October 21, 2005

LICENSEE: Nuclear Management Company, LLC

FACILITY: Monticello Nuclear Generating Plant

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON
OCTOBER 6, 2005, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND NUCLEAR MANAGEMENT COMPANY, LLC,
CONCERNING INFORMATION PERTAINING TO THE MONTICELLO
NUCLEAR GENERATING PLANT LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC) held a telephone conference call on October 6, 2005, to discuss and clarify the applicant's response to request for additional information (RAI), RAI 3.5.2.1.15-1, provided in a letter dated September 16, 2005, concerning the Monticello Nuclear Generating Plant license renewal application. The conference call was useful in clarifying the applicant's response. On the basis of the discussion, the applicant plans to submit a written response.

Enclosure 1 provides a listing of the meeting participants. Enclosure 2 contains a listing of the issues discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Daniel J. Merzke, Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket No.: 50-263

Enclosures: As stated

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: ML052970210

DOCUMENT NAME: E:\Filenet\ML052970210.wpd

| | | | |
|--------|------------|------------|------------|
| OFFICE | PM:RLEP | LA:RLEP | SC:RLEP |
| NAME | DMerzke | MJenkins | LLund |
| DATE | 10/ 18 /05 | 10/ 14 /05 | 10/ 21 /05 |

OFFICIAL RECORD COPY

Monticello Nuclear Generating Plant

cc:

Jonathan Rogoff, Esquire
Vice President, Counsel & Secretary
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
2807 W. County Road 75
Monticello, MN 55362

Manager, Regulatory Affairs
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

Robert Nelson, President
Minnesota Environmental Control
Citizens Association (MECCA)
1051 South McKnight Road
St. Paul, MN 55119

Commissioner
Minnesota Pollution Control Agency
520 Lafayette Road
St. Paul, MN 55155-4194

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Commissioner
Minnesota Department of Health
717 Delaware Street, S.E.
Minneapolis, MN 55440

Douglas M. Gruber, Auditor/Treasurer
Wright County Government Center
10 NW Second Street
Buffalo, MN 55313

Commissioner
Minnesota Department of Commerce
85 7th Place East, Suite 500
St. Paul, MN 55101-2198

Manager - Environmental Protection
Division
Minnesota Attorney General's Office
445 Minnesota St., Suite 900
St. Paul, MN 55101-2127

John Paul Cowan
Executive Vice President & Chief Nuclear
Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Nuclear Asset Manager
Xcel Energy, Inc.
414 Nicollet Mall, R.S. 8
Minneapolis, MN 55401

Mr. James Ross
Nuclear Energy Institute
1776 I Street, NW, Suite 400
Washington, DC 20006-3708

Patrick Burke
License Renewal Project Manager
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

Mr. Douglas F. Johnson
Director, Plant Life Cycle Issues
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Monticello Nuclear Generating Plant

-2-

cc:

David R. Lewis
Pillsbury Winthrop Shaw Pittman, LLP
2300 N Street, NW
Washington, DC 20037-1122

DISTRIBUTION: Summary of telecon held on 10/6/05 with NMC, Dated: October 21, 2005
Adams Accession No.: **ML052970210**

HARD COPY

RLEP RF

E-MAIL:

RidsNrrDrip
RidsNrrDe
G. Bagchi
K. Manoly
W. Bateman
J. Calvo
R. Jenkins
J. Fair
RidsNrrDssa
RidsNrrDipm
D. Thatcher
R. Pettis
G. Galletti
C. Li
K. Winsberg (RidsOgcMailCenter)
R. Weisman
M. Mayfield
A. Murphy
S. Smith (srs3)
S. Duraiswamy
Y. L. (Renee) Li
RLEP Staff

L. Raghavan
M. Padovan
A. Stone, RIII
B. Burgess, RIII
P. Loughheed, RIII
R. Orlikowski, RIII
T. Mensah
A. Hodgdon
M. Woods
OPA

**LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE
TO DISCUSS THE MONTICELLO NUCLEAR GENERATING PLANT
LICENSE RENEWAL APPLICATION**

October 6, 2005

Participants

Daniel Merzke
Matthew Yoder
Patrick Burke
Joe Pairitz
Dave Musolf
Dave Sexton

Affiliations

U.S. Nuclear Regulatory Commission (NRC)
NRC
Nuclear Management Company, LLC (NMC)
NMC
NMC
NMC

**MONTICELLO NUCLEAR GENERATING PLANT
LICENSE RENEWAL APPLICATION**

October 6, 2005

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC), held a telephone conference call on October 6, 2005, to discuss and clarify the applicant's response to request for additional information, RAI 3.5.2.1.15-1, provided in a letter dated September 16, 2005, concerning the Monticello Nuclear Generating Plant license renewal application. The following issues were discussed during the telephone conference call.

1. The applicant was asked to provide technical justification for not conducting inspections of the boron coupons into the period of extended operation after the One-Time Inspection is performed. The applicant was also asked to explain the criteria to be used in determining additional inspections would not be required after the One-Time Inspection.

Discussion: The applicant indicated that the question is clear and will provide a written response as a supplement to the RAI response provided.

Enclosure 2