

DCS No.: 05000213051031
Date: November 3, 2005

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-I-05-028

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility

Connecticut Yankee Atomic Power Company
Haddam Neck Plant
362 Injun Hollow Road
East Hampton, CT 06424-3099

Docket No.: 50-213
License No.: DPR-61

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: HADDAM NECK REPORT OF SPENT FUEL POOL LEAK

On Monday, October 31, the licensee reported that they had found evidence of a former below-ground spent fuel pool leak on the east side wall of the spent fuel building, while conducting routine decommissioning excavations at the Haddam Neck site. The evidence of the leak consisted of hairline cracks in the spent fuel building wall and the accumulation of a white residue around the cracks. The licensee believes that the leak is not ongoing based on the absence of dampness around the cracks. As part of the licensee's previous characterization activities, soil core bores had been made around the entire spent fuel building. Elevated soil contamination had been identified in one small area on the east side of the spent fuel building. Four core samples of the east side of the spent fuel building wall were taken by the licensee which identified very low concentrations of Cs-137, Co-60, Sr-90, and tritium. The licensee has a system of down gradient wells on site to monitor groundwater, including shallow and bedrock wells in the vicinity of the spent fuel building. Recent groundwater monitoring surveillance results indicated low levels of tritium (4000 pCi/l) and Sr-90 (1.4 pCi/l) that were less than the EPA drinking water standard of 20,000 pCi/l and 8 pCi/l, respectively.

While water remains in the pool, fuel removal was completed in March 2005. Previous NRC inspections of the licensee's spent fuel pool safety program identified no significant leakage from the spent fuel pool leak detection system. NRC RI plans to review the licensee's sampling results and conduct independent measurements as part of its routine decommissioning inspection program scheduled to begin on November 7, 2005.

The licensee made the Offsite Notification per 10 CFR Part 50.72(b)(2)(xi). The licensee initially notified the State of Connecticut of this event as required by state regulations.

On November 3, NRC RI made additional notifications to the State Department of Environmental Protection, the First Selectman from Haddam and the Chair of the Citizens Decommissioning Advisory Committee. NRC Office of Congressional Affairs also informed staff of the U.S. Connecticut Congressional Delegation.

The Region I Office of Public Affairs is prepared to respond to media inquires.

This information presented herein has been discussed with the licensee and is current as of 3:00 p.m., November 3, 2005.

Contact: Marie Miller
 (610) 337-5205
mtm1@nrc.gov

DISTRIBUTIONS:

BY E-MAIL:

<u>OWFN</u>	<u>TWFN</u>	<u>LST</u>
Chairman Diaz	IRO	PDR
Comm. McGaffigan Jr.	NMSS	
Comm. Merrifield	OIG	
Comm. Lyons	RES	
Comm. Jaczko		
OIP		
OCA		
OGC		
EDO		
OE		
NRR		
SECY		
Regional Offices		

BY FAX:

DOT:Trans
 INPO
 NSAC
 RI Resident Office
 Licensee: Joseph Bourassa, CYAPCo
 (Reactor Licensees)

DOCUMENT NAME: S:\PN\PN105028.wpd

OFFICE	RI/DNMS	RI/DNMS	RI/SAO	RI/PAO	
NAME	M Miller mtm1	G Pangburn gcp	S Minnick sam9	N Sheehan nas	
DATE	11/03/05	11/03/05	11/03/05	11/03/05	