

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.5.2.3	Verify each HPI pump's developed head at the test flow point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program
SR 3.5.2.4	Verify each HPI automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	18 months
SR 3.5.2.5	Verify each HPI pump starts automatically on an actual or simulated actuation signal.	18 months
SR 3.5.2.6	Verify, by visual inspection, each HPI train reactor building sump suction inlet is not restricted by debris and suction inlet strainers show no evidence of structural distress or abnormal corrosion.	18 months
SR 3.5.2.7	Cycle each HPI discharge crossover valve and LPI-HPI flow path discharge valve.	18 months

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.5.3.2	<p>-----NOTE----- Not applicable to operating LPI pump(s). -----</p> <p>Vent each LPI pump casing.</p>	31 days
SR 3.5.3.3	Verify each LPI pump's developed head at the test flow point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program
SR 3.5.3.4	Verify each LPI automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	18 months
SR 3.5.3.5	Verify each LPI pump starts automatically on an actual or simulated actuation signal.	18 months
SR 3.5.3.6	Verify, by visual inspection, each LPI train reactor building sump suction inlet is not restricted by debris and suction inlet strainers show no evidence of structural distress or abnormal corrosion.	18 months