



November 2, 2005

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Supplemental Information for License Amendment Request: Change Regarding
Mode Change Limitations Using the Consolidated Line Item Improvement
Process

REFERENCE: (a) Letter from Mr. G. Vanderheyden (CCNPP) to Document Control Desk
(NRC), dated January 27, 2005, License Amendment Request: Change
Regarding Mode Change Limitations Using the Consolidated Line Item
Improvement Process

In Reference (a) we requested changes to the Technical Specifications to modify mode change limitations in *Limiting Condition for Operation (LCO) 3.0.4* and *Surveillance Requirement 3.0.4*. One of the optional requested changes would allow a mode change with an inoperable diesel generator if a risk assessment would support it. Upon further consideration, we are withdrawing this portion of the original request. We recognize that this portion of the request is substantially beyond the scope of the Consolidated Line Item Improvement Process safety evaluation and do not wish to pursue it at this time. Therefore, we wish to amend our previous submittal (Reference a) to remove our request to allow mode changes with an inoperable diesel generator using LCO 3.0.4.b. We now request the addition of a Note to LCO 3.8.1 prohibiting the use of LCO 3.0.4.b for diesel generators, as described in Technical Specification Task Force (TSTF)-359-A, Revision 9. Please replace marked-up pages 3.8.1-2, 3.8.1-3, and 3.8.1-6 in Reference (a) with the attached marked-up page (Attachment 1). The No Significant Hazards Consideration determination and Environmental Evaluation presented in the Nuclear Regulatory Commission Notice of Availability published on April 4, 2003 remains valid for the reduced scope of this request.

A501

Should you have questions regarding this matter, please contact Mr. L. S. Larragoite at (410) 495-4922.

Very truly yours,

STATE OF MARYLAND :
 : TO WIT:
COUNTY OF CALVERT :

I, Bruce S. Montgomery, being duly sworn, state that I am Manager CCNPP Engineering Services - Calvert Cliffs Nuclear Power Plant, Inc. (CCNPP), and that I am duly authorized to execute and file this License Amendment Request on behalf of CCNPP. To the best of my knowledge and belief, the statements contained in this document are true and correct. To the extent that these statements are not based on my personal knowledge, they are based upon information provided by other CCNPP employees and/or consultants. Such information has been reviewed in accordance with company practice and I believe it to be reliable.

Subscribed and sworn before me, a Notary Public in and for the State of Maryland and County of St. Mary's, this 2nd day of November, 2005.

WITNESS my Hand and Notarial Seal:

Notary Public
Date

Attachment: (1) Marked-up Technical Specification Page

cc: P. D. Milano, NRC
S. J. Collins, NRC

Resident Inspector, NRC
R. I. McLean, DNR

ATTACHMENT (1)

MARKED-UP TECHNICAL SPECIFICATION PAGE

3 2

NOTE

LCO 3.0.4. b is not applicable
to DGs

AC Sources-Operating
3.8.1

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required LCO 3.8.1.a offsite circuit inoperable.	A.1 Perform SR 3.8.1.1 or SR 3.8.1.2 for required OPERABLE offsite circuits.	1 hour <u>AND</u> Once per 8 hours thereafter
	<u>AND</u> A.2 Declare required feature(s) with no offsite power available inoperable when its redundant required feature(s) is inoperable.	24 hours from discovery of no offsite power to one train concurrent with inoperability of redundant required feature(s)
	<u>AND</u> A.3 Restore required offsite circuit to OPERABLE status.	72 hours <u>AND</u> 17 days from discovery of failure to meet LCO 3.8.1.a or LCO 3.8.1.b