

SURVEILLANCE REQUIREMENTS

-----NOTE-----  
Section A, B, C, D, and E isolation valves are located in the LCS.  
-----

SURVEILLANCE	FREQUENCY
SR 3.6.3.1 Verify each 42 inch purge valve is sealed closed except for one purge valve in a penetration flow path while in Condition D of this LCO.	31 days
SR 3.6.3.2 Verify each 8 inch purge valve is closed except when the 8 inch purge valves are open for pressure control, ALARA or air quality considerations for personnel entry, or for Surveillances that require the valves to be open.	31 days
SR 3.6.3.3 -----NOTES----- 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. SR 3.0.4 is not applicable ----- Verify each containment isolation manual valve and blind flange that is located outside containment and not locked, sealed, or otherwise secured and is required to be closed during accident conditions is closed, except for containment isolation valves that are open under administrative controls.	31 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.3.4 -----NOTES-----            1. Valves and blind flanges in high radiation areas may be verified by use of administrative means.            2. SR 3.0.4 is not applicable.            -----            Verify each containment isolation manual valve and blind flange that is located inside containment and not locked, sealed, or otherwise secured and required to be closed during accident conditions is closed, except for containment isolation valves that are open under administrative controls.</p>	<p>Prior to entering MODE 4 from MODE 5 if not performed within the previous 92 days</p>
<p>SR 3.6.3.5 Verify the isolation time of each Section A and B power operated and each automatic containment isolation valve is within limits.</p>	<p>In accordance with the Inservice Testing Program</p>
<p>SR 3.6.3.6 -----NOTES-----            Results shall be evaluated against acceptance criteria applicable to SR 3.6.1.1            -----            Perform leakage rate testing for containment purge valves with resilient seals.</p>	<p>184 days  <u>AND</u>            Within 92 days after opening the valve</p>

(continued)