



Proposed Release of Part of R.E. Ginna Nuclear Power Plant Site for Unrestricted Use under 10 CFR 50.83

Meeting to Obtain Public Comments

September 28, 2005

Patrick Milano, Sr. Project Manager, NRR

Stephen Klementowicz, HP Team Leader, NRR

Jean-Claude Dehmel, HP Specialist, NRR

Daniel Barss, Sr. EP Team Leader, NSIR

Peter Lee, Sr. Security Specialist, NSIR

Enclosure 2



Ginna Partial Site Release

Application from Constellation Energy on May 20, 2005

- 2 land parcels of approximately 15 total acres
- Located along western edge of site boundary between Lake Ontario to North and Lake Road to South
- Consists primarily of undisturbed wooded areas and orchards and grain fields
- Licensee intends to sell to real estate developer for conversion to residential use
- Entirely outside of Ginna Station Exclusion Area Boundary



Ginna Partial Site Release

Correspondence to Date

- Licensee's application of May 20, 2005
- NRC letter of June 29, 2005, regarding administrative review for acceptability of application to begin detailed technical review
- Federal Register Notice of Receipt and Availability for Comment on July 11, 2005 (70 FR 39802)
- NRC letters requesting additional information:
 - ▶ September 7, 2005
 - ▶ September 15, 2005
- Federal Register Notice of Meeting to Obtain Public Comments on September 14, 2005 (70 FR 54416)





Proposed Release of Part of R.E. Ginna Nuclear Power Plant Site for Unrestricted Use under 10 CFR 50.83

Meeting to Obtain Public Comments

September 28, 2005

Patrick Milano, Sr. Project Manager, NRR
Stephen Klementowicz, HP Team Leader, NRR
Jean-Claude Dehmel, HP Specialist, NRR
Daniel Barss, Sr. EP Team Leader, NSIR
Peter Lee, Sr. Security Specialist, NSIR

Enclosure 2



Ginna Partial Site Release

- Licensee must also have performed:
 - ▶ Historical Site Assessment of the part to be released
 - ▶ Surveys to demonstrate compliance with radiological criteria for unrestricted use under Subpart E to 10 CFR Part 20



Ginna Partial Site Release

Scope of NRC Review Non-Impacted Areas

- Determine if the licensee has adequately evaluated the effect of releasing the property
 - ▶ Emergency planning
 - ▶ Physical security planning
 - ▶ Effluent releases and environmental monitoring
 - ▶ Plant siting criteria
- Determine if the licensee's classification of the property as "non-impacted" is adequately justified

