PPL SUSQUEHANNA, LLC

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

S/RO	78.AD.001.101	0	09/26/05	2.1	1.18	N/A	2.9/3.0		
Appl.	JPM Number	Rev. No.	Date	NURE	G 1123	K/A No.	K/A Imp.		
То				Sys. N	0.				
Task Title:	Task Title: Document a Failed LPRM Detector								
Completer	1 By:		Validate	Ч					
Completet	<i>.</i> .		Vandato	4					
Rich Chin		09/26/05							
Writer		Date	Instructo	or/Writer		Date			
Approval:									
Nuclear Ti	rng. Supv.	Date							
	-								
			15/25						
Date of Pe	erformance:	Valida	tion Time (Mir	n.)	Time Tak	en (Min.)			
	wmod By:								
JPM Perio	лпец Бу.								
Student N	ame:		First	M I	Employee	+/SS #			
	Lasi		1 1130	141.1.	Employee	, , , 0.0. "			
_ /	,			<i>,</i> ,		- 4			
Performar Evaluation	nce () Satisfac	story	()	Unsatista	ctory			
	1.								
Evaluator Name:									
	Signature			Туре	a or Printeo	1			
Comment	s:								

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE S/RO 78.AD.001.101

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. OI-078-001 LPRM STATUS CONTROL, (Rev. 8)
- B. TS amendment 217

III. REACTIVITY MANIPULATIONS

This JPM satisfies the requirements of Operational Activity(s):

None

IV. TASK CONDITIONS

- A. Unit 1 is in MODE 1at 80% power.
- B. Reactor Engineering has completed their evaluation of a downscale alarm condition for LPRM detector 48-17B. LPRM detector 48-17B is failed
- C. The PCOP has just **NOW** bypassed LPRM detector 48-17B in the lower relay room.
- D. All OPRM channels are INOPERABLE

V. INITIATING CUE

Complete all required "hardcopy" documentation in accordance with the appropriate instructions for LPRM detector 48-17B.

VI. TASK STANDARD

Zone 4 is identified as not having more than 50% upscale alarms operable, placard place on reactor panel, Unit Supervisor Notified to reference TRO 3.3.9, SROs must additionally identify required TRO actions.

Page 3 of 8

1

Appl. To/JPM No.: <u>S/RO 78.AD.001.101</u>

Student Name:_____

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	 Ensure the following material is available to support performance of this JPM: 			
	• A copy of OI-078-001.			
	 Prepare attachments A & B with zone 4 having exactly 50% operable LPRM upscale alarms. 			
	• Blank copy of attachment A & B.			
	EVALUATOR NOTE:			
	To begin this JPM, provide the candidate with the Task Conditions and Initiating Cue Sheet.			
1	Obtains a controlled copy of procedure.	Controlled copy of OI-078-001 obtained.		
2	Refers to correct section.	Refers to section 4.		

*Critical Step

Page 4 of 8

Appl. To/JPM No.: S/RO 78.AD.001.101

Student Name:____

Step	Action	Standard	Eval	Comments
3	Determines current LPRM status.	Obtains the Operations Special Log Book in the Unit 1 control room and locates the previously completed copy of Attachment A & B.		
	EVALUATOR CUE:			
	When the candidate identifies where the current LPRM Upscale Alarm Status Control Log is retained provide the candidate with previously filled-out copy of Attachments A & B.			
	EVALUATOR NOTE:			
	Allow candidate to use blank attachments from the copy of the procedure provided.			
4	Obtains a blank copy of Attachment A & B.	Blank copy obtained.		
5	Completes new Attachment A.	Enters 1 for Unit.		

*Critical Step

Page 5 of 8

Appl. To/JPM No.: <u>S/RO 78.AD.001.101</u>

Student Name:_____

Step	Action	Standard	Eval	Comments
	EVALUATOR CUE: If candidate elects to verify position of switches in lower relay room, provide the cue that the switches are in the positions indicated on Attachment A (Special log book)	Transfers the previous LPRM data to the new Attachment A.		
		Candidate may desire to verify switches in lower relay room.		
6	Enter a check ($$) in column (2) for LPRM alarms determined inoperable or bypassed for all other reasons.	Place a checkmark in column 2 adjacent to LPRM detector 48-17B in Zone 4.		
7	Consider all LPRM Upscale Alarms with a check in column (1) or (2) of Attachment A as inoperable	Circles YES for zone 1, 2, 3, 5, 6, 7, 8, and 9.		
	Determine if \geq 50% of LPRM Upscale alarms in each zone are operable.			
*8		Circles NO for zone 4.		
9	Notify Reactor Engineering of all LPRM upscale alarms determined inoperable.	N/A Previously noted in JPM cue.		

Page 6 of 8

Appl. To/JPM No.: S/RO 78.AD.001.101

Student Name:____

Step	Action	Standard	Eval	Comments
*10	Attach placard to 1C651 indicating < required # of LPRM Upscale Alarms.	Attaches placard to operating panel 1C651.		
	EVALUATOR NOTE:			
	The placard is required to remain posted until all zones have >50% upscale alarms operable.			
*11	Refer to TRO 3.3.9 LPRM, upscale alarm instrumentation	Notifies the Unit Supervisor to Refer to TRO 3.3.9 LPRM		
12	Complete an LPRM vs. APRM/LPRM Group Status Control Log (Attachment B) each time LPRM operability status is changed	Enters 1 for Unit.		
	Circle all inoperable LPRM's on LPRM vs. APRM/LPRM Group Status Control Log (Attachment B).			
13		Transfers the previous LPRM data to the new Attachment B.		
14		Circles LPRM detector 48-17 for APRM E, under the column 'B' Level.		
15	Obtains review.	Submit the completed Attachment A and B to the Unit Supervisor.		

*Critical Step

Page 7 of 8

Appl. To/JPM No.: <u>S/RO 78.AD.001.101</u>

Student Name:_____

Step	Action	Standard	Eval	Comments
	EVALUATOR CUE:			
	This completes the JPM for the ROs ONLY			
	EVALUATOR CUE:			
	FOR SRO CANDIDATES ONLY			
	Give the SRO candidate the second cue sheet that addresses the Tech Spec and TRO for the INOPERABLE LPRMs Upscale alarms.			
16	Obtains a copy of the Tech Specs and TRM	References:		
		TRO 3.3.9		
*17	Determines required actions	Determines the following actions are required:		
		TRO 3.3.9 condition H		
		Within 1 hour Post a sign on the reactor panel that less than 50% of the LPRM Upscale alarms are OPERABLE		
		AND		
		TRO 3.3.9 Condition E	ļ	
		Immediately Place the reactor mode switch in the shutdown position		

*Critical Step

(

Page 8 of 8

Appl. To/JPM No.: <u>S/RO 78.AD.001.101</u>

Student Name:_____

Step	Action	Standard	Eval	Comments
	EVALUATOR CUE:			
	This completes the JPM.			

*Critical Step

#Critical Sequence

TASK CONDITIONS

- A. Unit 1 is in MODE 1at 80% power.
- B. Reactor Engineering has completed their evaluation of a downscale alarm condition for LPRM detector 48-17B. LPRM detector 48-17B is failed
- C. The PCOP has just **NOW** bypassed LPRM detector 48-17B in the lower relay room.
- D. All OPRM channels are INOPERABLE

INITIATING CUE

Complete all required "hardcopy" documentation in accordance with the appropriate instruction for LPRM detector 48-17B.

TASK CONDITIONS

- A. Unit 1 is in MODE 1at 80% power.
- B. Reactor Engineering has completed their evaluation of a downscale alarm condition for LPRM detector 48-17B. LPRM detector 48-17B is failed
- C. The PCOP has just NOW bypassed LPRM detector 48-17B in the lower relay room.
- D. All OPRM channels are INOPERABLE

INITIATING CUE

Complete all required "hardcopy" documentation in accordance with the appropriate instruction for LPRM detector 48-17B.

SRO ONLY

TASK CONDITIONS

- A. Unit 1 is in MODE 1at 80% power.
- B. Reactor Engineering has completed evaluation of a downscale alarm condition for LPRM detector 48-17B.
- C. LPRM detector 48-17B is failed and bypassed.
- D. All OPRM channels are INOPERABLE
- E. It has been determined that < 50% of LPRM Upscale alarms in zone 4 are operable.
- F. The combination of thermal power and core flow is IN Region II of the power to Flow Map.

INITIATING CUE

Determine the required Tech Spec and TRO actions.

SRO ONLY

TASK CONDITIONS

- A. Unit 1 is in MODE 1at 80% power.
- B. Reactor Engineering has completed evaluation of a downscale alarm condition for LPRM detector 48-17B.
- C. LPRM detector 48-17B is failed and bypassed.
- D. All OPRM channels are INOPERABLE
- E. It has been determined that < 50% of LPRM Upscale alarms in zone 4 are operable.
- F. The combination of thermal power and core flow is IN Region II of the power to Flow Map.

INITIATING CUE

Determine the required Tech Spec and TRO actions.

PPL SUSQUEHANNA, LLC

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

SRO 00.AD.273.002 Appl. JPM Number To	0 Rev. No.	09/26/05 Date	2. NURE Sys. N	1.12 G 1123 o.	N/A K/A No.	4.0 K/A Imp.		
Task Title: Determine TRO applicability and complete the LCO/TRO log sheet.								
Completed By:		Validated						
Rich Chin Writer	09/26/05 Date	Instructor	/Writer		Date			
Approval:								
Nuclear Trng. Supv.	Date	<u></u>						
		15						
Date of Performance:	Validat	ed Time (Min.))	Time Take	n (Min.)			
JPM Performed By:								
Student Name:				<u> </u>	<u>+/00 +</u>			
Last		FIRST	M.I.	Employee	#/5.5.#			
Performance (Evaluation:) Satisfact	ory	()	Unsatisfac	tory			
Evaluator Name:Signature			Туре	d or Printed				
Comments:								

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE SRO 00.AD.273.002

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgement of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

NDAP-QA-0312, "CONTROLS OF LCO'S, TRO'S AND SAFETY FUNCTION DETERMINATION PROGRAM" (Revision 8) Tech Specs

III. REACTIVITY MANIPULATIONS

This JPM satisfies the requirements of Operational Activity(s):

NONE

IV. TASK CONDITIONS

- A. Unit 1 is in Mode 1 at 100% power.
- B. "B" RPS Bus De-energized 30 minutes ago due to a voltage regulator failure in the MG set.
- C. "B" RPS has been transferred to the alternate power supply IAW ON-158-001, LOSS OF RPS attachment B.
- D. At step 9 of ON-158-001, LOSS OF RPS attachment B, a problem was encountered. NONE of the CRM AIR SAMPLE ISO LOOP valves (HS-157110A1, A2, B1, B2) could be OPENED. All other steps of the attachment were completed successfully.
- E. Electrical maintenance was dispatched to determine the problem with the CRM AIR SAMPLE ISO LOOP valves. Electrical maintenance has determined the cause to be a failure of the MDR relay.
- F. AR-146-A02 CONTN RAD DET SYSTEM A TROUBLE alarm is locked in.
- G. AR-146-A05 CONTN RAD DET SYSTEM B TROUBLE alarm is locked in.
- H. No Tech Spec actions, TRO actions or Loss of safety function worksheets are in effect at either Unit.

V. INITIATING CUE

Based on these plant conditions, IAW with the appropriate procedure, determine the required Tech Spec/TRM actions, and complete the necessary tracking forms.

VI. TASK STANDARD

Entry into LCO 3.4.6 declared with LCO/TRO log and Operations portion of Chemistry/Health Physics LCO/TRO Sample /Survey Log sheet filled-out, and Chemistry notified.

Page 3 of 9

į.

Appl. To/JPM No.: 00.AD.273.002

Student Name:___

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	Due to the nature of this JPM, the candidate may refer to several procedures before determining CRM A & B are both INOPERABLE and LCO 3.4.6 entry is required. Allow candidate to use the forms from the copy of NDAP-QA-0312 that is provided with this JPM.			
1	Obtain a controlled copy of NDAP-QA-0312, "CONTROLS OF LCO'S, TRO'S AND SAFETY FUNCTION DETERMINATION PROGRAM"	Controlled copy obtained.		
2	Selects the correct section to perform.	Selects section 6.3		
3	Review applicable TS LCO and Bases or TRM TRO and Bases.	Reviews TS LCO and Bases and TRM TRO and Bases.		
		Determines LCO 3.4.6 is applicable.		
	EVALUATOR NOTE: Placing Unit 1 in either of the appropriate blocks in the next 2 steps will satisfy the "Critical " portion for BOTH steps.			

*Critical Step

Page 4 of 9

(

1

Appl. To/JPM No.: 00.AD.273.002

Student Name:___

Step	Action	Standard	Eval	Comments
*4	In accordance with the applicable TS/TRM, complete a LCO/TRO log sheet (Form NDAP-QA-0312-1) as follows:	Fills out a copy of Attachment C of NDAP-QA-0312 (Form NDAP-QA-0312-1)		
	Enter the applicable unit for which the log sheet is being completed.	Records a 1 in the space provided to designate Unit 1		
*5	Enter the unit containing the inoperable equipment.	Records a 1 in the space provided to designate Unit 1		
6	Enter the system number.	Records a 79 in the space provided.		
*7	Circle or enter whether the Action is an LCO or TRO and enter the specification number.	Circles or records LCO Then records 3.4.6.		
*8	Enter the applicable MODES.	Records 1,2,3.		
	EVALUATOR NOTE:			
	Candidate may choose to place references in the reference document section, however this is not required.			
9	Enter the reference documents, if applicable. The Reference Documents section may also be used to provide clarifying information for the reason the LCO/TRO is being entered.	Determines NO reference documents are applicable.		

*Critical Step

Page 5 of 9

Appl. To/JPM No.: 00.AD.273.002

Student Name:

Step	Action	Standard	Eval	Comments
*10	Review/revise all active LOSF worksheets based on the above inoperable equipment.	Determines from initial conditions that No Tech Spec actions, TRO actions or Loss of safety function worksheets are in affect at either Unit and		
		Records N/A in the space provided		
*11	Determine if LCO 3.0.6 has been applied for any other system on both Units 1 and 2.	Determines from initial conditions that No Tech Spec actions , TRO actions or Loss of safety function worksheets are in affect at either Unit and		
		Records an X in the "Is this a Safety Function Determination support system?" NO space provided		
		AND		
		Records an X in the "If YES, is TS 3.0.6 to be applied?" NA space provided.		
	EVALUATOR NOTE:			
	The next 4 steps of this JPM will require 2 separate line item entries on Attachment C of NDAP-QA-0312. One for action B.1, and one for B.2.			
	See attached answer key for specifics of this form should be completed.			

Page 6 of 9

Appl. To/JPM No.: 00.AD.273.002

Student Name:_____

Step	Action	Standard	Eval	Comments
12	Enter the Date and Time that the CONDITION was entered.	Records B in CONDITION block for both line items		
		Records date and time for each of the actions in the space provided.		
*13	Enter the reason for CONDITION and the appropriate REQUIRED ACTION. The REQUIRED ACTION should be listed by number and include a brief noun description.	Records all of the following		
		Required Primary Containment Atmospheric Monitoring System INOPERABLE		
		B.1 Analyze grab samples of primary containment atmosphere		
		AND		
		B.2 Restore required Primary Containment Atmospheric Monitoring System to OPERABLE status		
*14	Enter the Date and Time by when the REQUIRED	In the spaces provided Records:		
	ACTION must be completed.	Once per 12 hours B.1		
		Within 30 days for item B.2		
*15	Initial that the CONDITION has been entered.	Records candidate initials in the spaces provided		

*Critical Step

Page 7 of 9

ł

Appl. To/JPM No.: 00.AD.273.002

Student Name:_____

Have another SRO Peer Check the LCO/TRO entry and also initial in the "Entered By" box.	Asks another SRO to Peer Check the LCO/TRO entry and initial in the "Entered By" box.		
EVALUATOR CUE:		i I	
Role-play the second SRO and inform the candidate hat you have Peer Checked the LCO/TRO entry, and hey can assume that you have initialed the "Entered By" box.			
f required, additional CONDITION(S) can be entered vithin the same LCO/TRO as follows:	Determines: Form NDAP-QA-0312-5 "LCO/TRO		
f the REQUIRED ACTION requires a repetitive action ex; perform action once every 8 hours);	Repetitive Required Action Completion Sheet" IS NOT REQUIRED.		
COMPLETE Form NDAP-QA-0312-5 "LCO/TRO Repetitive Required Action Completion Sheet" and attach to the LCO/TRO log sheet			
EVALUATOR NOTE:			
t is not necessary to initiate a Chemistry/Health Physics LCO/TRO Sample/Survey Log if the LCO is expected to be cleared prior to the first required action/sample. However, caution must be used to ensure the sample/survey is not missed in the event he LCO is not cleared in a timely manner.			
	ole-play the second SRO and inform the candidate hat you have Peer Checked the LCO/TRO entry, and hey can assume that you have initialed the "Entered y" box. required, additional CONDITION(S) can be entered ithin the same LCO/TRO as follows: the REQUIRED ACTION requires a repetitive action ex; perform action once every 8 hours); OMPLETE Form NDAP-QA-0312-5 "LCO/TRO epetitive Required Action Completion Sheet" and ttach to the LCO/TRO log sheet VALUATOR NOTE: is not necessary to initiate a Chemistry/Health hysics LCO/TRO Sample/Survey Log if the LCO is expected to be cleared prior to the first required ction/sample. However, caution must be used to msure the sample/survey is not missed in the event the LCO is not cleared in a timely manner.	 bele-play the second SRO and inform the candidate bat you have Peer Checked the LCO/TRO entry, and rey can assume that you have initialed the "Entered y" box. required, additional CONDITION(S) can be entered ithin the same LCO/TRO as follows: the REQUIRED ACTION requires a repetitive action box; perform action once every 8 hours); OMPLETE Form NDAP-QA-0312-5 "LCO/TRO epetitive Required Action Completion Sheet" and ttach to the LCO/TRO log sheet VALUATOR NOTE: is not necessary to initiate a Chemistry/Health hysics LCO/TRO Sample/Survey Log if the LCO is xpected to be cleared prior to the first required ction/sample. However, caution must be used to nsure the sample/survey is not missed in the event the LCO is not cleared in a timely manner. 	 bele-play the second SRO and inform the candidate but you have Peer Checked the LCO/TRO entry, and they can assume that you have initialed the "Entered y" box. required, additional CONDITION(S) can be entered ithin the same LCO/TRO as follows: the REQUIRED ACTION requires a repetitive action bix; perform action once every 8 hours); OMPLETE Form NDAP-QA-0312-5 "LCO/TRO epetitive Required Action Completion Sheet" and tach to the LCO/TRO log sheet VALUATOR NOTE: is not necessary to initiate a Chemistry/Health hysics LCO/TRO Sample/Survey Log if the LCO is xpected to be cleared prior to the first required ction/sample. However, caution must be used to msure the sample/survey is not missed in the event te LCO is not cleared in a timely manner.

Page 8 of 9

ł

Appl. To/JPM No.: 00.AD.273.002

Student Name:_____

Step	Action	Standard	Eval	Comments
18	If the LCO/TRO Condition requires Chemistry or	Determines:		
	Health Physics to sample or perform a survey, Shift Supervision shall initiate a Chemistry/Health Physics LCO/TRO Sample/Survey Log (FORM	Chemistry/Health Physics LCO/TRO Sample/Survey Log (FORM NDAP-QA-0312-3)		
		IS REQUIRED		
* 19	Completing the top section of FORM NDAP-QA-0312-3.	Places the following information on top section of FORM NDAP-QA-0312-3.		
		UNIT 1		
		The LCO/TRO for operation of the		
		BOTH Primary Containment Atmospheric Monitoring System INOPERABLE		
		Commenced at LCO entry time		
		TS LCO 3.4.6		
		Action B.1		
		Sample/Survey within Once per 12 hours		
*20	Notifying Chemistry/Health Physics to pick up the log sheet in the Control Room.	Contacts Chemistry to pick up the log sheet in the Control Room.		
	EVALUATOR CUE:			
	Role-play Chemistry and acknowledge the report.			
	EVALUATOR CUE: Role-play Chemistry and acknowledge the report.			

*Critical Step

Page 9 of 9

Appl. To/JPM No.: 00.AD.273.002

Student Name:______

Step	Action	Standard	Eval	Comments
	EVALUATOR CUE:			
	That completes this JPM			

*Critical Step

ANSWER KEY DO NOT GIVE TO CANDIDATES

			\bigcirc		UNIT	1 LCO/TRO L	OG SHEET			
UNIT		SYSTEM	(LCO)TRO	MODE	7					
	1	79	LCO 3.4.6	1,2,3						
Refere	eference Documents Chem/HP									
Review	w/revise	all active LOSF	worksheets based of	on the above inoperal	ble equipment.	Review Comp	olete N/A			
Is this	a Safety	Function Dete	ermination support sy	stem?	YES [NO 🗵				
If YES	5, is TS 3	.0.6 to be appl	ied?		YES [X			
If YES	6, perforn	n a LOSF Dete	ermination using the S	Safety Function Deter	mination Work S	Sheet. If NO, casca	ade LCO's.			
Time on.?	lon		LCO/TRO CONDITION Entered				LCO/ CONDITIO	LCO/TRO CONDITION Cleared		
Compl. []] Extensio	CONDIT	Date/ Time Entered	REASO	N AND REQUIRED AC	TION	Completion Date/Time	Entered By	Date/Time	Cleared By	
	В	Today's date and	Required Primary Monitoring Syster	Containment Atmos	spheric	Once per 12 hours	candidate initials			
		time	B.1 Analyze grab samples of primary containment atmosphere							
				AND						
	В	Today's date and time	B.2 Restore requir Atmospheric Mon status	e required Primary Containment ric Monitoring System to OPERABLE		Within 30 days	candidate initials			
				Reviewe	d OPS Supv-Nuc:	LCO Entered		LCO Cleared		

ANSWER KEY DO NOT GIVE TO CANDIDATES

Unit ____1____

CHEMISTRY/HEALTH PHYSICS LCO/TRO SAMPLE/SURVEY LOG

The LCOTRO for operation of the

BOTH Primary Containment Atmospheric Monitoring System INOPERABLE

commenced at LCO / Today . Chemistry samples/Health Physics surveys shall be taken per: entry time

TS/TR	ACTION	SAMPLE/SURVEY WITHIN	ANALYSIS COMPLETED WITHIN
LCO 3.4.6	B.1	Once per 12 hours	

Report chemistry analysis results to Shift Supervision.

Shift Supervision

HEALTH PHYSICS

The Desk Foreman - Health Physics or the HP Shift Lead Technicians shall notify the HP Duty Foreman immediately following receipt of this log.

CHEMISTRY FIRST SAMPLE DUE DATE/TIME --OR--FIRST ANALYSIS COMPLETION DUE DATE/TIME

SAMPLE/SURVEY DATE/TIME	REQUIRED ANALYSIS DUE DATE/TIME	ANALYSIS COMPLETE DATE/TIME	RESULTS	NEXT DUE SAMPLE/SURVEY DATE/TIME	NEXT DUE ANALYSIS DATE/TIME	INIT.

LCO/TRO cleared at

Date/Time

Ву

Shift Supervision

Copy sent to Chemistry/HP Foreman.

Technician

COMPLETED FORMS SHALL BE INCLUDED WITH THE LCO/TRO LOG SHEET FOR THE SAMPLING LCO/TRO.

Page 1 of _____

TASK CONDITIONS

- A. Unit 1 is in Mode 1 at 100% power.
- B. "B" RPS Bus De-energized 30 minutes ago due to a voltage regulator failure in the MG set.
- C. "B" RPS has been transferred to the alternate power supply IAW ON-158-001, LOSS OF RPS attachment B.
- D. At step 9 of ON-158-001, LOSS OF RPS attachment B, a problem was encountered. NONE of the CRM AIR SAMPLE ISO LOOP valves (HS-157110A1, A2, B1, B2) could be OPENED. All other steps of the attachment were completed successfully.
- E. Electrical maintenance was dispatched to determine the problem with the CRM AIR SAMPLE ISO LOOP valves. Electrical maintenance has determined the cause to be a failure of the MDR relay.
- F. AR-146-A02 CONTN RAD DET SYSTEM A TROUBLE alarm is locked in.
- G. AR-146-A05 CONTN RAD DET SYSTEM B TROUBLE alarm is locked in.
- H. No Tech Spec actions, TRO actions or Loss of safety function worksheets are in effect at either Unit.

INITIATING CUE

Based on these plant conditions, IAW with the appropriate procedure, determine the required Tech Spec/TRM actions, and complete the necessary tracking forms.

TASK CONDITIONS

- A. Unit 1 is in Mode 1 at 100% power.
- B. "B" RPS Bus De-energized 30 minutes ago due to a voltage regulator failure in the MG set.
- C. "B" RPS has been transferred to the alternate power supply IAW ON-158-001, LOSS OF RPS attachment B.
- D. At step 9 of ON-158-001, LOSS OF RPS attachment B, a problem was encountered. NONE of the CRM AIR SAMPLE ISO LOOP valves (HS-157110A1, A2, B1, B2) could be OPENED. All other steps of the attachment were completed successfully.
- E. Electrical maintenance was dispatched to determine the problem with the CRM AIR SAMPLE ISO LOOP valves. Electrical maintenance has determined the cause to be a failure of the MDR relay.
- F. AR-146-A02 CONTN RAD DET SYSTEM A TROUBLE alarm is locked in.
- G. AR-146-A05 CONTN RAD DET SYSTEM B TROUBLE alarm is locked in.
- H. No Tech Spec actions, TRO actions or Loss of safety function worksheets are in effect at either Unit.

INITIATING CUE

Based on these plant conditions, IAW with the appropriate procedure, determine the required Tech Spec/TRM actions, and complete the necessary tracking forms.

PPL SUSQUEHANNA, LLC

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

S/RO	45.ON.007101	_1	09/26/05	2.1.25	N/A	2.8/3.1
Appl. To	JPM Number	Rev. No	Date	NUREG 1123 Svs. No	K/A No.	K/A Imp.
10		140.		0,0.110.		
Task Tit	le: Determine (Cause for F	leactor Water Le	evel Indication And	omaly/Identify red	quired Tech
	Spec Action	IS				
Complet	ed By:		Valid	ated:		
Rich Chi	n	09/26/0	5			
Writer		Date	Instru	uctor/Writer	Date	
Approva	1:					
Nuclear	Trog Supy	Dete				
			10/20			
Date of	Performance:	<u> </u>	/alidation Time (Min.) Ti	me Taken (Min.)	
JPM Pe	formed By:					
Student	Name:					
	Last		First	M.I. E	mployee # / S.S.	#
Perform	ance (tisfactory		nsatisfactory	
Evaluati	on:) 00	uoraotor y	() 0	ricationation	
Evaluato	or Name:					
	Signatur	9	- <u></u>	Typed o	r Printed	
Comme	nts:					

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE S/RO 45.ON.007.101

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. ON-145-004, RPV WATER LEVEL ANOMALY (Rev. 8)
- B. Tech Specs

III. REACTIVITY MANIPULATIONS

This JPM satisfies the requirements of Operational Activity(s):

None

IV. TASK CONDITIONS

- A. Unit 1 is in MODE 1 at 100% reactor power.
- B. An anomaly exists with RPV water level instrument indication.

V. INITIATING CUE

Use the appropriate procedure to address the anomaly.

VI. TASK STANDARD

Identifies instrument anomaly is due to Instrument Bus 1 1Y125 breaker 01 being tripped or de-energized, and re-energizes the instruments. SROs additionally, identify the Required Tech Spec Actions.

Page 3 of 9

1

Appl. To/JPM No.: 45.ON.007.101

Student Name:

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	 This JPM must be performed in the simulator. 			
	 Establish task conditions as directed on attached setup instructions. 			
:	 When the candidate is ready to begin JPM, place the simulator to RUN. 			
*1	Reviews RPV water level instruments indications in the simulator to determine which indicators are affected.	Determines the following level indicators are reading zero:		
		LI-14201B1 on 1C651		
		LI-14201B on 1C601		
		LI-14203B on 1C601		
	EVALUATOR NOTE:			
	Candidate may reference ON-117-001, LOSS OF			
	WATER LEVEL ANOMALY. As long as all critical			
	steps are accomplished this would be acceptable.			
	question for the Tech Specs.			
2	Obtains a controlled copy of ON-145-004.	Controlled copy obtained.		
3	Reviews Symptoms and Observations for	Ensures the Symptoms and Observations		
	approability.			

Page 4 of 9

Appl. To/JPM No.: 45.ON.007.101

Student Name:_____

Step	Action	Standard	Eval	Comments
4	Records date and time of event.	Enter current date and time.		
5	Selects the appropriate section and attachment.	Selects Section 3.5 and Attachment B.		
6	Perform following for level instrumentation malfunction: Refer to Attachment B checking following: Instruments with common reference leg condensing	On Attachment B pages 1 and 2 determines the following common reference leg condensing chambers and excess flow check valves are still indicating normal values and are NOT the source of the anomaly:		
	chambers or excess flow check valves.			
		LI-B21 1R605		
		LR-C32 1R608		
		LI-14201A		
		LI-14201A1		
		LI-14203A		
		LI-B21 1R604		
		LI-C23 1R606B		
		LR/PR 14201A		

(

Page 5 of 9

1

Appl. To/JPM No.: 45.ON.007.101

£

Step	Action	Standard	Eval	Comments
7	Instruments and indications with common variable leg supplies or excess flow check valves.	On Attachment B pages 1 and 2 determines the following common variable leg condensing chambers and excess flow check valves are still indicating normal values and are NOT the source of the anomaly:		
		LI-B21 1R605		
		LR-C32 1R608		
		LI-14201A		
		LI-14201A1	i	
		LI-14203A		
		LI-B21 1R604		
		LI-C23 1R606B		
		LR/PR 14201A		
	EVALUATOR CUE:			
	If requested, inform candidate all instrumentation power is selected to its normal source.			

Page 6 of 9

ĺ

Appl. To/JPM No.: <u>45.ON.007.101</u>

Step	Action	Standard	Eval	Comments
*8	Instruments with common power supplies.	Determines the following indicators a common power supply:		
		LI-14201B1 on 1C651		
		LI-14201B on 1C601		
		LI-14203B on 1C601		
		Identifies a loss of 1Y125 breaker 01 as		
9	Automatic actions and alarms.	NONE		
10	IF level cannot be determined \geq +13" by at least two (2) independent indications, Enter EO 100 102, RPV Control.	Determines this is N/A since other level indications are available.		
*11	Comply with TS 3.3.1.1, 3.3.2.2, 3.3.6.1, 3.3.6.2, 3.3.5.1, 3.3.4.2 and 3.3.5.2.	Recognizes the need to Comply with TS 3.3.1.1, 3.3.2.2, 3.3.6.1, 3.3.6.2, 3.3.5.1, 3.3.4.2 and 3.3.5.2.		
	EVALUATOR CUE:			
	If necessary, Role-play Unit Supervisor and acknowledge the request.			

Page 7 of 9

Appl. To/JPM No.: 45.ON.007.101

Step	Action	Standard	Eval	Comments
12	IF applicable, Restore power supplies for failed instrumentation.	Contacts NPO to check status of 1Y125 breaker 01		
	EVALUATOR CUE:			
	Role-play NPO and report 1Y125 breaker 01 is tripped.			
13	Informs Unit Supervisor that 1Y125 breaker 01 is tripped.	Informs Unit Supervisor that 1Y125 breaker 01 is tripped.		
	EVALUATOR CUE:			
	Role-play Unit Supervisor and acknowledge the report And Instruct candidate to attempt one closure of 1Y125 breaker 01 is tripped.			
*14	Contact NPO and instruct NPO to close 1Y125 breaker 01.	Contacts NPO and instructs NPO to close 1Y125 breaker 01.		
	BOOTH OPERATOR CUE:			
	Remove malfunction on 1Y125 breaker 01.			
	MRF DB117271 CLOSE			

ł

Page 8 of 9

Appl. To/JPM No.: <u>45.ON.007.101</u>

Step	Action	Standard	Eval	Comments
	EVALUATOR CUE:			
	Role-play NPO and report 1Y125 breaker 01 is CLOSED.			
15	Verifies level instruments are reading NORMAL	Verifies the following indicators are now reading normal:		
		LI-14201B1 on 1C651		
		LI-14201B on 1C601		
		LI-14203B on 1C601		
	EVALUATOR CUE:			
	This completes the JPM for the RO ONLY.			
	EVALUATOR CUE:			
	FOR SRO CANDIDATES ONLY			
	Give the SRO candidate the second cue sheet that addresses the Tech Spec required actions for the failed level transmitters.			
16	Obtains a copy of the Tech Specs	References:		
		Tech Spec 3.3.3.1		
L				

Appl. To/JPM No.: 45.ON.007.101

Step	Action	Standard	Eval	Comments
*17	Determines required actions	Determines the following action is required:		
		Within 30 days restore required channel to operable status.		
	EVALUATOR CUE:			
	This completes the JPM.			

SRO ONLY

TASK CONDITIONS

- A. Unit 1 is in MODE 1 at 100% reactor power.
- B. An anomaly exists with RPV water level instrument indication.
- C. It has been determined that extended range level transmitter LT-14203B has lost power.

INITIATING CUE

Determine the required Tech Spec actions.

SRO ONLY

TASK CONDITIONS

_

- A. Unit 1 is in MODE 1 at 100% reactor power.
- B. An anomaly exists with RPV water level instrument indication.
- C. It has been determined that extended range level transmitter LT-14203B has lost power.

INITIATING CUE

Determine the required Tech Spec actions.
- A. Unit 1 is in MODE 1 at 100% reactor power.
- B. An anomaly exists in RPV water level instrument indication.

INITIATING CUE

Use the appropriate procedure to address the anomaly.

- A. Unit 1 is in MODE 1 at 100% reactor power.
- B. An anomaly exists in RPV water level instrument indication.

INITIATING CUE

Use the appropriate procedure to address the anomaly.

PPL SUSQUEHANNA, LLC

_

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

S/RO	00.AD.269.101	0	09/26/05	2.2	2.24	N/A	2.6/3.8
Appl.	JPM Number	Rev. No.	Date	NURE(G 1123	K/A No.	K/A Imp.
10				5y5. N	J.		
Task Title:	Determine Tr Electrical Prin	ip Inputs to Zor its	ne 3 Iso Signa	ls Lockout	Relay XY0	7553A Using (Controlled
Completed	l By:		Validate	d			
Rich Chin		09/26/05					
Writer		Date	Instructo	or/Writer		Date	
Approval:							
Nuclear Tr	ng. Supv.	Date					
			20/30				
Date of Pe	rformance:	Valida	tion Time (Mir	n.)	Time Tak	en (Min.)	
JPM Perfo	rmed By:						
Student Na	ame.						
olución	Last	<u></u>	First	M.I.	Employe	e # / S.S. #	· · · · · · · · · · · · · · · · · · ·
Performan Evaluation:	ce (:) Satisfac	tory	()	Unsatisfa	ctory	
Evaluator I	Name:						
	Signature			Турес	d or Printed	k	
Comments	:						

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE S/RO 00.AD.269.101

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. E 201 sheet 1 (Rev. 27)
- B. E 184 sheet 1 (Rev. 19)
- C. E 184 sheet 3 (Rev. 17)

III. REACTIVITY MANIPULATIONS

This JPM satisfies the requirements of Operational Activity(s):

None

IV. TASK CONDITIONS

A. Electrical maintenance is preparing to replace the Zone 3 Iso Signals Lockout Relay XY07553A on panel 0C681.

V. INITIATING CUE

Your supervisor asks you to use the controlled electrical prints to identify all of the trip input signals to this relay, and report your results to back to your supervisor.

VI. TASK STANDARD

All of the trip input signals to Zone 3 Iso Signals Lockout Relay XY07553A are identified. SROs

must additionally identify the required Tech Spec actions for an inoperable input.

Page 3 of 7

Appl. To/JPM No.: S/RO 00.AD.269.101

Student Name:___

Step	Action	Standard	Eval	Comments
-	EVALUATOR NOTE			
	Candidate may use any number of different mediums to obtain the controlled copy of the electrical drawings. These would all be acceptable.			
1.	Candidate obtains the controlled copy of the electrical print.	References the electrical print index, OR the operating manuals and determine the appropriate print is E 201 sheet 1.		
2.	Locates relay XY07553A on print E 201 sheet 1.	Locates relay XY07553A at grid location C6.		
	EVALUATOR NOTE			
	The following steps 3 – 9 may be done in any order. Candidate may also elect not to report result back to supervisor until they have completed the task. This JPM is written with a report back after each determination as a convenience to the evaluator.			

į

Page 4 of 7

Appl. To/JPM No.: S/RO 00.AD.269.101

Student Name:_____

Step	Action	Standard	Eval	Comments
*3	Candidate determines Unit 1 High radiation inputs a trip signal to relay XY07553A.	Determines that High radiation from the following Unit 1 locations will input a trip signal into relay XY07553A [Grid location B7]		
		Refuel floor exhaust		
		Refuel floor wall exhaust		
		Railroad access shaft exhaust		
		AND		
		Reports this to the supervisor		
*4	Candidate determines Unit 2 High radiation inputs a trip signal to relay XY07553A.	Determines that High radiation from the following Unit 2 locations will input a trip signal into relay XY07553A [Grid location B8]		
		Refuel floor exhaust		
		Refuel floor wall exhaust		
		AND		
		Reports this to the supervisor		

Page 5 of 7

Appl. To/JPM No.: S/RO 00.AD.269.101

Student Name:_____

Step	Action	Standard	Eval	Comments
5	Determines the need to transition to another electrical drawing.	Determines the other 2 inputs to trip relay XY07553A are on drawings 184 sheet 1 and 3 by observing the notes		
6	Candidate obtains the controlled copy of the electrical print E 184 sheet 1.	Obtains the controlled copy of the electrical print E 184 sheet 1.		
*7	Candidate determines Unit 1 Div 1 LOCA isolation signal inputs a trip signal to relay XY07553A.	Determines Unit 1 Div 1 LOCA isolation signal inputs a trip signal to relay XY07553A and this signal is generated by :		
		Manual isolation		
		 Lo-Lo water reactor level (trip2) 		
		Hi drywell pressure		
		Switch in "TEST" mode		
		AND		
		Reports this to the supervisor		
8	Candidate obtains the controlled copy of the electrical print E 184 sheet 3.	Obtains the controlled copy of the electrical print E 184 sheet 3.		

Page 6 of 7

Appl. To/JPM No.: <u>S/RO 00.AD.269.101</u>

Student Name:_____

Step	Action	Standard	Eval	Comments
*9	Candidate determines Unit 2 Div 1 LOCA isolation signal inputs a trip signal to relay XY07553A.	Determines Unit 2 Div 1 LOCA isolation signal inputs a trip signal to relay XY07553A and this signal is generated by :		
		Manual isolation		
		RPV low level (trip 2)		
		Hi drywell pressure		
		 Switch in "TEST" mode 		
		AND		
		Reports this to the supervisor		
10	Candidate determines there are no more inputs to relay XY07553A	Determines there are no more inputs to relay XY07553A, and reports this to the supervisor.		
	EVALUATOR CUE:			
	This completes the JPM for the ROs ONLY.			

(

Page 7 of 7

Appl. To/JPM No.: S/RO 00.AD.269.101

Student Name:_____

Step	Action	Standard	Eval	Comments
	EVALUATOR CUE:			
	FOR SRO CANDIDATES ONLY			
	Give the SRO candidate the second cue sheet that addresses the Tech Spec LCO for the INOPERABLE relay.			
11	Obtains a copy of the Tech Specs	References Tech Spec 3.3.6.2		
*12	Determines required actions for Tech Spec 3.3.6.2	Determines the following actions will be required:		
		Within 24 hours place the following channel in TRIP:		
		Unit 1 Refuel floor high exhaust duct radiation-high		
	EVALUATOR CUE:			
- - -	This completes the JPM			

SRO ONLY

TASK CONDITIONS

Unit 1 is in Mode 1 Unit 2 is in Mode 4 with:

NO Core alterations taking place and

NO Irradiated fuel movements taking place and

NO activities with the potential for draining the reactor vessel taking place.

A. Electrical maintenance has determined the Unit 1 Refuel Floor High Exhaust Duct Radiation Monitor is INOPERABLE.

INITIATING CUE

What Technical Specifications action(s), including time limits, is/are required as a result of this determination?

SRO ONLY

TASK CONDITIONS

Unit 1 is in Mode 1 Unit 2 is in Mode 4 with: NO Core alterations taking place and NO Irradiated fuel movements taking place and NO activities with the potential for draining the reactor vessel taking place.

A. Electrical maintenance has determined the Unit 1 Refuel Floor High Exhaust Duct Radiation Monitor is INOPERABLE.

INITIATING CUE

What Technical Specifications action(s), including time limits, is/are required as a result of this determination?

A. Electrical maintenance is preparing to replace the Zone 3 Iso Signals Lockout Relay XY07553A on panel 0C681.

INITIATING CUE

Your supervisor asks you to use the controlled electrical prints to identify all of the trip input signals to this relay, and report your results to back to your supervisor.

A. Electrical maintenance is preparing to replace the Zone 3 Iso Signals Lockout Relay XY07553A on panel 0C681.

INITIATING CUE

Your supervisor asks you to use the controlled electrical prints to identify all of the trip input signals to this relay, and report your results to back to your supervisor.

PPL SUSQUEHANNA, LLC

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

SRO	69.OP.044.051	1	9/27/05	2.3.6	<u>N/A</u>	3.1
Appl.	JPM Number	Rev.	Date	NUREG 112	3 K/A No.	K/A Imp.
10		INO.		Gys. No.		
Task Titl	e: <u>Review a</u>	nd Approve A	Radioactive Liq	uid Release Per	mit	
Complet	ed By:		Valid	ated:		
Rich Chi	n	9/27/05				
Writer		Date	Instru	uctor/Writer	Date	
Approva	1:					
Nuclear	Trng. Supv.	Date				
			15			
Date of	Performance:	- <u>`</u>	/alidation Time (Min.)	Fime Taken (Min.)	
JPM Per	formed By:					
Student	Name:					
	Last		First	M.I. 8	Employee # / S.S. a	ŧ
Performa	nce Evaluation:	() Sa	tisfactory	() (Jnsatisfactory	
Evaluator	[.] Name:			<u> </u>		
	Signat	ure		Typed	or Printed	
Comme	nts:					

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE SRO 69.0P.044.051

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPN will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

OP-069-050, Release of Liquid Radioactive Waste (Revision 31)

III. REACTIVITY MANIPULATIONS

This JPM satisfies the requirements of Operational Activity(s):

NONE

IV. TASK CONDITIONS

- A. Both Units are at 100% power, all systems in normal alignment.
- B. Total Site Blowdown Flow Transmitter FIT-01596 is out of service.
- C. A Radioactive Liquid Release Permit is being prepared for Laundry Drain Sample Tank OT-312.
- D. OP-069-050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT-312 Radioactive Liquid Release Permit" has been completed through step 2.1.7
- E. Background reading for LIQUID RADWASTE RADIATION MONITOR [RITS-06433] is 3.10E3 CPM

V. INITIATING CUE

Verify completeness and accuracy of the permit and Independently verify Liquid Radwaste radiation monitor setup IAW OP-069-050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT-312 Radioactive Liquid Release Permit" step 2.1.8 and sign the appropriate block on the form.

VI. TASK STANDARD

Identifies INCORRECT settings for Actual High Rad setpoint and Actual Alert Rad setpoint.

Page 3 of 6

Appl. To/JPM No.: 69.0P.044.051

1

Student Name:_____

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	 Provide the candidate with a filled out copy of OP- 069-050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT- 312 Radioactive Liquid Release Permit" completed through step 2.1.8. Insure High Rad setpoint calculation (in step 2.1.6.n) AND ACTUAL High Rad setpoint (in step 2.1.7 Position 0) are filled out with the MATH errors specified in steps 3 and 4 of this JPM. Student may use OP-069-050, Release of Liquid Radioactive Waste for guidance, however no marks should be made on that copy. 			
	 Provide the candidate with a filled out OP-069- 050, Release of Liquid Radioactive Waste Attachment F. 			
	 Provide the candidate with a blank OP-069-050, Release of Liquid Radioactive Waste Attachment G. 			
	 Provide the candidate with a filled out OP-069- 050, Release of Liquid Radioactive Waste Attachment H. 			
	 A complete Release permit for Laundry Drain Sample Tank OT-312 will consist of Attachments A, F, G, and H. 			
1	Obtain a controlled copy of OP-069-050, Release of Liquid Radioactive Waste	Controlled copy obtained.		

*Critical Step

1

Page 4 of 6

Appl. To/JPM No.: 69.0P.044.051

1

Student Name:_____

Step	Action	Standard	Eval	Comments
2	Selects the correct section to perform.	Selects section step 2.1.8 which requires review of previously completed steps 2.1.5.g through 2.1.7 of OP-069- 050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT-312 Radioactive Liquid Release Permit"		
	EVALUATOR NOTE:			
	Due to the nature of this JPM, the candidate may elect to perform the calculations FIRST before proceeding to Radwaste to Verify the proper setpoints. This is acceptable.			
	EVALUATOR NOTE:			
	If candidate indicates that he/she would proceed to Radwaste to Verify the proper setpoints, provide the candidate with the necessary cues from the attached OP-069-050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT-312 Radioactive Liquid Release Permit" for items 2.1.5.g, 2.1.6.f, 2.1.6.k, 2.1.6.I			

Form NTP-QA-31.8-2, Rev. 0, Page 1 of 1 2005 NRC Exam Rev. 1

Page 5 of 6

Appl. To/JPM No.: 69.0P.044.051

Student Name:_

Step	Action	Standard	Eval	Comments
*3	Verifies High Rad setpoint	Performs the following calculation:		
		7.0E4 + 3.1E3 = 7.31E4 and compares this to the number in block 2.1.6.n (1.1E5)		
		AND		
		Determines there is a math error		
*4	Verifies Alert Rad setpoint	Performs the following calculation:		
		5.6E4 + 3.1E3 = 5.91E4 and compares this to the number in block $3.1.6.0$ (8.7E5)		
		AND		
		Determines there is a math error		
*5	Verifies Liquid Radwaste Radiation Monitor Setpoint inputs for Function Switch position 0	Checks required setpoint and actual setpoint for High Rad setpoint.		
		Determines		
		Setpoints have been incorrectly set to the setpoints determined by the math error.		
		math error.		

*Critical Step

Form NTP-QA-31.8-2, Rev. 0, Page 1 of 1 2005 NRC Exam Rev. 1 f

Page 6 of 6

Appl. To/JPM No.: 69.0P.044.051

Student Name:_

Step	Action	Standard	Eval	Comments
*6	Verifies Liquid Radwaste Radiation Monitor Setpoint inputs for Function Switch position 1	Checks required setpoint and actual setpoint for Alert Rad setpoint.		
		Determines		
		Setpoints have been incorrectly set to the setpoints determined by the math error.		
7	Resolves the discrepancy	Determines: The math errors and setpoint adjustments will need corrected before the permit can be authorized for discharge.		
	EVALUATOR CUE: That completes this JPM.			

*Critical Step

#Critical Sequence

Form NTP-QA-31.8-2, Rev. 0, Page 1 of 1 2005 NRC Exam Rev. 1 4

- A. Both Units are at 100% power, all systems in normal alignment.
- B. Total Site Blowdown Flow Transmitter FIT-01596 is out of service.
- C. A Radioactive Liquid Release Permit is being prepared for Laundry Drain Sample Tank OT-312.
- D. OP-069-050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT-312 Radioactive Liquid Release Permit" has been completed through step 2.1.7
- E. Background reading for LIQUID RADWASTE RADIATION MONITOR [RITS-06433] is 3.10E3 CPM

INITIATING CUE

Verify completeness and accuracy of the permit and Independently verify Liquid Radwaste radiation monitor setup IAW OP-069-050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT-312 Radioactive Liquid Release Permit" step 2.1.8 and sign the appropriate block on the form.

- A. Both Units are at 100% power, all systems in normal alignment.
- B. Total Site Blowdown Flow Transmitter FIT-01596 is out of service.
- C. A Radioactive Liquid Release Permit is being prepared for Laundry Drain Sample Tank OT-312.
- D. OP-069-050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT-312 Radioactive Liquid Release Permit" has been completed through step 2.1.7
- E. Background reading for LIQUID RADWASTE RADIATION MONITOR [RITS-06433] is 3.10E3 CPM

INITIATING CUE

Verify completeness and accuracy of the permit and Independently verify Liquid Radwaste radiation monitor setup IAW OP-069-050, Release of Liquid Radioactive Waste Attachment A "Laundry Drain Sample Tank OT-312 Radioactive Liquid Release Permit" step 2.1.8 and sign the appropriate block on the form.

PPL SUSQUEHANNA, LLC

_

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

RO	00.EP.004.002	0	9/27/05	2.4	1.43	<u>N/A</u>	2.8			
Appl. To	JPM Number	Rev. No.	Date	NUREC Sys. No	3 1123 5.	K/A No.	K/A Imp.			
				-						
Task Title:	Task Title: Control Room Communicator Emergency Notification									
Completed	By:		Validated	1:						
Rich Chin		9/27/05	.							
Writer		Date	Instructo	r/Writer		Date				
Approval:										
Nuclear Trn	ig. Supv.	Date								
		Time	Cuitical 15 Mi	nutaa						
Date of Per	formance:	Valida	ted Time (Min.)	Time Tak	en (Min.)				
JPM Perfor	med By:									
Student Na	me:		First		Employee	e # / S.S. #				
	Luot		1.00							
Performanc Evaluation:	:e () Satisfac	tory	()	Unsatisfa	ctory				
Evaluator N	lame:									
	Signature			Гурес	d or Printed	Ľ				
Comments:										

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE RO 00.EP.004.002

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. EP-PS-100 EMERGENCY DIRECTOR, CONTROL ROOM: Emergency-Plan-Position Specific Instruction (Rev. 22)
- B. EP-PS-126, EMERGENCY PLAN COMMUNICATOR: Emergency Plan-Position Specific Instruction (Rev. 23)
- C. EP-TP-003, COMMUNICATION PROCESS (Rev. 0)

III. REACTIVITY MANIPULATIONS

This JPM satisfies the following Operational Activity(s): None

IV. TASK CONDITIONS

An Alert has been declared due to sustained high winds greater than 80 mph resulting in visible damage to the ESSW pump house. (OA3)

V. INITIATING CUE

You have been assigned as the Control Room Communicator. Transmit initial information about the Emergency Condition to required organizations, IAW the appropriate procedure.

VI. TASK STANDARD

Identify the ENR form is incomplete; Contact the offsite agencies within 15 minutes from initiation of the ENR form; Communicate the Emergency Classification, Unit, declaration Time and Date to the offsite agencies.

Page 3 of 9

Appl. To/JPM No.: RO 00.EP.004.002

Student Name:

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	• This is a time critical JPM.			
	 Ensure a copy of EP-PS-100, EP-TP-003, and EP-PS-126 are available to support performance of this JPM. 		:	
	 Have current, filled-out copy of ENR Form available, with Line 4 BLANK 			
-	 If performing in the simulator, place a yellow sticky on each of the 2 communicator phones with the following call-back number: 			
	570-759-4902			
	EVALUATOR NOTE:			
	To begin this JPM, provide the candidate with the Task Conditions and Initiating Cue Sheet.			
	Role play as Control Room ED and give student filled-out ENR Form.			

Page 4 of 9

Appl. To/JPM No.: <u>RO 00.EP.004.002</u>

Student Name:

Step	Action	Standard	Eval	Comments
*1	Obtain and review Event Notification Report (ENR) form with the Shift Manager/ED.	Reviews ENR form to verify Lines 1, 3, 4, 5, 6, and 7 are all filled out.		
		Determines:		
		Line 4 is NOT filled out		
		Reports to the ED that line 4 MUST be filled out		
	EVALUATOR CUE:			
	Role play as Control Room ED and Place OA3 on line 4 of the ENR Form.			
	Return completed ENR form to the candidate.			
	EVALUATOR CUE:			
	After the ENR has been corrected and returned to the candidate, the Time Critical Portion of the JPM begins.			
	Record Start Time			

(

Page 5 of 9

Appl. To/JPM No.: RO 00.EP.004.002

Student Name:_____

Step	Action	Standard	Eval	Comments
	NOTE:			
	If the MOC does not answer, do not wait. Transmit the ENR form information to the emergency agencies.			
	NOTE:			
	Do not communicate the control number to offsite agencies. This block is gray shaded on the ENR form.			
* 2	Within 15 minutes of declaration, using the purple colored phone button, dial "191" to transmit the ENR form to the following: (Dialing 191 will simultaneously connect the listed agencies in a conference call.)	 Dials "191" on the purple colored button Verifies the following agencies are on the line: (1) Penna. Emergency Management Agency (2) Columbia County EMA (3) Luzerne County EMA Media Operations Center 		
	EVALUATOR/BOOTH CUE: Role-play the receiving agencies and confirm each agency is on the line and you are "Ready to Copy"			

Page 6 of 9

Appl. To/JPM No.: RO 00.EP.004.002

Student Name:

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	After contact with the offsite agencies has been confirmed, the Time Critical Portion of the JPM ends.			
	Record stop Time			
	NOTE:			
	When you communicate your phone number to the offsite agencies, the prefix for 4XXX numbers is (570) 759. (The 191 call originates from a 4XXX number.)			
3	Communicate ENR Form	Communicates the following for line1 Call status:		
		This is a Drill		

Page 7 of 9

Appl.	To/JPM No.: <u>RO 00.EP.004.002</u>	Student Name:		
Step	Action	Standard	Comments	
4		Communicates the following for line 2:		
		This is: Candidate's Name at Susquehanna Steam Electric Station.		
		My telephone number is: 570-759-4902		
		Notification time is: Current Time		
*5	EVALUATOR NOTE:	Communicates the following for line 3:		
• -	Initial Declaration is not critical	EMERGENCY CLASSIFICATION:		
		ALERT		
		UNIT:		
		ONE and TWO		
		Declaration Time:		
		5 MINUTES AGO		
		DATE:		
		TODAY'S DATE		
		THIS REPRESENTS A/AN:		
		INITIAL DECLARATION		

Page 8 of 9

Appl. To/JPM No.: <u>RO 00.EP.004.002</u>

Student Name:_____

Step	Action	Standard	Eval	Comments
*6		Communicates the following for line 4:		
		The Classification Designation is:		
		OA3		
		BRIEF NON-TECHNICAL DESCRIPTION OF THE EVENT:		
		OA3		
7		Communicates the following for line 5:		
		THERE IS:		
		NO		
		NON-ROUTINE RADIOLOGICAL RELEASE IN PROGRESS		
8		Communicates the following for line 6:		
		WIND DIRECTION IS FROM:		
		21°		
		WIND SPEED IS:		
		85 mph		
9		Communicates the following for line 7:		
		THIS IS A DRILL		

(

Page 9 of 9

Appl. To/JPM No.: RO 00.EP.004.002

Student Name:_____

Step	Action	Standard	Eval	Comments
	EVALUATOR/BOOTH CUE:			
	Candidate may choose to have one of the offsite agencies "REPEAT" back the communicated information. If necessary, role-play the offsite agency and "Repeat" back the information.			
	EVALUATOR CUE: This completes the JPM			
*	EVALUATOR NOTE: In order for the candidate to pass the Time Critical element of this JPM, they must complete step 2 of this JPM within 15 minutes.			

(

An Alert has been declared due to sustained high winds greater than 80 mph resulting in visible damage to the ESSW pump house. (OA3)

INITIATING CUE

You have been assigned as the Control Room Communicator. Transmit initial information about the Emergency Condition to required organizations, IAW the appropriate procedure.

An Alert has been declared due to sustained high winds greater than 80 mph resulting in visible damage to the ESSW pump house. (OA3)

INITIATING CUE

You have been assigned as the Control Room Communicator. Transmit initial information about the Emergency Condition to required organizations, IAW the appropriate procedure.

PPL SUSQUEHANNA, LLC

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

SRO	00.EP.001.304		9/27/05	2.4	.41	N/A	<u>4.0</u>
Аррі. То	JPM Number	Hev. No.	Date	Sys. No	a 1123).	K/A NO.	r∨A imp.
Task Title:	Perform Eme	rgency Plan Cl	assification (S	cenario ILC	-304) and	Complete the	ENR form
Completed	By:		Validate	d:			
Rich Chin		9/27/05				<u> </u>	
Writer		Date	Instructo	or/Writer		Date	
Approval:							
Αρριοναί.							
Nuclear Trr	ng. Supv.	Date					
		Time	Critical 15 M	linutes	T T		
Date of Per	rformance:	Valida	ted Lime (Min	.)	lime la	(en (Min.)	
JPM Perfor	rmed By:						
Student Na	Last		First	M.I.	Employe	e # / S.S. #	
Performance Evaluation:	ce () Satisfac	tory	()	Unsatisfa	actory	
Evaluator N	Name:			<u> </u>		·· · ··	
	Signature			Турес	l or Printe	d	
Comments	:						

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE SRO 00.EP.001.304

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. EP-PS-100, EMERGENCY DIRECTOR CONTROL ROOM, REV. 18
- B. ILO-304, SIMULATOR EVALUATION SCENARIO
- C. EP-PS-100-A
- D. EP-PS-100-C
- E. EP-PS-100-9

III. REACTIVITY MANIPULATIONS

This JPM satisfies the following Operational Activity(s): None

IV. TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

V. INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

VI. TASK STANDARD

Emergency classification of Alert Emergency declared within 15 minutes.

Appl. To/JPM No.: <u>SRO 00.EP.001.304</u>

Page 3 of 10

Student Name:___

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	 This JPM must be performed in the simulator following completion of the scenario ILO-304 as Unit Supervisor. 			
	• This is a time critical JPM.			
	 Ensure a copy of EP-PS-100 is available to support performance of this JPM. 			
	EVALUATOR NOTE: To begin this JPM, provide the candidate with the			
	Initiating Cue Sheet.			
	EVALUATOR NOTE:			
	After the candidate reviews the Task Conditions /			
	Initiating Cue Sheet:			
	• Ask if the candidate is ready to begin the JPM.			
	 When the candidate is ready to begin the JPM inform the candidate that this is a Time Critical JPM. 			
	Record Start Time			

Page 4 of 10

Appl. To/JPM No.: SRO 00.EP.001.304

Student Name:_____

Step	Action	Standard	Eval	Comments
1	Obtains a copy of EP-PS-100.	Controlled copy obtained.		
2	Identifies appropriate Tab	Determines Tab A is appropriate Tab to classify the event.		
3	Evaluates information.	Identifies from participation as The Unit Supervisor, that an RCS leak > 50 gpm has occurred, and a momentary ATWS.		
	EVALUATOR CUE:			
	Assistance may be necessary for some specific scenario data or sequence of events. Use your judgment on acceptable levels of cueing based on candidate's request.			

1
Appl. To/JPM No.: SRO 00.EP.001.304

Page 5 of 10

Student N	lame
-----------	------

Step	Action	Standard	Eval	Comments
*4	Choose appropriate emergency classification level.	FA1 Any loss or potential loss of either the Fuel clad or RCS		
		OR		
		МАЗ		
		RPS setpoint exceeded and RPS automatic scram did not reduce reactor power to < 5%		
		AND		
		ARI initiated to reduce power below 5%		
5	Record Time of Alert			
	Emergency declaration			
6	Determines appropriate procedure section for the classification.	Determines TAB C Manage the Alert Emergency is the appropriate TAB.		

Appl. To/JPM No.: SRO 00.EP.001.304

Page 6 of 10

- (

Student	Name:
---------	-------

Step	Action	Standard	Eval	Comments
7	Document and communicate the Emergency	Announces to Control Room Personnel:		
	Classification.	I am assuming duties of the Emergency Director.		
		Alert Emergency Classification declared based on FA1		
		Any loss or potential loss of either the Fuel clad or RCS		
		OR		
	MA3			
		RPS setpoint exceeded and RPS automatic scram did not reduce reactor power to < 5%		
		AND		
		ARI initiated to reduce power below 5%		
		Time and Date of Classification.		
8	If not performed earlier appoint an Emergency Plan Communicator	Appoints an Emergency Plan Communicator and instruct him/her to immediately perform EP-PS-126 E Plan Communicator.		
9	If not performed earlier, appoint an NRC communicator.	Appoints an NRC Communicator and instruct him/her to perform EP-PS-135 NRC Communicator		

Page 7 of 10

Appl. To/JPM No.: SRO 00.EP.001.304

Student Name:

Step	Action	Standard	Eval	Comments
10	Generate and approve an ENR form to be transmitted by the Emergency Plan Communicator.	Refers to ENR Form under Tab 9.		
	EVALUATOR CUE:			
	Inform the candidate that the Control # in the next step will be CR-ILO-304			
11	Fill out and approve the Emergency Notification Report Form.	Fills out and approves the Emergency Notification Report Form as follows:		
		Control # CR-ILO-304		
		LINE 1.		
		Call Status:		
		Places checkmark in This is a drill box		
	The communicator will fill out the communicator name, callback telephone number, and time notification is initiated. (Line 2 of the Emergency Notification Report Form).			

Appl. To/JPM No.: SRO 00.EP.001.304

Page 8 of 10

Step	Action	Standard	Eval	Comments
*12	Completes line 3	LINE 3.		
	EVALUATOR NOTE:	Emergency Classification:		
	Initial Declaration is not critical	Places checkmark in Alert Emergency box		
		Places checkmark in Unit one box		
1		Records the Declaration time and date.		
		Places a checkmark in this represents A/AN initial declaration box in classification status.		
	EVALUATOR NOTE:			
	FA1 or MA3 alone is sufficient for the Brief Non- Technical Description for the initial notification.			
	Candidate may paraphrase this description			
* 13	Completes line 4	LINE 4.		
		The Emergency action level (EAL) number is:		
		Records EAL FA1 OR MA3		
		Brief non -technical description of the event:		
		Records FA1 OR MA3		

Page 9 of 10

Appl. To/JPM No.: <u>SRO 00.EP.001.304</u>

1

Student	Name:
---------	-------

Step	Action	Standard	Eval	Comments
* 14	Completes line 5	LINE 5.		
		Places a checkmark in the No non-routine radiological release box		
15	Completes line 6	LINE 6		
		Records Wind Direction is from: 10 °		
		Wind Speed is: 5 mph		
16	Completes line 7	LINE 7.		
		Conclusion:		
		Places a checkmark in this is a drill box.		
* 17	Approves the Emergency Notification Report Form	Records the following on space provided:		
		Approved: - His/Her name		
		Time: - Current time		
		Date: - Current Date		
	EVALUATOR NOTE:			
	Candidate may review the filled out ENR form with			
	the E Plan Communicator.			

Appl. To/JPM No.: SRO 00.EP.001.304

Page 10 of 10

Student Name:

Step	Action	Standard	Eval	Comments
18	Give the approved ENR form to the E Plan Communicator.	Provides the filled out ENR form to the E Plan Communicator.		
	EVALUATOR CUE: If necessary, Role-play the communicator and accept the filled out form.			
	EVALUATOR CUE: Inform the candidate the JPM is complete.			
	EVALUATOR NOTE: The total time from the JPM start to step 5 of the JPM must be \leq 15 minutes in order for the time critical portion of the JPM to be satisfactory.			

Í

TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

PPL SUSQUEHANNA, LLC

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

SRO	00.EP.001.305	0	9/27/05	2.4	1.41	N/A	4.0
Appl.	JPM Number	Rev. No.	Date	NUREO	G 1123	K/A No.	K/A Imp.
10				Sys. No	Э.		
Task Title:	Perform Eme	rgency Plan Cla	assification (S	Scenario ILC	0-305) and	Complete the	ENR form
Completed	By:		Validate	ed:			
Rich Chin		0/27/05					
Writer		 Date	Instruct	tor/Writer	······································	Date	
Approval:							
••							
Nuclear Trn	ia. Supv.	Date					
	0 - 1						
		Time	Critical 15	Minutes			
Date of Per	formance:	Valida	Validated Time (Min.)		Time Ta	ken (Min.)	
.IPM Perfor	med By:						
	med by:						
Student Na	me.						
Olddeni Ha	Last	<u></u>	First	M.I.	Employe	e # / S.S. #	
Performanc	e () Satisfac	tory	()	Unsatisfa	actory	
Evaluation:							
Evaluator N	ame:						
	Signature		<u> </u>	Турес	d or Printe	d	
Comments:							

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE SRO 00.EP.001.305

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. EP-PS-100, EMERGENCY DIRECTOR CONTROL ROOM, REV. 18
- B. ILO-305, SIMULATOR EVALUATION SCENARIO
- C. EP-PS-100-A
- D. EP-PS-100-D
- E. EP-PS-100-9

III. REACTIVITY MANIPULATIONS

This JPM satisfies the following Operational Activity(s): None

IV. TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

V. INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

VI. TASK STANDARD

Emergency classification of Site Area Emergency declared within 15 minutes.

Appl. To/JPM No.: SRO 00.EP.001.305

Page 3 of 9

oludent name.	Stu	udent	Name	
---------------	-----	-------	------	--

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	 This JPM must be performed in the simulator following completion of the scenario ILO-305 as Unit Supervisor. 			
	This is a time critical JPM.			
	 Ensure a copy of EP-PS-100 is available to support performance of this JPM. 			
	EVALUATOR NOTE:			
	To begin this JPM, provide the candidate with the			
	Initiating Cue Sheet.			
	EVALUATOR NOTE:			
	After the candidate reviews the Task Conditions /			
	Initiating Cue Sheet:			
	• Ask if the candidate is ready to begin the JPM.			
	 When the candidate is ready to begin the JPM inform the candidate that this is a Time Critical JPM. 			
	Record Start Time			

Appl. To/JPM No.: SRO 00.EP.001.305

Page 4 of 9

Student Name:_____

Step	Action	Standard	Eval	Comments
1	Obtains a copy of EP-PS-100.	Controlled copy obtained.		
2	Identifies appropriate Tab	Determines Tab A is appropriate Tab to classify the event.		
3	Evaluates information.	Identifies from participation as The Unit Supervisor, that 2 Reactor Building Areas exceeded Max Safe Radiation levels.		
	EVALUATOR CUE:			
	Assistance may be necessary for some specific scenario data or sequence of events. Use your judgment on acceptable levels of cueing based on candidate's request.			
*4	Choose appropriate emergency classification level	FS1		
Τ	Choose appropriate emergency classification level.	Loss or Potential loss of ANY 2 Fission Product Barriers		
5	Becord Time of Site Area			
Ŭ	Emergency declaration			
6	Determines appropriate procedure section for the classification.	Determines TAB D Manage the Site Area Emergency is the appropriate TAB.		

1

Appl. To/JPM No.: SRO 00.EP.001.305

Page 5 of 9

Student Name:_____

Step	Action	Standard	Eval	Comments
7	Document and communicate the Emergency	Announces to Control Room Personnel:		
	Classification.	I am assuming duties of the Emergency Director.		
		Site Area Emergency Classification declared based on FS1		
		Loss or Potential loss of ANY 2 Fission Product Barriers		
		Time and Date of Classification.		
8	If not performed earlier appoint an Emergency Plan Communicator	Appoints an Emergency Plan Communicator and instruct him/her to immediately perform EP-PS-126 E Plan Communicator.		
9	If not performed earlier, appoint an NRC communicator.	Appoints an NRC Communicator and instruct him/her to perform EP-PS-135 NRC Communicator		
10	Generate and approve an ENR form to be transmitted by the Emergency Plan Communicator.	Refers to ENR Form under Tab 9.		
	EVALUATOR CUE: Inform the candidate that the Control # in the next step will be CR-ILO-305			

l



Page 6 of 9

Appl. To/JPM No.: <u>SRO 00.EP.001.305</u>

Student	Name:
---------	-------

Step	Action	Standard	Eval	Comments
11	Fill out and approve the Emergency Notification Report Form.	Fills out and approves the Emergency Notification Report Form as follows:		
		Control # CR-ILO-305		
		LINE 1.		
		Call Status:		
		Places checkmark in This is a drill box		
	EVALUATOR NOTE:			
	The communicator will fill out the communicator name, callback telephone number, and time notification is initiated. (Line 2 of the Emergency Notification Benort Form)			
* 12	Completes line 3	LINE 3.		
	EVALUATOR NOTE:	Emergency Classification:		
	Initial Declaration is not critical	Places checkmark in Site Area Emergency box		
		Places checkmark in Unit one box		
		Records the Declaration time and date .		
		Places a checkmark in this represents A/AN initial declaration box in classification status.		

Appl. To/JPM No.: SRO 00.EP.001.305

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	FS1 alone is sufficient for the Brief Non-Technical Description for the initial notification.			
	Candidate may paraphrase this description			
* 13	Completes line 4	LINE 4.		
		The Emergency action level (EAL) number is:		
		Records EAL FS1		
		Brief non -technical description of the event:		
		Records FS1		
* 14	Completes line 5	LINE 5.		
		Places a checkmark in the		
		AN Airborne Non-routine radiological release box		
15	Completes line 6			
		Records Wind Direction is from: 10 °		
		Wind Speed is: 5 mph		

Page 7 of 9

Appl. To/JPM No.: SRO 00.EP.001.305

Page 8 of 9

Student	Name:
---------	-------

Step	Action	Standard	Eval	Comments
16	Completes line 7	LINE 7.		
		Conclusion:		
		Places a checkmark in this is a drill box.		
* 17	Approves the Emergency Notification Report Form	Records the following on space provided:		
		Approved: - His/Her name		
		Time: - Current time		
		Date: - Current Date		
	EVALUATOR NOTE:			
	Candidate may review the filled out ENR form with			
18	Give the approved ENR form to the E Plan	Provides the filled out ENR form to the E Plan		
10	Communicator.	Communicator.		
	EVALUATOR CUE:			
	If necessary, Role-play the communicator and accept			
	the filled out form.			
	Inform the candidate the JPM is complete.			

Appl. To/JPM No.: <u>SRO 00.EP.001.305</u>

	Student Name:				
Step	Action	Standard	Eval	Comments	
*	EVALUATOR NOTE: The total time from the JPM start to step 5 of the JPM must be ≤ 15 minutes in order for the time critical portion of the JPM to be satisfactory.				

pi. 10/01 WHYO. <u>6110 00.21.001.00</u>

*Critical Step #Critical Sequence Form NTP-QA-31.8-2, Rev. 0, Page 1 of 1 2005 NRC Exam Rev. 1

i.

TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

PPL SUSQUEHANNA, LLC

. -----

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

SRO (00.EP.001.504	0 Bey No	9/27/05 Date		.41	N/A K/A No	4.0 K/A Imp
то		Hev. NO.	Dale	Sys. No).	IVA NO.	iva mp.
			asification (Co.	morio II C) E0(1) and	Complete the	
Task The:	Perform Emer	gency Plan Cla	ssilication (Sci		7-504) anu	Complete the	
Completed B	y:		Validated				
Rich Chin		9/27/05					
Writer		Date	Instructor	Writer		Date	
Approval:							
Nuclear Trng	. Supv.	Date					
		Time (Critical 15 Mir	nutes			
Date of Perfo	ormance:	Validate	ed Time (Min.)		Time Tak	en (Min.)	
JPM Perform	ed By:						
Student Nam	ie:						
	Last		First	M.I.	Employee	# / S.S. #	
Performance Evaluation:	e () Satisfact	ory	()	Unsatisfa	ctory	
Evaluator Na	ime:						
	Signature			Турес	d or Printed		
Comments:							

_-

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE SRO 00.EP.001.504

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. EP-PS-100, EMERGENCY DIRECTOR CONTROL ROOM, REV. 18
- B. ILO-504, SIMULATOR EVALUATION SCENARIO
- C. EP-PS-100-A
- D. EP-PS-100-D
- E. EP-PS-100-9

III. REACTIVITY MANIPULATIONS

This JPM satisfies the following Operational Activity(s): None

IV. TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

V. INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

VI. TASK STANDARD

Emergency classification of Site Area Emergency declared within 15 minutes.

Appl. To/JPM No.: <u>SRO 00.EP.001.504</u>

Stu	ident	Na	me
u			

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	 This JPM must be performed in the simulator following completion of the scenario ILO-504 as Unit Supervisor. 			
	• This is a time critical JPM.			
	 Ensure a copy of EP-PS-100 is available to support performance of this JPM. 			
	EVALUATOR NOTE:			
	To begin this JPM, provide the candidate with the			
	Initiating Cue Sheet.			
	EVALUATOR NOTE:			
	After the candidate reviews the Task Conditions /			
	Initiating Cue Sheet:			
	• Ask if the candidate is ready to begin the JPM.			
	 When the candidate is ready to begin the JPM inform the candidate that this is a Time Critical JPM. 			
	Record Start Time			

Page 4 of 9

Appl. To/JPM No.: SRO 00.EP.001.504

Student I	Name:
-----------	-------

Step	Action	Standard	Eval	Comments
1	Obtains a copy of EP-PS-100.	Controlled copy obtained.		
2	Identifies appropriate Tab	Determines Tab A is appropriate Tab to classify the event.		
3	Evaluates information.	Identifies from participation as The Unit Supervisor, RPV water level dropped below -161 inches		
	EVALUATOR CUE:			
	Assistance may be necessary for some specific scenario data or sequence of events. Use your judgment on acceptable levels of cueing based on candidate's request.			
* 4	Choose appropriate emergency classification level.	FS1		
		Loss or Potential loss of ANY 2 Fission Product Barriers		
5	Record Time of Site Area			
	Emergency declaration			
6	Determines appropriate procedure section for the classification.	Determines TAB D Manage the Site Area Emergency is the appropriate TAB.		

Appl. To/JPM No.: SRO 00.EP.001.504

Page 5 of 9

Student N	lame	9:
-----------	------	----

Step	Action	Standard	Eval	Comments
7 Document and communicate the Emergency A		Announces to Control Room Personnel:		
	Classification.	I am assuming duties of the Emergency Director.		
		Site Area Emergency Classification declared based on FS1		
		Loss or Potential loss of ANY 2 Fission Product Barriers		
		Time and Date of Classification.		
8	If not performed earlier appoint an Emergency Plan Communicator	Appoints an Emergency Plan Communicator and instruct him/her to immediately perform EP-PS-126 E Plan Communicator.		
9	If not performed earlier, appoint an NRC communicator.	Appoints an NRC Communicator and instruct him/her to perform EP-PS-135 NRC Communicator		
10	Generate and approve an ENR form to be transmitted by the Emergency Plan Communicator.	Refers to ENR Form under Tab 9.		
	EVALUATOR CUE: Inform the candidate that the Control # in the next step will be CR-ILO-504			

Page 6 of 9

Appl. To/JPM No.: SRO 00.EP.001.504

Juuchi Name.

Step	Action	Standard	Eval	Comments
11	Fill out and approve the Emergency Notification Report Form.	Fills out and approves the Emergency Notification Report Form as follows:		
		Control # CR-ILO-504		
		LINE 1.		
		Call Status:		
		Places checkmark in This is a drill box		
	EVALUATOR NOTE:			
	The communicator will fill out the communicator name, callback telephone number, and time notification is initiated. (Line 2 of the Emergency Notification Report Form).			
* 12	Completes line 3	LINE 3.		
	EVALUATOR NOTE:	Emergency Classification:		
	Initial Declaration is not critical	Places checkmark in Site Area Emergency box		
		Places checkmark in Unit one box		
		Records the Declaration time and date .		
		Places a checkmark in this represents A/AN initial declaration box in classification status.		

ĺ.

Appl. To/JPM No.: SRO 00.EP.001.504

Page 7 of 9

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	FS1 alone is sufficient for the Brief Non-Technical Description for the initial notification.			
	Candidate may paraphrase this description			
*13	Completes line 4	LINE 4.		
		The Emergency action level (EAL) number is:		
		Records EAL FS1		
		Brief non -technical description of the event:		
		Records FS1		
* 14	Completes line 5	LINE 5.		
		Places a checkmark in the		
		NO Non-routine radiological release box		
15	Completes line 6	LINE 6		
		Records Wind Direction is from: 10°		
		Wind Speed is: 5 mph		

Page 8 of 9

Appl. To/JPM No.: SRO 00.EP.001.504

1	Action	Standard	Eval	Comments
-	Completes line 7	LINE 7.		
		Conclusion:		
		Places a checkmark in this is a drill box.		
	Approves the Emergency Notification Report Form	Records the following on space provided:		
		Approved: - His/Her name		
		Time: - Current time		
		Date: - Current Date		
	EVALUATOR NOTE:			
	Candidate may review the filled out ENR form with the E Plan Communicator.			
	Give the approved ENB form to the E Plan	Provides the filled out ENR form to the E Plan		
	Communicator.	Communicator.		
	EVALUATOR CUE:			
	If necessary, Role-play the communicator and accept			

Student Name:_

Inform the candidate the JPM is complete.

the filled out form.

EVALUATOR CUE:

Step

16

*17

18

(

Page 9 of 9

Appl. To/JPM No.: SRO 00.EP.001.504

Student Name:

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE: The total time from the JPM start to step 5 of the JPM must be \leq 15 minutes in order for the time critical portion of the JPM to be satisfactory.			

(

TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

PPL SUSQUEHANNA, LLC

. _____

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

SRO	00.EP.001.505	0	9/27/05	2.4	.41	N/A	4.0
Appí.	JPM Number	Rev. No.	Date		à 1123	K/A No.	K/A Imp.
10				Sys. NC).		
Task Title:	Perform En	nergency Plan Cl	assification (S	Scenario ILC)-505) and	Complete the	ENR form
Completed	By:		Validate	ed:			
Rich Chin		9/27/05					
Writer		Date	Instruct	or/Writer		Date	
Approval:							
Nuclear Trr	ng. Supv.	Date					
		Time	Critical 15 M	linutes			
Date of Per	formance:	Valida	ted Time (Mi	n.)	Time Tak	en (Min.)	
JPM Performed By:							
	-						
Student Na	me:						
	Last		First	M.I.	Employee	e # / S.S. #	• • •
Performanc	ce () Satisfac	tory	()	Unsatisfa	ctory	
Evaluation:							
Evaluator N	lame:						
	Signature	9		Турес	l or Printec	ł	
Comments	:						

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE SRO 00.EP.001.505

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. EP-PS-100, EMERGENCY DIRECTOR CONTROL ROOM, REV. 18
- B. ILO-505, SIMULATOR EVALUATION SCENARIO
- C. EP-PS-100-A
- D. EP-PS-100-D
- E. EP-PS-100-9

III. REACTIVITY MANIPULATIONS

This JPM satisfies the following Operational Activity(s): None

IV. TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

V. INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

VI. TASK STANDARD

Emergency classification of Site Area Emergency declared within 15 minutes.

Appl. To/JPM No.: <u>SRO 00.EP.001.505</u>

Page 3 of 9

Student	Name:
---------	-------

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	 This JPM must be performed in the simulator following completion of the scenario ILO-505 as Unit Supervisor. 			
	This is a time critical JPM.			
	 Ensure a copy of EP-PS-100 is available to support performance of this JPM. 			
	EVALUATOR NOTE:			
	To begin this JPM, provide the candidate with the			
	Initiating Cue Sheet.			
	EVALUATOR NOTE:			
	After the candidate reviews the Task Conditions /			
	Initiating Cue Sheet:			
	Ask if the candidate is ready to begin the JPM.			
	 When the candidate is ready to begin the JPM inform the candidate that this is a Time Critical JPM. 			
	Record Start Time			

Page 4 of 9

Appl. To/JPM No.: <u>SRO 00.EP.001.505</u>

Student	Name:
---------	-------

Step	Action	Standard	Eval	Comments
1	Obtains a copy of EP-PS-100	Controlled copy obtained.		
2	Identifies appropriate Tab	Determines Tab A is appropriate Tab to classify the event.		
3	Evaluates information.	Identifies from participation as The Unit Supervisor, RPV water level dropped below -161 inches		
	EVALUATOR CUE:			
	Assistance may be necessary for some specific scenario data or sequence of events. Use your judgment on acceptable levels of cueing based on candidate's request.			
*4	Choose appropriate emergency classification level.	FS1		
11 4		Loss or Potential loss of ANY 2 Fission Product Barriers		
5	Becord Time of Site Area			
	Emergency declaration			
6	Determines appropriate procedure section for the classification.	Determines TAB D Manage the Site Area Emergency is the appropriate TAB.		

Appl. To/JPM No.: SRO 00.EP.001.505

Page 5 of 9

Student N	ame:_
-----------	-------

Step	Action	Standard	Eval	Comments
7	Document and communicate the Emergency	Announces to Control Room Personnel: I am assuming duties of the Emergency Director.		
	Classification.			
		Site Area Emergency Classification declared based on FS1		
		Loss or Potential loss of ANY 2 Fission Product Barriers		
		Time and Date of Classification.		
8	If not performed earlier appoint an Emergency Plan Communicator	Appoints an Emergency Plan Communicator and instruct him/her to immediately perform EP-PS-126 E Plan Communicator.		
9	If not performed earlier, appoint an NRC communicator.	Appoints an NRC Communicator and instruct him/her to perform EP-PS-135 NRC Communicator		
10	Generate and approve an ENR form to be transmitted by the Emergency Plan Communicator.	Refers to ENR Form under Tab 9.		
	EVALUATOR CUE: Inform the candidate that the Control # in the next step will be CR-ILO-505			

Page 6 of 9

Appl. To/JPM No.: SRO 00.EP.001.505

Stude	nt N	lame:_
-------	------	--------

Step	Action	Standard	Eval	Comments
11	Fill out and approve the Emergency Notification Report Form.	Fills out and approves the Emergency Notification Report Form as follows:		
		Control # CR-ILO-505		
		LINE 1.		
		Call Status:		
		Places checkmark in This is a drill box		
	EVALUATOR NOTE:			
	The communicator will fill out the communicator name, callback telephone number, and time notification is initiated. (Line 2 of the Emergency Notification Beport Form).			
* 12	Completes line 3	LINE 3.		
	EVALUATOR NOTE:	Emergency Classification:		
	Initial Declaration is not critical	Places checkmark in Site Area Emergency box		
		Places checkmark in Unit one box		
		Records the Declaration time and date.		
		Places a checkmark in this represents A/AN initial declaration box in classification status.		
ł

Appl. To/JPM No.: <u>SRO 00.EP.001.505</u>

Page 7 of 9

Student	Name:
---------	-------

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	FS1 alone is sufficient for the Brief Non-Technical Description for the initial notification.			
	Candidate may paraphrase this description			
*1 3	Completes line 4	LINE 4.		
		The Emergency action level (EAL) number is:		
		Records EAL FS1		
		Brief nontechnical description of the event:		
		Records FS1		
* 14	Completes line 5	LINE 5.		
		Places a checkmark in the		
		NO Non-routine radiological release box		
15	Completes line 6	LINE 6		
		Records Wind Direction is from: 10°		
		Wind Speed is: 5 mph		

Ĺ

Appl. To/JPM No.: SRO 00.EP.001.505

Page 8 of 9

C+.	1000		
SIL	Inen	пля	me
\mathbf{u}			

Step	Action	Standard	Eval	Comments
16	Completes line 7	LINE 7.		
		Conclusion:		
		Places a checkmark in this is a drill box.		
* 17	Approves the Emergency Notification Report Form	Records the following on space provided:		
		Approved: - His/Her name		
		Time: - Current time		
		Date: - Current Date		
	EVALUATOR NOTE:			
	Candidate may review the filled out ENR form with the E Plan Communicator.			
18	Give the approved ENR form to the E Plan	Provides the filled out ENR form to the E Plan		
	Communicator.	Communicator.		
	EVALUATOR CUE:			
	If necessary, Role-play the communicator and accept the filled out form.			
	EVALUATOR CUE:			
	Inform the candidate the JPM is complete.			

Appl. To/JPM No.: <u>SRO 00.EP.001.505</u>

Page 9 of 9

<u> </u>	
Student	Namo
Oludeni	name.

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE: The total time from the JPM start to step 5 of the JPM must be \leq 15 minutes in order for the time critical portion of the JPM to be satisfactory.			

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

PPL SUSQUEHANNA, LLC

JOB PERFORMANCE MEASURE

APPROVAL AND ADMINISTRATIVE DATA SHEET

SRO	00.EP.001.602	0	9/27/05	2.4	.41	N/A	4.0
Appl.	JPM Number	Rev. No.	Date	NUREC	G 1123	K/A No.	K/A Imp.
10				Sys. No).		
			· · · · · · · · · · · · · · · · · · ·			Complete the	
Task Title:	Perform Eme	ergency Plan Cla	assification (S	cenario ILC	-602) and	Complete the	ENR form
Completed	By:		Validate	d:			
Bich Chin		9/27/05					
Writer		Date	Instructo	or/Writer		Date	······································
Approval:							
Nuclear Tr	ng. Supv.	Date					
<u> </u>		Time	Critical 15 M	inutes			<u> </u>
Date of Pe	rformance:	Validat	ted Time (Min	.)	Time Tal	ken (Min.)	
JPM Perfo	rmed By:						
Student Na	ame:			<u> </u>			
	Last		First	M.I.	Employe	e # / S.S. #	
Performan	ce () Satisfac	tory	()	Unsatisfa	actory	
Evaluation							
Evaluator I	Name:				d or Brinto		
	Signature			турес		u	
Comments	:						

REQUIRED TASK INFORMATION JOB PERFORMANCE MEASURE SRO 00.EP.001.602

I. SAFETY CONSIDERATIONS

- A. All Operations personnel are responsible for maintaining their radiation exposure As Low As Reasonably Achievable in accordance with OP-AD-002, Standards for Shift Operations.
- B. All applicable safety precautions shall be taken in accordance with established PPL safety policies and the Safety Rule Book, for example:
 - 1. Whenever any electrical panel is opened for inspection during JPM performance.
 - 2. Whenever entering any plant area where specific safety equipment; such as hearing or eye protection, safety shoes, hardhats, etc; is required and/or posted as being necessary.
- C. If in the judgment of the evaluator any safety issue occurs during the performance of a JPM, the JPM will be terminated until the issue is resolved.
- D. Peer checking is the expectation for all evolutions; however, since a JPM is an individual effort, no peer check will be provided and Self Checking is required.

II. REFERENCES

- A. EP-PS-100, EMERGENCY DIRECTOR CONTROL ROOM, REV. 18
- B. ILO-602, SIMULATOR EVALUATION SCENARIO
- C. EP-PS-100-A
- D. EP-PS-100-D
- E. EP-PS-100-9

III. REACTIVITY MANIPULATIONS

This JPM satisfies the following Operational Activity(s): None

IV. TASK CONDITIONS

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

V. INITIATING CUE

Provide the highest emergency classification level for the events in the scenario just completed, and complete the Emergency Notification Form.

VI. TASK STANDARD

Emergency classification of Site Area Emergency declared within 15 minutes.

Appl. To/JPM No.: SRO 00.EP.001.602

Page 3 of 9

Student	Name:
---------	-------

Step	Action	Standard	Eval	Comments
	EVALUATOR NOTE:			
	 This JPM must be performed in the simulator following completion of the scenario ILO-602 as Unit Supervisor. 			
	This is a time critical JPM.			
	 Ensure a copy of EP-PS-100 is available to support performance of this JPM. 			
	EVALUATOR NOTE:			
	To begin this JPM, provide the candidate with the			
	Initiating Cue Sheet.			
	EVALUATOR NOTE:			
	After the candidate reviews the Task Conditions /			
	Initiating Cue Sheet:			
	 Ask if the candidate is ready to begin the JPM. 			
	 When the candidate is ready to begin the JPM inform the candidate that this is a Time Critical JPM. 			
	Record Start Time			

Appl. To/JPM No.: <u>SRO 00.EP.001.602</u>

Page 4 of 9

1

Step	Action	Standard	Eval	Comments
1	Obtains a copy of EP-PS-100.	Controlled copy obtained.		
2	Identifies appropriate Tab	Determines Tab A is appropriate Tab to classify the event.		
3	Evaluates information.	Identifies from participation as The Unit Supervisor, ATWS and RPV water level dropped below -161 inches		
	EVALUATOR CUE:			
	Assistance may be necessary for some specific scenario data or sequence of events. Use your judgment on acceptable levels of cueing based on candidate's request.			
¥-1	Choose appropriate emergency classification level	MS3		
Ψ 4	Choose appropriate energency classification level.	ATWS and ARI fail to reduce power to less than 5%		
		OR		
		FS1		
		Loss or Potential loss of ANY 2 Fission Product		
		Burnero		

Page 5 of 9

Appl. To/JPM No.: SRO 00.EP.001.602

Student	Nomo
oluueni	ivanie.

Step	Action	Standard	Eval	Comments
5	Record Time of Site Area			
	Emergency declaration			
6	Determines appropriate procedure section for the classification.	Determines TAB D Manage the Site Area		
		Emergency is the appropriate TAD.		
7	Document and communicate the Emergency	Announces to Control Room Personnel:		
	Classification.	I am assuming duties of the Emergency Director.		
		Site Area Emergency Classification declared based on		
		MS3		
		ATWS and ARI fail to reduce power to less than 5%		
		OR		
		FS1		
		Loss or Potential loss of ANY 2 Fission Product Barriers		
		Time and Date of Classification.		
8	If not performed earlier appoint an Emergency Plan Communicator	Appoints an Emergency Plan Communicator and instruct him/her to immediately perform EP-PS-126 E Plan Communicator.		
9	If not performed earlier, appoint an NRC communicator.	Appoints an NRC Communicator and instruct him/her to perform EP-PS-135 NRC Communicator		

Page 6 of 9

Appl. To/JPM No.: SRO 00.EP.001.602

Student Name:_

Step	Action	Standard	Eval	Comments
10	Generate and approve an ENR form to be transmitted by the Emergency Plan Communicator.	Refers to ENR Form under Tab 9.		
	EVALUATOR CUE:			
	Inform the candidate that the Control # in the next step will be CR-ILO-602			
11	Fill out and approve the Emergency Notification Report Form.	Fills out and approves the Emergency Notification Report Form as follows:		
		Control # CR-ILO-602		
		LINE 1.		
		Call Status:		
:		Places checkmark in This is a drill box		
	EVALUATOR NOTE:			
	The communicator will fill out the communicator name, callback telephone number, and time notification is initiated. (Line 2 of the Emergency Notification Report Form).			

Page 7 of 9

í.

Appl. To/JPM No.: <u>SRO 00.EP.001.602</u>

Stude	ent N	lame:_
-------	-------	--------

Step	Action	Standard	Eval	Comments
* 12	Completes line 3	LINE 3.		
	EVALUATOR NOTE:	Emergency Classification:		
	Initial Declaration is not critical	Places checkmark in Site Area Emergency box		
		Places checkmark in Unit one box		
		Records the Declaration time and date.		
		Places a checkmark in this represents A/AN initial declaration box in classification status.		
	EVALUATOR NOTE:			
	MS3 or FS1 alone is sufficient for the Brief Non- Technical Description for the initial notification.			
	Candidate may paraphrase this description			
* 13	Completes line 4	LINE 4.		
		The Emergency action level (EAL) number is:		
		Records EAL		
		MS 3 or FS1		
		Brief non -technical description of the event:		
		Records MS 3 or FS1		

Page 8 of 9

1

Appl. To/JPM No.: <u>SRO 00.EP.001.602</u>

Action	Standard	Eval	Comments
Completes line 5	LINE 5.		
	Places a checkmark in the		
	NO Non-routine radiological release box		
Completes line 6	LINE 6		
	Records Wind Direction is from: 10°		
	Wind Speed is: 5 mph		
Completes line 7	LINE 7.		
	Conclusion:		
	Places a checkmark in this is a drill box.		
Approves the Emergency Notification Report Form	Records the following on space provided:		
	Approved: - His/Her name		
	Time: - Current time		
	Date: - Current Date		
EVALUATOR NOTE:			
Candidate may review the filled out ENR form with			
the E Plan Communicator.			
	Action Completes line 5 Completes line 6 Completes line 7 Approves the Emergency Notification Report Form EVALUATOR NOTE: Candidate may review the filled out ENR form with the E Plan Communicator.	ActionStandardCompletes line 5LINE 5.Places a checkmark in the NO Non-routine radiological release boxCompletes line 6LINE 6 Records Wind Direction is from: 10° Wind Speed is: 5 mphCompletes line 7LINE 7. Conclusion: Places a checkmark in this is a drill box.Approves the Emergency Notification Report Form Completes Ime 7Records the following on space provided: Approved: - His/Her name Time: - Current time Date: - Current DateEVALUATOR NOTE: Candidate may review the filled out ENR form with the E Plan Communicator.EVALUATOR NOTE: Candidate may review the filled out ENR form with the E Plan Communicator.	ActionStandardEvalCompletes line 5LINE 5. Places a checkmark in the NO Non-routine radiological release boxLINE 6 Records Wind Direction is from: 10° Wind Speed is: 5 mphLINE 7. Conclusion: Places a checkmark in this is a drill box.Completes line 7LINE 7. Conclusion: Places a checkmark in this is a drill box.LINE 7. Conclusion: Places a checkmark in this is a drill box.Approves the Emergency Notification Report Form Candidate may review the filled out ENR form with the E Plan Communicator.Records the following on space provided: Approved: - His/Her name Time: - Current Time Date: - Current DateEvaluation is form: 10° Current Date

Page 9 of 9

Appl. To/JPM No.: SRO 00.EP.001.602

Student	Name:_
---------	--------

Step	Action	Standard	Eval	Comments
18	Give the approved ENR form to the E Plan Communicator.	Provides the filled out ENR form to the E Plan Communicator.		
	EVALUATOR CUE:			
	If necessary, Role-play the communicator and accept the filled out form.			
	EVALUATOR CUE:			
	Inform the candidate the JPM is complete.			
	EVALUATOR NOTE:			
	The total time from the JPM start to step 5 of the JPM must be \leq 15 minutes in order for the time critical portion of the JPM to be satisfactory.			
	EVALUATOR NOTE:			
· ·	If RPV water level drops below -205 inches the EAL will escalate to a General Emergency under MG3, and the ENR form will also reflect AN airborne NON routine radiological release based on loss of the Fuel clad barrier.			

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE

Consider the plant transient conditions and failures experienced in this scenario. Assume Wind Direction was from: 10° and Wind Speed was: 5 mph throughout the scenario.

INITIATING CUE