

PROPOSED REVISION 15
AP1000 DESIGN CONTROL DOCUMENT

Tier 1 Table 2.3.3-2

Standby Diesel and Auxiliary Boiler Fuel Oil System

Description of Change

Correct the value for the volume of the ancillary diesel generator fuel tank.

Editorial Justification

The correct value for the volume of this tank is given in Tier 2 Table 9.5.4-1.

Regulatory Consequence

This change is an editorial correction only. There is no effect on the FSER. However, this change does represent a change to Tier 1 material.

Change Markup

Tier 1 Table 2.3.3-2 Revise item 3.d) "Acceptance Criteria" of Tier 1 Table 2.3.3-2 as follows:

Table 2.3.3-2 Inspections, Tests, Analyses, and Acceptance Criteria		
Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
3.d) The ancillary diesel generator fuel tank is sized to supply power to long-term safety-related post accident monitoring loads and control room lighting through a regulating transformer and one PCS recirculation pump for four days.	Inspection of the ancillary diesel generator fuel tank will be performed.	The volume of the ancillary diesel generator fuel tank is greater than or equal to <u>650600</u> gallons.