

PROPOSED REVISION 15
AP1000 DESIGN CONTROL DOCUMENT

Tier 1 Table 2.5.2-8

Protection and Safety Monitoring System

Description of Change

Provide a precise reference for an ITAAC item.

Technical Justification

This change provides a direct reference to the relevant material.

Regulatory Consequence

There is no effect on the FSER. However, this correction does represent changes in Tier 1 material.

Change Markup

Tier 1 Table 2.5.2-8 Revise item 5.b) in Tier 1 Table 2.5.2-8 as follows:

Table 2.5.2-8 (cont.) Inspections, Tests, Analyses, and Acceptance Criteria		
Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
5.b) Separation is provided between PMS Class 1E divisions, and between Class 1E divisions and non-Class 1E cable.	See Tier 1 Material, Table 3.3-6, items 7.d and 7.e, Section 3.3, Nuclear Island Buildings.	See Tier 1 Material, Table 3.3-6, items 7.d and 7.e, Section 3.3, Nuclear Island Buildings.