

PROPOSED REVISION 15
AP1000 DESIGN CONTROL DOCUMENT

Tier 1 Table 2.5.5-2

In-Core Instrumentation System

Description of Change

Provide a precise reference for an ITAAC item.

Technical Justification

This change provides a direct reference to the relevant material.

Regulatory Consequence

There is no effect on the FSER. However, this correction does represent changes in Tier 1 material.

Change Markup

Tier 1 Table 2.5.5-2 Revise item 3.c) in Tier 1 Table 2.5.5-2 as follows:

Table 2.5.5-2 (cont.) Inspections, Tests, Analyses, and Acceptance Criteria		
Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
3.c) For cables other than those covered by 3.b, separation is provided between IIS Class 1E divisions, and between Class 1E divisions and non-Class 1E cable.	See Tier 1 Material, Table 3.3-6, item 7.d, Section 3.3, Nuclear Island Buildings, item 6.d.	See Tier 1 Material, Table 3.3-6, item 7.d, Section 3.3, Nuclear Island Buildings, item 6.d.