

**PROPOSED REVISION 15**  
**AP1000 DESIGN CONTROL DOCUMENT**

---

**Tier 1 Table 2.6.3-3**

**Class 1E dc and Uninterruptible Power Supply System**

**Description of Change**

Provide a precise reference for an ITAAC item.

**Technical Justification**

This change provides a direct reference to the relevant material.

**Regulatory Consequence**

There is no effect on the FSER. However, this correction does represent changes in Tier 1 material.

**Change Markup**

**Tier 1 Table 2.6.3-3** Revise item 3 in Tier 1 Table 2.6.3-3 as follows:

<b>Table 2.6.3-3</b> <b>Inspections, Tests, Analyses, and Acceptance Criteria</b>		
<b>Design Commitment</b>	<b>Inspections, Tests, Analyses</b>	<b>Acceptance Criteria</b>
3. Separation is provided between Class 1E divisions, and between Class 1E divisions and non-Class 1E cables.	See Tier 1 Material, <a href="#">Table 3.3-6, item 7.d</a> <del>Section 3.3, Nuclear Island Buildings.</del>	See Tier 1 Material, <a href="#">Table 3.3-6, item 7.d</a> <del>Section 3.3, Nuclear Island Buildings.</del>