David Loveless - S/U transformer soak times

Page 1

18-RE

From:

Don Marksberry

To:

David Loveless 6/28/04 9:57AM

Date: Subject:

S/U transformer soak times

Per Bill, a transformer that has been powered down on the high side (such as a startup transformer) for an hour or two (due to a LOOP) does not need soaking.

Soaking is important for cold transformers, which includes moisture and oil testing in addition to no load soak time.

M