

24-RES

**From:** Don Marksberry  
**To:** David Loveless  
**Date:** Thu, Jul 1, 2004 8:48 AM  
**Subject:** EOPs

David,

Do the EOPs instruct the operators to ensure or request that GTG are started and loaded given an LOOP? I want to make sure that recovery of power is a single action and not two independent actions (i.e., GTG/swtichyard operators and control room operators). If it's in the EOPs, then a single XHE is sufficient.

Do you have the EOPs handy that you could e-mail or send a copy to me?

4/23 K