



Part 50 License Amendment Request (LAR) for Dry Storage Loadings at Oconee

Presentation to the United States Nuclear Regulatory Commission (NRC) Rockville, MD November 1, 2005



Purpose

• **Provide Information to the NRC Concerning:**

- Duke's suspension of dry storage loadings at Oconee in response to Regulatory Issue Summary (RIS) 2005-05
- Duke's LAR to address the RIS 2005-05 issues for Oconee
- Schedule for the LAR submittal to the NRC and requested approval date

• Obtain NRC Feedback

- Can the NRC Staff support Duke's LAR schedule?
- What can Duke do to expedite the review process?



Duke Representatives

Oconee Nuclear Site

Steve Newman -**Regulatory Compliance**

• Nuclear General Office

Steve Nesbit -

- Mgr. Spent Fuel Management
- Gary Walden -SFM (lead for ONS ISFSI)
- Joe Coletta -
- SFM (criticality analyst)
- William Murphy SFM (criticality analyst)

Overview

- Need for LAR
- Scope
- Technical Approach
- Schedule
- Discussion
- Closing Remarks

(Nesbit)
(Nesbit)
(Coletta)
(Walden)
(ALL)
(Newman)



Need for LAR

• Dry Fuel Storage Systems at Oconee

License	Storage System	Soluble Boron Required During Loading?	Number of Canisters	Time Period
Site-Specific	NUHOMS®-24P	yes	40 (loaded)	1990-1996
General	NUHOMS®-24P	yes	44 (loaded)	1999-2005
General	NUHOMS®-24PHB	yes	28 (to be loaded)	2005-2009



Need for LAR

• RIS 2005-05

- Issued on March 23, 2005
- Noted potential inconsistencies between regulatory bases of fuel pools and dry storage
 - Potential for unanalyzed condition during dry cask loading in the spent fuel pool
- Stated that affected licensees must meet both Part 50 and Part 72 requirements for cask loading/unloading in the pool
 - Part 50: credit for burnup is allowed; must show subcriticality in unborated water
 - Part 72: credit for dissolved boron is allowed for demonstrating subcriticality
- Suggests Part 50 license amendment for burnup credit



Need for LAR

• Actions on RIS 2005-05

- Suspended Oconee dry storage loadings planned for June 2005 (suspension in effect until issue resolved)
- Entered the issue into Oconee's corrective active program
- Began development of a request for exemption from 10CFR50.68(b)(1)
- Changed to LAR approach based on subsequent NRC interactions with other licensees
- Duke is working through the Nuclear Energy Institute toward a generic resolution of the issue



Scope

• New Dry Storage Canister Criticality Analysis

- New Part 50 LAR
- Analysis will address current and previously loaded NUHOMS[®] canisters
- Conform to current NRC expectations for soluble boron credit under Part 50
- No change to NUHOMS® Part 72 licenses or analyses

• No Change to SFP Storage Rack Analyses

- Maintain current Oconee SFP licensing basis
 - > Approved by NRC in 2002
 - Based on WCAP 14416



Scope

New Part 50 Technical Specification

- Establish minimum burnup requirements for fuel to be loaded into dry storage canisters (burnup vs. enrichment curve)
- Supporting analyses are being developed by Duke
- LAR will be crafted with goal of flexibility to evaluate future dry storage casks via the 50.59 process



 NUHOMS®-24P Systems Have Common Basket Design



Source: NUHOMS® FSAR, Rev. 8, June 2004



• Roadmap to Fuel Burnup Requirements





• Codes Used for Analysis

- CASMO-3
 - ➢ Base 2-D model calculations
 - Burnup credit computations
 - Reactor depletion
 - 2-D dry storage canister "rack" calculations with burned fuel
- SIMULATE-3
 - ➢ 3-D axial burnup bias determination
 - >Axial bias applied to 95/95 k-eff calculations where positive
- SCALE 4.4 / KENO V.a
 - > 3-D full detail canister model with fresh fuel
 - ➢ Used to demonstrate conservatism of CASMO-3



Geometric Models



3 different fuel assembly spacings (KENO V.a)



CASMO-3 Computational Canister Model

- 2-D infinite lattice
- Single representative fuel assembly spacing
 - Conservatism will be demonstrated
- No axial leakage
- Full density moderator in dry storage canister
 Water temperature between 32°F and 212°F
 No moderator in pellet-clad gap
- Fuel designs: Mark B2-B8; B9; B10; B10L
- Conservative depletion parameters
- Credit for 5 years post-irradiation cooling time



Preliminary Results

- Curve specifies minimum burnup based on maximum initial enrichment
- Single "region" within dry storage canister
- Applies to all analyzed fuel types
- Applicable to NUHOMS®-24P and NUHOMS®-24PHB





Conservatisms in Analysis

- Infinite lattice (radial and axial) canister model
- In-reactor depletion parameters
 - Boron concentration
 - Moderator temperature
 - ➢ Discrete BP presence
 - >Fuel temperature
- Mechanical and burnup-related uncertainties
- Axial burnup profiles for 3-D bias
- Most reactive fuel assembly design



Schedule

• Prudent Operating Reserve (POR) for Oconee

- Empty storage cells for core offload during refuel (177)
- Storage cells empty of irradiated fuel (168)
 - Diver access to repair upender, if needed
 - \geq New fuel assemblies stored in these cells

• Unit 1/2 Spent Fuel Pool (SFP)

- Unit 2 Refuel, Fall 2005: POR not available
- Unit 1 Refuel, Fall 2006

Need to load 4 canisters to restore POR

Need to load 2 canisters to store all new fuel in pool

• Unit 3 SFP

- Unit 3 Refuel, Spring 2006: POR not available
- Unit 3 Refuel, Fall 2007

 \geq Need to load 3 canisters to restore POR



Schedule

LAR Schedule

Submittal to NRCNRC approval

3/1/06 6/1/06

November 1, 2005