Robert A. Saccone Vice President - Nuclear Operations

PPL Susquehanna, LLC 769 Salem /Boulevard Berwick, PA 18603 Tel. 570.542.3959 Fax 570.542.1504 RASaccone@pplweb.com



November 8, 2005

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Mail Stop O-P1-17 Washington, D.C. 20555-0001

SUSQUEHANNA STEAM ELECTRIC STATION MONTHLY OPERATING REPORTS Docket Nos. 50-387/NPF-14 and 50-388/NPF-22 PLA-005985

The October 2005 Monthly Operating Reports for Susquehanna SES Units 1 and 2 are attached.

Very truly yours,

Robert Ar Saccon

JJH/cmm

cc: NRC Region 1

NRC Sr. Resident Inspector, Mr. Brice Bickett NRC Project Manager, Mr. R V. Guzman

JEZY

OPERATING DATA REPORT



50-387
One
11/10/2005
J. J. Hennings
(570) 542-3747

OPERATING STATUS

ı.	Unit Name: Susquehanna Steam Electr	ic Station (U1)		
2.	Reporting Period: October 2005			
3.	Design Electrical Rating (Net MWe): 1177			
4.	Maximum Dependable Capacity (Net MWe):	1135		
		This Month	Yrto-Date	Cumulative
5.	Hours in Reporting Period	745	7,296.0	196,369.0
6.	Number of Hours Reactor Was Critical	679.7	7,230.7	165,218.7
7.	Hours Generator On-Line	672.1	7,223.1	162,823.1
8.	Unit Reserve Shutdown Hours	0	0	0
9.	Net Electrical Energy Generated (MWH)	749,966	8,165.309	168,805,751

NOTES:

UNIT SHUTDOWNS



DOCKET NO.
UNIT
DATE
COMPLETED BY
TELEPHONE

50-387 One 11/10/2005 J. J. Hennings (570) 542-3747

REPORT MONTH October 2005

No.	Date	Туре	Duration (Hours)	Reason 2	Method of Shutting Down Reactor ³	Cause & Corrective Action To Prevent Recurrence
	10/29/05	S	72:55 (continuing)	В	1	On 10/29/05 a planned Reactor shutdown started a Maintenance Outage established for measurement of fuel channels and replacement of those not meeting pre-established criteria. The Maintenance Outage schedule specifies activities that replace the channels of some incore fuel bundles as well as replacing some bundles with those from previous fuel cycles. This activity will correct the issue of excess control cell friction experienced during control rod testing earlier this year. The Maintenance Outage is planned to be complete in mid November.

Summary: Unit 1 Reactor achieved 100% power on 10/03/05 following a planned power reduction for control rod friction testing that began on 9/30/05. Three(3) planned power reductions greater than 20% were performed in October for Control Rod adjustments and testing. (10/04 to 80% power, 10/08 to 79% power and 10/14 to 75% power). A planned maintenance outage was also initiated on 10/29/05 to correct issues with increased Control Cell friction that caused some extended Control Rod travel times. The Maintenance Outage is scheduled to end in mid November.

2. 1. F. Forced Reason: Method: 1 - Manual S. Scheduled A - Equipment Failure (Explain) B - Maintenance or Test 2 - Manual Scram 3 – Automatic Scram C - Refueling D - Regulatory Restriction 4 – Continuation from previous month E – Operator Training & Licensee Exam 5 - OtherF - Administrative

G - Operational Error (Explain)

Page 1 of 1

SUSQUEHANNA STEAM ELECTRIC STATION

 Docket Number:
 50-387
 Date:
 11/10/05

 Completed by:
 J. J. Hennings
 Telephone:
 (570) 542-3747

Challenges to Main Steam Safety Relief Valves

None.

OPERATING DATA REPORT



 DOCKET NO.
 50-388

 UNIT
 Two

 DATE
 11/10/05

 COMPLETED BY
 J. J. Hennings

 TELEPHONE
 (570) 542-3747

OPERATING STATUS

NOTES:

5.	Unit Name: Susquehanna Steam Electric Stat	tion (U2)					
6.	Reporting Period: October 2005						
7.	Design Electrical Rating (Net MWe): 1182						
8.							
		This Month	Yrto-Date	Cumulative			
5.	Hours in Reporting Period	745	7,296	181,609			
6.	Number of Hours Reactor Was Critical	745	6,527.9	159,207.7			
7.	Hours Generator On-Line	745	6,436.8	157,129.5			
8.	Unit Reserve Shutdown Hours	0	0	0			
9.	Net Electrical Energy Generated (MWH)	858,493	7,185,396	166,000,536			

UNIT SHUTDOWNS



DOCKET NO. UNIT DATE **COMPLETED BY TELEPHONE**

50-388 Two 11/10/05 J. J. Hennings (570) 542-3747

REPORT MONTH October 2005

No.	Date	Туре	Duration (Hours)	Reason 2	Method of Shutting Down Reactor	Cause & Corrective Action to Prevent Recurrence
						No reactor shutdowns this month.

Summary: No power changes greater than 20% this month.						

1.

F. Forced S. Scheduled 2.

3.

Reason:

A - Equipment Failure (Explain)

B – Maintenance or Test

C - Refueling

D - Regulatory Restriction

E - Operator Training & Licensee Exam

F – Administrative

G - Operational Error (Explain)

Method:

1 - Manual

2 - Manual Scram

3 - Automatic Scram

4 - Continuation from previous month

5 - Other

SUSQUEHANNA STEAM ELECTRIC STATION

 Docket Number:
 50-388
 Date:
 11/10//05

 Completed by:
 J. J. Hennings
 Telephone:
 (570) 542-3747

Challenges to Main Steam Safety Relief Valves

None.