

November 21, 2005

10 CFR 54

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Stop: OWFN P1-35  
Washington, D.C. 20555-0001

Gentlemen:

In the Matter of	)	Docket Nos. 50-259
Tennessee Valley Authority	)	50-260
		50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - UNITS 1, 2, AND 3 -  
LICENSE RENEWAL APPLICATION (LRA) - RESPONSE TO NRC REQUEST  
FOR CLARIFICATION FOR BFN'S USE OF LINDE 80 WELD MATERIAL ON  
UNIT 1 (TAC NOS. MC1704, MC1705, AND MC1706)

By letter dated December 31, 2003, TVA submitted, for NRC review, an application pursuant to 10 CFR 54, to renew the operating licenses for the Browns Ferry Nuclear Plant, Units 1, 2, and 3. As part of its review of TVA's LRA, the NRC staff, through an informal request on October 12, 2005, identified additional information needed concerning the use of Linde 80 weld material on Unit 1.

The enclosure to this letter contains the specific NRC request for additional information and the corresponding TVA response.

U.S. Nuclear Regulatory Commission  
Page 2  
November 21, 2005

If you have any questions regarding this information, please contact Ken Brune, Browns Ferry License Renewal Project Manager, at (423) 751-8421.

I declare under penalty of perjury that the foregoing is true and correct. Executed on this 21<sup>st</sup> day of November, 2005.

Sincerely,

Original signed by:

William D. Crouch  
Manager of Licensing  
and Industry Affairs

Enclosure:

cc: See page 3

U.S. Nuclear Regulatory Commission  
Page 3  
November 21, 2005

Enclosure

cc (Enclosure):

State Health Officer  
Alabama Department of Public Health  
RSA Tower - Administration  
Suite 1552  
P.O. Box 303017  
Montgomery, Alabama 36130-3017

Chairman  
Limestone County Commission  
310 West Washington Street  
Athens, Alabama 35611

(Via NRC Electronic Distribution)

Enclosure

cc (Enclosure):

U.S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, Georgia 30303-8931

Mr. Stephen J. Cahill, Branch Chief  
U.S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, Georgia 30303-8931

NRC Senior Resident Inspector  
Browns Ferry Nuclear Plant  
10833 Shaw Road  
Athens, Alabama 35611-6970

NRC Unit 1 Restart Senior Resident Inspector  
Browns Ferry Nuclear Plant  
10833 Shaw Road  
Athens, Alabama 35611-6970

cc: continued page 4

U.S. Nuclear Regulatory Commission  
Page 4  
November 21, 2005

cc: (Enclosure)

Margaret Chernoff, Project Manager  
U.S. Nuclear Regulatory Commission  
(MS 08G9)  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

Eva A. Brown, Project Manager  
U.S. Nuclear Regulatory Commission  
(MS 08G9)  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

Yaira K. Diaz-Sanabria, Project Manager  
U.S. Nuclear Regulatory Commission  
(MS 011F1)  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

Ramachandran Subbaratnam, Project Manager  
U.S. Nuclear Regulatory Commission  
(MS 011F1)  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

U.S. Nuclear Regulatory Commission  
Page 5  
November 21, 2005

JEM:TLE:BAB

Enclosure

cc (Enclosure):

- B. M. Aukland, POB 2C-BFN
- A. S. Bhatnagar, LP 6-C
- K. A. Brune, LP 4F-C
- J. C. Fornicola, LP 6A-C
- R. G. Jones, NAB 1A-BFN
- R. F. Marks, Jr., PAB 1A-BFN
- N. M. Moon, LP 6A-C
- G. W. Morris, LP 4G-C
- B. J. O'Grady, PAB 1E-BFN
- J. R. Rupert, NAB 1F-BFN
- K. W. Singer, LP 6A-C
- E. J. Vigluicci, ET 11A-K
- NSRB Support, LP 5M-C
- EDMS, WT CA-K

s://Licensing/Lic/Submit/Subs/BFN LR Clarification for Linde 80 weld material.doc

ENCLOSURE

TENNESSEE VALLEY AUTHORITY  
BROWNS FERRY NUCLEAR PLANT (BFN)  
UNITS 1, 2, AND 3  
LICENSE RENEWAL APPLICATION (LRA)

RESPONSE TO NRC REQUEST FOR CLARIFICATION FOR  
BROWNS FERRY USE OF LINDE 80 WELD MATERIAL ON UNIT 1

---

(SEE ATTACHED)

TENNESSEE VALLEY AUTHORITY  
BROWNS FERRY NUCLEAR PLANT (BFN)  
UNITS 1, 2, AND 3  
LICENSE RENEWAL APPLICATION (LRA)

RESPONSE TO NRC REQUEST FOR CLARIFICATION FOR  
BFN'S USE OF LINDE 80 WELD MATERIAL ON UNIT 1

---

By letter dated December 31, 2003, TVA submitted, for NRC review, an application pursuant to 10 CFR 54, to renew the operating licenses for the Browns Ferry Nuclear Plant, Units 1, 2, and 3. As part of its review of TVA's LRA, the NRC staff, through an informal request on October 12, 2005, identified additional information needed concerning the use of Linde 80 weld material on Unit 1.

The enclosure to this letter contains the specific NRC request for additional information and the corresponding TVA response.

NRC Request

The limiting beltline circumferential weld - heat # 406L44 for BFN Unit 1 is made of Linde 80 material. According to Section B.3.4 of the BWRVIP-74, "BWR Reactor Pressure Vessel Inspection and Flaw Evaluation," report, fracture toughness of the weld shall be established by using J-R curve based on the values of copper and fluence. In the LRA, the applicant provided EMA for this weld by using figure 2 of the RegGuide 1.99 which is not appropriate for Linde 80 weld. Therefore, the staff requests that the applicant revise the Table 4.2.1.1 of the LRA to indicate that the EMA analysis for the circumferential Linde 80 weld in BFN Unit 1 complies with the requirements specified in Section B.3.4 of the BWRVIP-74 report, and submit any calculations to substantiate its claim of compliance with this method.

TVA Response To NRC Request

Since no upper shelf energy value was available, the J-R curve for heat # 406L44 was calculated using copper content and fluence in accordance with the methodology originally applied in the Equivalent Margin Analysis (Reference 1). The copper content and fluence for the BFN Unit 1 Linde 80 weld are 0.27% and  $1.33E18$  n/cm<sup>2</sup> (¼ thickness), respectively.

The mean J-R curve for Linde 80 weld material can be represented by the following equation, which is equation 4-2 of Reference 1:

$$J_d = C1(\Delta a)^{C2} \left\{ \exp[C3(\Delta a)^{C4}] \right\} \text{ (in-lb/in}^2\text{)} \quad \text{(See Note 1.)}$$

where

$J_d$  = the deformation J-Integral

$$\ln C1 = a1 + a2 * Cu(\phi t)^{a5} + a3 * T$$

$$C2 = d1 + d2(\ln C1)$$

$$C3 = d4 + d5(\ln C1)$$

$$C4 = -0.0491 \text{ (per Table 4-2 of Reference 1)}$$

$$Cu = \text{copper content in percent} = 0.27$$

$\Delta a$  = crack growth, inches

**Note 1:** The results of the calculation are multiplied by 1,000 to obtain the correct units. See example calculation.

The values for the constants a1, a2, a3, a5, d1, d2, d4, and d5 were obtained from Table 4-2 of Reference 1 as follows:

a1 = 2.413	d1 = 0.077
a2 = - 0.506	d2 = 0.116
a3 = - 0.0025	d4 = - 0.0812
a5 = 0.634	d5 = - 0.0092
T = 550°F	$\phi t$ = fluence at ¼ thickness, n/cm <sup>2</sup> x10 <sup>18</sup> (1.33 for BFN)

Example Calculation (crack growth = 0.10 inches)

$$\ln C1 = 2.413 - 0.506 * 0.27 * 1.33^{0.634} - 0.0025 * 550$$

$$\ln C1 = \underline{0.874}$$



$$C1 = \underline{2.397}$$

$$C2 = 0.077 + 0.116*0.874$$

$$C2 = \underline{0.178}$$

$$C3 = - 0.0812 - 0.0092*0.874$$

$$C3 = \underline{- 0.0892}$$

$$J_d = 2.397*(0.10)^{0.178} * \{\exp(-0.0892*0.10^{-0.491})\} * 1,000$$

$$J_d = 1205 \text{ in-lb/in}^2$$

This J-R value, however, is the mean value. For purposes of this evaluation, the mean minus two sigma J-R curve was used, consistent with the methodology presented in Section 4.5 of Reference 1. The mean minus two sigma curve is obtained by multiplying the mean curve by a factor of 0.626 (see Table 4-2 of Reference 1). Therefore, the J-R value for a crack growth of 0.10 inches is:

$$J_d = 1205 * 0.626 = 754.76 \text{ in-lb/in}^2$$

The remaining values of  $J_d$  were calculated in a similar manner, varying the crack growth value,  $\Delta a$ . The results of the calculations are presented in Figure 1.

To determine if the material maintains adequate fracture toughness, the  $J_{\text{applied}}$  values are also plotted in Figure 1; the  $J_{\text{applied}}$  values were obtained from Figure 5-5 of Reference 1. As can be seen in the figure, the  $J_{\text{applied}}$  values are shown to be well within the J-R curve limits. Therefore, BFN Heat 406L44 will maintain adequate fracture toughness throughout the period of extended operation.


The revised version of Table 4.2.1.2 is enclosed as Attachment 1 to this Enclosure.

#### REFERENCE

1. H.S. Mehta, T.A. Caine, and S.E. Plaxton, "10CFR50 Appendix G Equivalent Margin Analysis for Low Upper Shelf Energy in BWR/2 Through BWR/6 Vessels," NEDO-32205-A, Revision 1, February 1994.

Figure 1

Lined 80 Weld J-R Curve



**ATTACHMENT 1**

Table 4.2.1.2: Equivalent Margin Analysis for BFN Unit 1 Weld Material

BWR/2-6 WELD
<p><u>Surveillance Weld USE:</u></p> <p style="text-align: center;">%Cu = N/A 1<sup>st</sup> Capsule Fluence = N/A 2<sup>nd</sup> Capsule Fluence = N/A</p> <p style="text-align: center;">1<sup>st</sup> Capsule Measured % Decrease = N/A      (Charpy Curves) 2<sup>nd</sup> Capsule Measured % Decrease = N/A      (Charpy Curves)</p> <p style="text-align: center;">1<sup>st</sup> Capsule R.G. 1.99 Predicted % Decrease = N/A      (R.G. 1.99, Figure 2) 2<sup>nd</sup> Capsule R.G. 1.99 Predicted % Decrease = N/A      (R.G. 1.99, Figure 2)</p>
<p><u>Limiting Beltline Weld USE:</u></p> <p style="text-align: center;">%Cu = 0.27 54 EFPY 1/4T Fluence = 1.33E+18 n/cm<sup>2</sup> R.G. 1.99 Predicted % Decrease = N/A (Linde 80 Weld Material) (R.G. 1.99, Figure 2) Adjusted % Decrease = N/A (R.G. 1.99, Position 2.2)</p>
<p>For the specific copper and fluence for the BFN Unit 1 Linde 80 weld material, the vessel welds meet the requirements of the BWRVIP-74-A equivalent margin analysis.</p>