

72-1014

From: "Evan Rosenbaum" <Evan_Rosenbaum@holtec.com>
To: <cmr1@nrc.gov>
Date: 11/10/05 5:42PM
Subject: Holtec Feedback from 2 November 2005 Telecon

Chris,

We appreciate the telecon between the SFPO Staff and Holtec that occurred on 2 November 2005, where the SFPO Staff reminded us of their 23 March 2005 letter and the methodology discussed therein for calculating hydraulic resistance parameters for porous media used to model fuel assemblies in dry storage casks. We have revisited the methodology discussed in that letter, independently confirming the derivation of the equations therein, finding the methodology conservative and appropriate for use in dry storage cask thermal analysis.

We have performed porous media hydraulic resistance calculations, using the March 23rd letter methodology, for the GE-12/14 10x10 BWR and Westinghouse 17x17 OFA PWR fuel assemblies that are the design-basis thermal assemblies in our HI-STORM CoC Amendment Request #3. We find that the porous media hydraulic resistance parameters calculated using the March 23rd letter methodology are lower than the corresponding values that we have used in our amendment request. These results confirm that the values used in our amendment request are appropriately conservative.

We have attached our calculation sheets to this e-mail, and trust that the Staff's reviewers will find them to be correct. We believe that Holtec and the SFPO have reached a point of agreement on this technical issue, and look forward to the successful completion of the thermal review of our amendment request. Please contact me if the Staff has any questions.

Evan

Evan Rosenbaum, P.E.
Principal Engineer
Manager, Thermal-Hydraulics
Holtec International voice: (856) 797-0900 x-627
555 Lincoln Drive West fax: (856) 797-0909
Marlton, NJ 08053 e-mail: Evan_Rosenbaum@holtec.com

www.holtecinternational.com

The information contained herein is intended only for the person or entity to which it is addressed and may contain confidential and/or privileged material. Review, retransmission, dissemination, or other use of this information in whole or part for any other purpose by persons outside the recipient's organization is permitted only after an explicit authorization to such effect has been issued by the sender of this message. If you received this e-mail in error, please contact the sender and delete this e-mail and its attachments immediately.

Mail Envelope Properties (4373CCB2.847 : 7 : 30791)

Subject: Holtec Feedback from 2 November 2005 Telecon
Creation Date: Thu, Nov 10, 2005 5:38 PM
From: "Evan Rosenbaum" <Evan_Rosenbaum@holtec.com>

Created By: Evan_Rosenbaum@holtec.com

Recipients

nrc.gov
owf4_po.OWFN_DO
CMR1 (Christopher Regan)

Post Office

owf4_po.OWFN_DO

Route

nrc.gov

Files

	Size
MESSAGE	2453
D_BWR-mcad2000.mcd	31438
D_PWR-mcad2000.mcd	30225
Postprocessing_Steps.doc	22528
Mime.822	119889

Date & Time

Thursday, November 10, 2005 5:38 PM

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard