

November 23, 2005

Mr. George Vanderheyden
Vice President
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657

SUBJECT: ERRATA FOR THE U.S. NUCLEAR REGULATORY COMMISSION (NRC)
SAFETY EVALUATION REPORT (SER) RELATED TO AMENDMENT 7 TO
MATERIALS LICENSE NO. SNM-2505 FOR THE CALVERT CLIFFS
INDEPENDENT SPENT FUEL STORAGE INSTALLATION

Dear Mr. Vanderheyden:

On November 2, 2005, the NRC issued license Amendment No. 7 to Materials License SNM-2505, pursuant to Part 72 to Title 10 of the Code of Federal Regulations. This amendment permits the use of the NUHOMS-32P cask as an optional design to the existing NUHOMS-24P design for dry storage of spent nuclear fuel. The staff has determined that the safety evaluation report (SER) that supports this amendment needs to be revised. Specifically, on the third page of the SER there is an evaluation of a change in the thermal analysis. Please replace the fifth paragraph on the third page of the SER with the paragraph below.

The accident analysis that leads to the 99.4 psig DSC internal pressure load is a conservative bounding analysis that assumes the air vents for the Horizontal Storage Module (HSM) in which the DSC is placed are blocked for 48 hours. Therefore, because the 99.4 psig DSC internal pressure value is bounded by the 100 psig value used in the structural analysis and because the thermal analysis uses conservative assumptions, the staff finds the change in DSC internal pressure due to the new thermal analysis to be acceptable.

If you have any questions about this document, please contact Joseph Sebrosky, Senior Project Manager, at (301) 415-8500.

Sincerely,

/RA/

Robert A. Nelson, Chief
Licensing Section
Spent Fuel Project Office
Office of Nuclear Material Safety
and Safeguards

Docket No. 72-8

cc: Service List

Mr. George Vanderheyden
 Vice President
 Calvert Cliffs Nuclear Power Plant
 1650 Calvert Cliffs Parkway
 Lusby, MD 20657

**SUBJECT: ERRATA FOR THE U.S. NUCLEAR REGULATORY COMMISSION (NRC)
 SAFETY EVALUATION REPORT (SER) RELATED TO AMENDMENT 7 TO
 MATERIALS LICENSE NO. SNM-2505 FOR THE CALVERT CLIFFS
 INDEPENDENT SPENT FUEL STORAGE INSTALLATION**

Dear Mr. Vanderheyden:

On November 2, 2005, the NRC issued license Amendment No. 7 to Materials License SNM-2505, pursuant to Part 72 to Title 10 of the Code of Federal Regulations. This amendment permits the use of the NUHOMS-32P cask as an optional design to the existing NUHOMS-24P design for dry storage of spent nuclear fuel. The staff has determined that the safety evaluation report (SER) that supports this amendment needs to be revised. Specifically, on the third page of the SER there is an evaluation of a change in the thermal analysis. Please replace the fifth paragraph on the third page of the SER with the paragraph below.

The accident analysis that leads to the 99.4 psig DSC internal pressure load is a conservative bounding analysis that assumes the air vents for the Horizontal Storage Module (HSM) in which the DSC is placed are blocked for 48 hours. Therefore, because the 99.4 psig DSC internal pressure value is bounded by the 100 psig value used in the structural analysis and because the thermal analysis uses conservative assumptions, the staff finds the change in DSC internal pressure due to the new thermal analysis to be acceptable.

If you have any questions about this document, please contact Joseph Sebrosky, Senior Project Manager, at (301) 415-8500.

Sincerely,

/RA/

Robert A. Nelson, Chief
 Licensing Section
 Spent Fuel Project Office
 Office of Nuclear Material Safety
 and Safeguards

Docket No. 72-8

cc: Service List Distribution:
 MMiller, R-I PMilano, NRR
Package ML

SBaggett

NJensen, OGC

SFPO Reading File

*** see previous concurrence**

OFC:	SFPO	SFPO	E	SFPO:CSHT	SFPO:S&M	SFPO	SFPO
NAME:	JSebrosky	EZiegler*		ADias*	GBjorkman	S.Treby (nlo)	RNelson
DATE:	11/14/05	11/14/05		11/04/05	11/15/05	11/15/05	11/23/05

OFFICIAL RECORD COPY

Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2

cc:

President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, MD 20678

Mr. Loren F. Donatell
NRC Technical Training Center
5700 Brainerd Road
Chattanooga, TN 37411-4017

Mr. Carey W. Fleming
Sr. Counsel - Nuclear Generation
Constellation Generation Group, LLC
750 E. Pratt Street, 17th Floor
Baltimore, MD 21202

Mark Geckle
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

Resident Inspector
U.S. Nuclear Regulatory
Commission
P.O. Box 287
St. Leonard, MD 20685

Mr. Richard I. McLean, Manager
Nuclear Programs
Power Plant Research Program
Maryland Dept. of Natural Resources
Tawes State Office Building, B3
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Kristen A. Burger, Esquire
Maryland People's Counsel
6 St. Paul Centre
Suite 2102
Baltimore, MD 21202-1631

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P.O. Box 33111
Baltimore, MD 21218