

November 21, 2005

Document Control Desk
US Nuclear Regulatory Commission
Washington, DC 20555

50-27


As a follow up to the letter dated July 10th, 2005, I am pleased to inform the Commission that the Washington State University Nuclear Radiation Center (WSUNRC) has returned to compliance with our surveillance requirements as of November 21st, 2005.

Section 4.3.1 part (5) (page 26) of our Technical Specifications denotes "The reactor shall be pulsed semiannually to compare fuel temperature measurements and peak power levels with those of previous pulses of the same reactivity."

As noted on a recent inspection, this is currently an unresolved item (URI 50-27/2005-201-01). With the successful performance of a \$2.00 pulse on 11/21, the WSUNRC considers the matter closed.

If there are any questions, please feel free to contact the WSUNRC.

Sincerely,



Dr. Ken Spitzer, Interim Director

A020