

December 8, 2005

Mr. Karl W. Singer
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNIT 2 — WITHDRAWAL OF ONE-TIME
EXTENSION TO LOW PRESSURE EMERGENCY CORE COOLING SYSTEM
COMPLETION TIME (TAC NO. MC8928)

Dear Mr. Singer:

By letter dated November 21, 2005, the Tennessee Valley Authority (TVA) submitted a request for an emergency technical specification (TS) change to revise a one-time basis the current Unit 2 low pressure Emergency Core Cooling System (ECCS) injection/spray completion time (CT) from 7 days to 14 days. The emergency request to extend the CT was necessary as a result of additional efforts to restore the low pressure coolant injection (LPCI) motor-generator (MG) set due to the additional failure of the replacement LPCI MG set.

Subsequently, on November 22, 2005, at 11:15 AM, operability of the associated ECCS equipment was restored and the relevant TS Required Actions were exited. As a result, in a letter dated November 22, 2005, TVA requested that the proposed emergency TS change be withdrawn.

The purpose of this letter is to advise that the above cited application is being treated as withdrawn. This completes the U.S. Nuclear Regulatory Commission staff's review of the November 21, 2005, submittal under TAC No. MC8928.

Sincerely,

/RA/

Eva A. Brown, Project Manager
Project Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-260

cc: See next page

December 8, 2005

Mr. Karl W. Singer
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNIT 2 — WITHDRAWAL OF ONE-TIME
EXTENSION TO LOW PRESSURE EMERGENCY CORE COOLING SYSTEM
COMPLETION TIME (TAC NO. MC8928)

Dear Mr. Singer:

By letter dated November 21, 2005, the Tennessee Valley Authority (TVA) submitted a request for an emergency technical specification (TS) change to revise a one-time basis the current Unit 2 low pressure Emergency Core Cooling System (ECCS) injection/spray completion time (CT) from 7 days to 14 days. The emergency request to extend the CT was necessary as a result of additional efforts to restore the low pressure coolant injection (LPCI) motor-generator (MG) set due to the additional failure of the replacement LPCI MG set.

Subsequently, on November 22, 2005, at 11:15 AM, operability of the associated ECCS equipment was restored and the relevant TS Required Actions were exited. As a result, in a letter dated November 22, 2005, TVA requested that the proposed emergency TS change be withdrawn.

The purpose of this letter is to advise that the above cited application is being treated as withdrawn. This completes the U.S. Nuclear Regulatory Commission staff's review of the November 21, 2005, submittal under TAC No. MC8928.

Sincerely,

/RA/

Eva A. Brown, Project Manager
Project Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-260

cc: See next page

Distribution:

PUBLIC	LPLII-2 R/F	RidsNrrPMEBrown	RidsNrrDorlLpld	BWetzel, EDO
BClayton (Hard copy)		RidsAcrsAcnwMailCenter	AHodgdon, OGC	LLois
RidsRgn2MailCenter(SCahill)		RidsOgcRp	GThomas	RidsNrrDorl

Package No.: ML053500136 TS: ML053490281

ADAMS ACCESSION NUMBER: ML053400298

NRR-106

OFFICE	LPL2-2/PM	LPL2-2/LA	LPL2-2/BC
NAME	EBrown	BClayton	MMarshall
DATE	12/ 08 /05	12/ 08 /05	12/ 08 /05

OFFICIAL RECORD COPY

Mr. Karl W. Singer
Tennessee Valley Authority

BROWNS FERRY NUCLEAR PLANT

cc:

Mr. Ashok S. Bhatnagar, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Glenn W. Morris, Manager
Corporate Nuclear Licensing
and Industry Affairs
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Larry S. Bryant, General Manager
Nuclear Engineering
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. William D. Crouch, Manager
Licensing and Industry Affairs
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Brian O'Grady, Site Vice President
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, AL 35611-6970

Mr. Robert J. Beecken, Vice President
Nuclear Support
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

State Health Officer
Alabama Dept. of Public Health
RSA Tower - Administration
Suite 1552
P.O. Box 303017
Montgomery, AL 36130-3017

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

Chairman
Limestone County Commission
310 West Washington Street
Athens, AL 35611
Karl W. Singer

Mr. John C. Fornicola, Manager
Nuclear Assurance and Licensing
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Bruce Aukland, Plant Manager
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609