

From: Sandra Figueroa *JOE*
To: Undine Shoop
Date: 4/21/05 9:53AM
Subject: Fwd: EN-05-013, FirstEnergy Nuclear Operating Company

FYI - Chris

F-2

From: Sandra Figueroa 10E
To: ENLIST
Date: 4/20/05 3:04PM
Subject: EN-05-013, FirstEnergy Nuclear Operating Company
Place: OPA

EA-03-025, EA-05-066, EA-05-067, EA-05-068, EA-05-069, EA-05-070, EA-05-071,
EA-05-072, IA-05-021

ADAMS ACN #ML051100424

CC: Doug Starkey; Kenneth O'Brien

April 20, 2005
EN-05-013

OFFICE OF ENFORCEMENT
NOTIFICATION OF SIGNIFICANT REGULATORY ACTION

Licensee: FirstEnergy Nuclear Operating Company EA-03-025, EA-05-066, EA-05-067
Davis-Besse Nuclear Power Station EA-05-068, EA-05-069, EA-05-070,
Docket No. 50-346 EA-05-071, EA-05-072, IA-05-021

Subject: PROPOSED IMPOSITION OF CIVIL PENALTY - \$5,450,000

This is to inform the Commission that a Notice of Violation (NOV) and Proposed Imposition of Civil Penalty in the amount of \$5,450,000 will be issued on or about April 21, 2005, to FirstEnergy Nuclear Operating Company (FENOC). This action is based on FENOC's failure to properly implement the boric acid corrosion control and corrective action programs at its Davis-Besse Nuclear Power Station (Davis-Besse), which allowed reactor coolant system pressure boundary leakage to occur undetected for a prolonged period of time, resulting in reactor pressure vessel head degradation. The NRC assessed the significance of the performance deficiency using the Significance Determination Process (SDP) and concluded that the significance was in the RED range. A RED finding is one with high importance to safety that will result in increased NRC inspection and other NRC action.

The violations associated with the enforcement action fall within two categories. The first category involves non-willful violations associated with the RED finding related to the reactor vessel head wastage event. Central to the significance of this finding is that from May 18, 2000, to February 16, 2002, the licensee started up and operated the plant with reactor coolant system pressure boundary leakage, a violation of the Technical Specification (TS). The NRC is proposing a \$5,000,000 civil penalty for this violation. The second category includes four willful violations of NRC requirements for which the staff is proposing civil penalties in the amount of \$450,000, the statutory maximum civil penalty. There are two additional violations related to the completeness and accuracy of information that will be noticed with no associated civil penalty.

A separate enforcement action involves the issuance of an Order banning an individual from all NRC-licensed activities for a period of 5 years for violating 10 CFR 50.5, "Deliberate misconduct." Specifically, the individual deliberately provided inaccurate information concerning the removal of boric acid deposits from the Davis-Besse reactor pressure vessel head and the completion of required inspection of the reactor pressure vessel head for reactor coolant system leakage, which caused FENOC to be in violation of 10 CFR 50.9, "Completeness and Accuracy of Information."

It should be noted that the licensee has not been specifically informed of these enforcement actions. The schedule of issuance and notification is:

Telephone Notification of Licensee and individual April 21, 2005
Mailing of the Notice of Violation and Proposed Imposition April 21, 2005
of Civil Penalty and Order

The State of Ohio will be informed.

Contacts: D. Starkey, OE, 415-3456 C. Nolan, OE, 415-3360

PRELIMINARY INFORMATION - NOT FOR PUBLIC DISCLOSURE UNTIL VERIFICATION THAT LICENSEE HAS RECEIVED ACTION

Distribution:

OWFN

Chairman Diaz
Comm. McGaffigan
Comm. Merrifield
Comm. Lyons
Comm. Jaczko

SECY
OCA
PA
IP

OWFN

EDO
DEDR
DEDE
OE
OGC
NRR
NSIR
OI
SP

TWFN

OCFO
OP CENTER
NMSS
OIG
OCIO
RES
ACRS

Regional Offices

RI RII
RIII RIV

MAIL
ADAMS

File Name: G:\OECASES\ENs\2005 ENs\EN-05-013.DavisBesse.drs.wpd

ADAMS ACN. ML0510110424

OE:ES OE:C

DStarkey CNolan
04/19/05 04/20/05

PRELIMINARY INFORMATION - NOT FOR PUBLIC DISCLOSURE UNTIL VERIFICATION THAT LICENSEE HAS RECEIVED ACTION