

December 20, 2005

Mr. Jeffrey S. Forbes
Site Vice President
Arkansas Nuclear One
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

SUBJECT: CORRECTION LETTER - ARKANSAS NUCLEAR ONE, UNIT NO. 2
ISSUANCE OF AMENDMENT RE: CONTAINMENT STRUCTURAL
INTEGRITY (TAC NO. MC5637)

Dear Mr. Forbes:

On September 29, 2005, the U.S. Nuclear Regulatory Commission issued Amendment No. 262 to Renewed Facility Operating License No. NPF-6 for Arkansas Nuclear One, Unit No. 2. The amendment was in response to your application dated December 20, 2004, as supplemented by letter dated April 26, 2005. The amendment changed the containment structures and tendon inservice inspection requirements to be consistent with NUREG-1432, "Standard Technical Specifications, Combustion Engineering Plants," Revision 3 and the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI. These changes modify the Surveillance Requirement of Technical Specification (TS) 3.6.1.5, add a new Surveillance Program to TS 6.5.6, add a new report to TS 6.5.7, and make two administrative changes to the TSs.

After issuance, it was discovered that page 6-6, provided with Amendment No. 262, omitted a requirement pertaining to tendon baseline measurements from initial operation. Please replace the incorrect page with the enclosed corrected page for Amendment No. 262.

If you have any questions, please contact me at 301-415-1436.

Sincerely,

/RA/

Drew G. Holland, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-368

Enclosure: Corrected TS page 6-6

cc w/encl: See next page

December 20, 2005

Mr. Jeffrey S. Forbes
Site Vice President
Arkansas Nuclear One
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

SUBJECT: CORRECTION LETTER - ARKANSAS NUCLEAR ONE, UNIT NO. 2
ISSUANCE OF AMENDMENT RE: CONTAINMENT STRUCTURAL
INTEGRITY (TAC NO. MC5637)

Dear Mr. Forbes:

On September 29, 2005, the U.S. Nuclear Regulatory Commission issued Amendment No. 262 to Renewed Facility Operating License No. NPF-6 for Arkansas Nuclear One, Unit No. 2. The amendment was in response to your application dated December 20, 2004, as supplemented by letter dated April 26, 2005. The amendment changed the containment structures and tendon inservice inspection requirements to be consistent with NUREG-1432, "Standard Technical Specifications, Combustion Engineering Plants," Revision 3 and the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI. These changes modify the Surveillance Requirement of Technical Specification (TS) 3.6.1.5, add a new Surveillance Program to TS 6.5.6, add a new report to TS 6.5.7, and make two administrative changes to the TSs.

After issuance, it was discovered that page 6-6, provided with Amendment No. 262, omitted a requirement pertaining to tendon baseline measurements from initial operation. Please replace the incorrect page with the enclosed corrected page for Amendment No. 262.

If you have any questions, please contact me at 301-415-1436.

Sincerely,
/RA/

Drew G. Holland, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-368

Enclosure: Corrected TS page 6-6

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDirsltsb (TBoyce)
LPLIV RF	RidsOgcRp
GHill (2)	RidsAcrsAcnwMailCenter
RidsNrrDorlLplg (DTerao)	RidsRgn4MailCenter (DGraves)
RidsNrrPMDHolland	RidsNrrDorlDpr
RidsNrrLADJohnson	RTaylor

TS: ML053540042 NRR-100
Accession No.: ML053420654 PKG.: ML053540111 NRR-106

OFFICE	LPL4/PM	LPL4/LA	LPL4/BC
NAME	DHolland	DJohnson*	DTerao
DATE	12/20/05	12/20/05	12/20/05

Arkansas Nuclear One

cc:

Senior Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Director, Division of Radiation
Control and Emergency Management
Arkansas Department of Health
4815 West Markham Street, Slot 30
Little Rock, AR 72205-3867

Winston & Strawn
1700 K Street, N.W.
Washington, DC 20006-3817

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, AR 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

County Judge of Pope County
Pope County Courthouse
Russellville, AR 72801

Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205