

**APPENDIX B
TO
FACILITY OPERATING LICENSE DPR-24
AND
FACILITY OPERATING LICENSE DPR-27
FOR
POINT BEACH NUCLEAR PLANT UNITS NOS. 1 AND 2**

DOCKET NOS. 50-266 AND 50-301

APPENDIX B
TO
FACILITY OPERATING LICENSE DPR-24
AND
FACILITY OPERATING LICENSE DPR-27
FOR POINT BEACH NUCLEAR PLANT UNIT NOS. 1 AND 2
WISCONSIN ELECTRIC POWER COMPANY
WISCONSIN MICHIGAN POWER COMPANY
NUCLEAR MANAGEMENT COMPANY
DOCKET NOS. 50-266 AND 50-301

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
16	NONRADIOLOGICAL TECHNICAL SPECIFICATIONS	16.1-1
16.1	Definitions	16.1-1
16.2	Limiting Conditions for Operation	16.1-2
16.3	Environmental Monitoring	16.1-2
16.4	Record Keeping and Monitoring Program for Nonradiological Parameters	16.1-2
16.5	Reporting Requirements	16.1-3

Unit 1 - Amendment No. 69

Unit 2 - Amendment No. 74 16-1

16. NONRADIOLOGICAL TECHNICAL SPECIFICATIONS

16.1 Definitions

The definitions for terms used in these Nonradiological Technical Specifications for Units 1 and 2 are stated below.

WPDES Permit

The WPDES permit is the Wisconsin Pollutant Discharge Elimination System Permit No. WI-0000957 issued by the State of Wisconsin Department of Natural Resources for the Wisconsin Electric Power Company, Point Beach Nuclear Plant, and as subsequently amended.

16.2 Limiting Conditions for Operation

None required.*

16.3 Environmental Monitoring

None required.*

16.4 Recordkeeping and Monitoring Program for Nonradiological Parameters

None required.*

* In consideration of the provisions of the Clear Water Act (33 USC & 1251, et seq.) and in the interest of avoiding duplication of effort, the conditions and monitoring and recording requirements related to water quality and aquatic biota are specified in the WPDES Permit. As a matter of law, the NRC acknowledges the applicability of the WPDES Permit limitations for protection of the aquatic environment due to nonradiological effluents.

16.5 Reporting Requirements

Specification

1. As part of the Annual Monitoring Report, described in Section 5.6.2 of Appendix A, the following shall be reported:
 - a. All scheduled and unscheduled chemical discharge to the condenser cooling water.
 - b. A description of circulating water system operation for each unit which includes ambient temperature, intake temperature, discharge temperature, and circulating water system flow.