

**APPENDIX C
TO
FACILITY OPERATING LICENSE DPR-27
FOR
POINT BEACH NUCLEAR PLANT UNIT NO. 2**

DOCKET NO. 50-301

APPENDIX C
ADDITIONAL CONDITIONS
OPERATING LICENSE NO. DPR-27

Nuclear Management Company, LLC shall comply with the following conditions and the schedules noted below:

<u>Amendment Number</u>	<u>Additional Conditions</u>	<u>Implementation Date</u>
178	Deleted	
178	This amendment is authorized contingent on compliance with commitments provided by the licensee to operate Point Beach Nuclear Plant in accordance with its service water system analyses and approved procedures. Specifically, each unit will utilize only one component cooling water heat exchanger until such time as analyses are completed and the service water system reconfigured as necessary to allow operation of one or both units with two heat exchangers in service. If two component cooling water heat exchangers are required in one or both units for maintaining acceptable component cooling water temperature prior to completion of necessary analyses to allow operation in the required configuration, the service water system will be considered in an unanalyzed condition, declared inoperable, and action taken as specified by TS LCO 3.0.3 except for short periods of time as necessary to effect procedurally controlled changes in system lineups and unit operating conditions.	Immediately
206	The licensee is authorized to relocate certain Technical Specification requirements previously included in Appendix A to licensee controlled documents, as described in Table R, Relocated Specifications and Removal of Details Matrix, attached to the NRC Staff's safety evaluation dated August 8, 2001. These requirements shall be relocated to the appropriate documents no later than December 31, 2001.	Immediately
206	<p>The schedule for performing Surveillance Requirements (SRs) that are new or revised in Amendment No. 206 shall be as follows:</p> <p>For SRs that are new in this amendment, the first performance is due at the end of the first surveillance interval that begins on the date of implementation of this amendment.</p> <p>For SRs that existed prior to this amendment, whose intervals of performance are being reduced, the first reduced surveillance interval begins upon completion of the first surveillance performed after implementation of this amendment.</p> <p>For SRs that existed prior to this amendment that have modified acceptance criteria, the first performance is due at the end of the first surveillance interval that began on the date the surveillance was last performed prior to the implementation of this amendment.</p> <p>For SRs that existed prior to this amendment, whose intervals of performance are being extended, the first extended surveillance interval begins upon completion of the last surveillance performed</p>	Immediately