

SAFETY INSPECTION REPORT AND COMPLIANCE INSPECTION

1. LICENSEE/LOCATION INSPECTED: <i>City of Wyandotte 3005 B. DOLE Ave Wyandotte MI</i>		2. NRC/REGIONAL OFFICE: <i>NRC Region III 2443 Warrenville Rd Lisle, IL</i>	
REPORT NUMBER(S) <i>3030852/2005001</i>			
3. DOCKET NUMBER(S) <i>03030852</i>	4. LICENSE NUMBER(S) <i>21-25984-01</i>	5. DATE(S) OF INSPECTION <i>Nov. 29, 2005</i>	

LICENSEE:
The inspection was an examination of the activities conducted under your license as they relate to radiation safety and to compliance with the Nuclear Regulatory Commission (NRC) rules and regulations and the conditions of your license. The inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector. The inspection findings are as follows:

- 1. Based on the inspection findings, no violations were identified.
 - 2. Previous violation(s) closed.
 - 3. The violation(s), specifically described to you by the inspector as non-cited violations, are not being cited because they were self-identified, non-repetitive, and corrective action was or is being taken, and the remaining criteria in the NRC Enforcement Policy, NUREG-1600, to exercise discretion, were satisfied.
- _____ non-cited violation(s) were discussed involving the following requirement(s):

4. During this inspection, certain of your activities, as described below and/or attached, were in violation of NRC requirements and are being cited. This form is a NOTICE OF VIOLATION, which may be subject to posting in accordance with 10 CFR 19.11.

(Violations and Corrective Actions)

10 CFR PART 29.1902 requires the licensee to post each radiation area with a conspicuous sign or signs bearing the radiation symbol and words "Caution, Radiation Area."
Contrary to the above, on Nov 21, 2005, the licensee did not have the fixed gauge on the "A-Feeder" labeled with radiation warning sign. The licensee will replace the missing labels within two weeks.

Statement of Corrective Actions

I hereby state that, within 30 days, the actions described by me to the Inspector will be taken to correct the violations identified. This statement of corrective actions is made in accordance with the requirements of 10 CFR 2.201 (corrective steps already taken, corrective steps which will be taken, date when full compliance will be achieved). I understand that no further written response to NRC will be required, unless specifically requested.

TITLE	PRINTED NAME	SIGNATURE	DATE
LICENSEE	Richard W. Arens	<i>Richard W. Arens</i>	29 Nov '05
NRC INSPECTOR	G. Parker V. Kulzer	<i>G. Parker V. Kulzer</i>	11/29/05

Docket File Information
SAFETY INSPECTION REPORT
AND COMPLIANCE INSPECTION

1. LICENSEE City of Wyandotte REPORT NUMBER(S) 03030852/2005-001		2. NRC/REGIONAL OFFICE Region III	
3. DOCKET NUMBER(S) 030-30852	4. LICENSE NUMBER(S) 21-25984-01	5. DATE(S) OF INSPECTION November 29, 2005	
6. INSPECTION PROCEDURES USED 87124	7. INSPECTION FOCUS AREAS 03.01 - 03.07		

SUPPLEMENTAL INSPECTION INFORMATION

1. PROGRAM CODE(S) 03120	2. PRIORITY 5	3. LICENSEE CONTACT Richard Arens	4. TELEPHONE NUMBER 734/324-7170
-----------------------------	------------------	--------------------------------------	-------------------------------------

Main Office Inspection Next Inspection Date: **November 2010**

Field Office _____

Temporary Job Site _____

PROGRAM SCOPE

The licensee is City of Wyandotte power company that produces electrical power for the city and employs 31 individuals. The licensee possesses 5 specifically licensed fixed gauges used in the production of electrical power. Currently, one individual (the RSO) is involved with the use and oversight of the devices. Gauges are leak tested at three-year frequencies in accordance with manufacturers specifications. Inventories and shutter checks are performed at required frequencies.

The licensee is authorized to remove and/or relocate gauges, however, according to the authorized users, gauges are relocated, removed, etc. by the manufacturer. The licensee does not perform any service or maintenance activities on its gauges; these services are performed by the manufacturer.

Performance Observations

The inspectors performed a walk down of the facility and observed the gauges in conjunction with the licensee's current inventory. The licensee had lock/tag-out and leak test procedures which were also adequately described. Interviews conducted with plant workers revealed that under no circumstances would a vessel be entered without RSO supervision following lock-out/tag-out procedures. The inspector performed independent and confirmatory radiation measurements which indicated similar results as noted in the licensee's survey records, < 2 mR/hour.

At the time of the inspection, the licensee had no "Caution Radiation" labels on the fixed gauge on the "A-feeder" line. The RSO stated that the gauge would be labeled in the next two weeks.