

## 5.0 ADMINISTRATIVE CONTROLS

### 5.3 Unit Staff Qualifications

---

5.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of the American National Standards Institute N18.1-1971, "Selection and Training of Nuclear Power Plant Personnel," with the following exceptions:

- a. The radiological manager shall meet or exceed the qualifications of Regulatory Guide 1.8, Revision 2.
  - b. The Shift Manager, Senior Operator, Licensed Operator, and Shift Technical Engineer shall meet or exceed the qualifications of Regulatory Guide 1.8, Revision 3.
  - c. The operations manager shall meet or exceed the qualifications of ANSI N18.1-1971 except for the requirement to have a current Senior Reactor Operator's (SRO) license, which shall be in accordance with Technical Specification 5.2.2.e. If not currently licensed, the operations manager shall have previously held a SRO license.
-