



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

REGION II  
SAM NUNN ATLANTA FEDERAL CENTER  
61 FORSYTH STREET, SW, SUITE 23T85  
ATLANTA, GEORGIA 30303-8931

December 20, 2005

Duke Energy Corporation  
ATTN: Mr. Ronald A. Jones  
Vice President  
Oconee Site  
7800 Rochester Highway  
Seneca, SC 29672

SUBJECT: NOTIFICATION OF OCONEE NUCLEAR STATION COMPONENT DESIGN  
BASES INSPECTION - NRC INSPECTION REPORT 05000269/2006006,  
05000270/2006006 AND 05000287/2006006

Dear Mr. Jones:

The purpose of this letter is to notify you that the U.S. Nuclear Regulatory Commission (NRC) Region II staff will conduct a component design bases inspection at your Oconee Nuclear Station during the weeks of February 13-17, 2006, February 27-March 3, 2006, and March 13-17, 2006. The inspection team will be led by Mr. Caudle Julian, a Senior Reactor Inspector from the NRC's Region II Office. This inspection will be conducted in accordance with the baseline inspection procedure, Procedure 71111.21, Component Design Bases Inspection, issued December 2, 2005

The inspection will evaluate the capability of risk significant / low margin components to function as designed and support proper system operation. The inspection will also include a review of selected operator actions, operating experience, and modifications.

During a telephone conversation on November 22, 2005, Mr. R. Moore of my staff, and Ms. J. Smith of your staff, confirmed arrangements for an information gathering site visit and the three-week onsite inspection. The schedule is as follows:

- Information gathering visit: Week of January 30, 2006
- Onsite weeks: February 13, 2006; February 27, 2006; and March 13, 2006

The purpose of the information gathering visit is to meet with members of your staff to identify risk-significant components and operator actions. Information and documentation needed to support the inspection will also be identified. Mr. Walter Rogers, a Region II Senior Reactor Analyst, will accompany Mr. Julian and the inspection team during the information gathering visit to review probabilistic risk assessment data and identify risk significant components which will be examined during the inspection. Please contact Mr. Julian prior to preparing copies of the materials listed in the enclosure. The inspectors will try to minimize your administrative burden by specifically identifying only those documents required for inspection preparation.

During the information gathering visit, the team leader will also discuss the following inspection support administrative details: office space; specific documents requested to be made available to the team in the Region II office prior to the inspection preparation week of February 6, 2006; arrangements for site access; and the availability of knowledgeable plant engineering and licensing personnel to serve as points of contact during the inspection.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Thank you for your cooperation in this matter. If you have any questions regarding the information requested or the inspection, please contact Mr. Julian at (404) 562-4603 or me at (404) 562-4605.

Sincerely,

**/RA/**

Charles R. Ogle, Chief  
Engineering Branch 1  
Division of Reactor Safety

Docket Nos.: 50-269, 50-270, and 50-287  
License Nos.: DPR - 38, DPR - 47, and DPR - 55

Enclosure  
cc: w/encl: (See page 3)

cc w/encl:  
B. G. Davenport  
Compliance Manager (ONS)  
Duke Energy Corporation  
Electronic Mail Distribution

Lisa Vaughn  
Associate General Counsel  
Duke Energy Corporation  
526 South Church Street  
Mail Code EC 07H  
Charlotte, NC 28201-1244

Anne Cottingham  
Winston & Strawn LLP  
Electronic Mail Distribution

Beverly Hall, Acting Director  
Division of Radiation Protection  
N. C. Department of Environmental  
Health & Natural Resources  
Electronic Mail Distribution

Henry J. Porter, Assistant Director  
Div. of Radioactive Waste Mgmt.  
S. C. Department of Health and  
Environmental Control  
Electronic Mail Distribution

R. Mike Gandy  
Division of Radioactive Waste Mgmt.  
S. C. Department of Health and  
Environmental Control  
Electronic Mail Distribution

County Supervisor of  
Oconee County  
415 S. Pine Street  
Walhalla, SC 29691-2145

Lyle Graber, LIS  
NUS Corporation  
Electronic Mail Distribution

R. L. Gill, Jr., Manager  
Nuclear Regulatory Issues  
and Industry Affairs  
Duke Energy Corporation  
526 S. Church Street  
Charlotte, NC 28201-0006

Peggy Force  
Assistant Attorney General  
N. C. Department of Justice  
Electronic Mail Distribution

DEC

4

Distribution w/encl:

L. Olshan, NRR  
C. Evans (Part 72 Only)  
L. Slack, RII EICS  
RIDSNRRDIPMLIPB  
PUBLIC

PUBLICLY AVAILABLE       NON-PUBLICLY AVAILABLE       SENSITIVE       NON-SENSITIVE

ADAMS:X Yes      ACCESSION NUMBER: \_\_\_\_\_

OFFICE	RII:DRS	RII:DRS	RII:DRS	RII:DRS	RII:DRS		
SIGNATURE	/RA/	/RA/	/RA/	/RA/	/RA/		
NAME	C. Ogle	M. Ernstes	R. Moore	L. Mellen	CJulian		
DATE	12/20/2500	12/19/2005	12/19/2005	12/19/2005	12/19/2005	12/ /2005	12/ /2005
E-MAIL COPY?	NO	YES NO	YES NO	YES NO	YES	YES NO	YES NO

OFFICIAL RECORD COPY      DOCUMENT NAME: E:\Filenet\ML053540247.wpd

**INFORMATION REQUEST FOR OCONEE NUCLEAR STATION**

## COMPONENT DESIGN BASES INSPECTION

(Please provide the information electronically in “.pdf” files, Excel, or other searchable format on CDROM. The CDROM should be indexed and hyperlinked to facilitate ease of use. Information in “lists” should contain enough information to be easily understood by someone who has a knowledge of pressurized water reactor technology.)

1. Risk ranking of components from your site specific probabilistic safety analysis (PSA) sorted by Risk Achievement Worth (RAW) and sorted separately by Birnbaum Importance. (If possible, provide component identification related to event name column on list of Basic Event Importances by RAW list.)
2. Provide a list of the top 500 cutsets from your PSA.
3. Risk ranking of operator actions from your site specific PSA sorted by RAW. Provide copies of your human reliability worksheets for these items.
4. If you have an External Events or Fire PSA Model, provide the information requested in Items 1 and 2 for external events and fire.
5. Any pre-existing evaluation or list of components and calculations with low design margins, (i.e., pumps closest to the design limit for flow or pressure, diesel generator close to design required output, heat exchangers close to rated design heat removal etc.)
6. A list of the last two years of operating experience evaluations, modifications, and corrective actions sorted by component or system.
7. Information of any common cause failure of components experienced in the last 5 years at your facility.

Enclosure