



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001
December 16, 2005

DOCKETED
USNRC

December 20, 2005 (9:50am)

OFFICE OF SECRETARY
RULEMAKINGS AND
ADJUDICATIONS STAFF

Docket No. 50-271-OLA

SERVED December 20, 2005

SECRETARY

The Honorable John Olver
United States House of Representatives
Washington, D.C. 20515

Dear Congressman Olver:

This is a response to your letter dated November 10, 2005, addressed to Chairman Nils J. Diaz, in which you request an evaluation by the NRC of the condition of the steam dryer at the Vermont Yankee Nuclear Power Station. You emphasized that it is essential that your constituents receive information on the condition of the steam dryer during the consideration by the NRC of the proposed power uprate for Vermont Yankee. Your letter has been referred to the NRC staff. The staff will address your specific concerns in a direct reply.

Currently, contentions addressing the power uprate for Vermont Yankee are before an Atomic Safety and Licensing Board in a contested proceeding. Under Nuclear Regulatory Commission procedural rules for adjudications, the Commission has an appellate role in proceedings commenced before its Atomic Safety and Licensing Boards. Because of that role, I trust that you will understand that the Commissioners must remain impartial during the pendency of a case, whether it is before a Licensing Board or on appeal to the Commission.

A copy of your letter and this response, as well as, the response of the NRC staff when issued will be served on the participants in the Vermont Yankee proceeding.

Sincerely,

A handwritten signature in black ink, appearing to read "Annette L. Vietti-Cook".

Annette L. Vietti-Cook

cc: Vermont Yankee Service List



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 16, 2005

The Honorable John W. Olver
United States House of Representatives
Washington, D.C. 20515

Dear Representative Olver:

On behalf of the Nuclear Regulatory Commission (NRC), I am writing in response to your letter of November 10, 2005, in which you urged the NRC to fully evaluate the condition of the steam dryer at the Vermont Yankee Nuclear Power Station (Vermont Yankee) as the NRC staff reviews the proposed extended power uprate (EPU) request from Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). I am pleased to take this opportunity to update you on the NRC's actions to address this issue.

During the fall 2005 refueling outage at Vermont Yankee, Entergy performed an enhanced visual inspection which identified 46 indications of small cracks in the steam dryer. These were in addition to 18 indications identified during the spring 2004 outage. Although the previous dryer inspection was conducted in accordance with the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, it was expected that additional indications would be found during the 2005 outage based on use of visual examination techniques that provided greater magnification and resolution. The enhanced inspection also confirmed that none of the previously-identified cracks had propagated in width or length since the last inspection.


Entergy currently believes that, like the previously-identified indications, these new indications developed sometime early in plant operational history, and will not affect the steam dryer structural integrity at current power conditions or at the proposed EPU conditions. None of the identified indications required repairs; however, Entergy did make modifications during the 2004 outage to provide additional structural support to the steam dryer to address generic industry issues with steam dryer integrity. Entergy will continue to monitor the indications during future inspections to ensure there is no further change to the individual indications.

The NRC is closely monitoring Entergy's steam dryer examination and evaluation activities. A specialist inspector from the NRC's Region I office was sent to the site to review the steam dryer inspection results. Further, specialists from Region I and NRC Headquarters reviewed the examination data and steam dryer evaluation. The NRC reviews did not identify problems with the steam dryer crack evaluation and disposition that would cause concern with operation of Vermont Yankee at current licensed conditions.

Entergy is completing its final evaluation of the new steam dryer indications with regard to EPU operation. The NRC will thoroughly review the final evaluation as part of the proposed EPU review. Additionally, if the proposed EPU is granted, a condition would be added to the Vermont Yankee license for Entergy to monitor and evaluate the effects of increased steam flow on the steam dryer, and promptly take actions as necessary to resolve any adverse flow effects.

The NRC's primary mission is to ensure adequate protection of public health and safety. The NRC will not approve the Vermont Yankee EPU, or any proposed change to any plant license, unless our technical staff can conclude that it has reasonable assurance that adequate protection of public health and safety will be ensured.

Sincerely,

A handwritten signature in black ink, appearing to read "Luis A. Reyes". The signature is fluid and cursive, with a large initial "L" and "R".

Luis A. Reyes
Executive Director
for Operations

Congress of the United States

Washington, DC 20515

November 10, 2005

The Honorable Nils J. Diaz
Chairman
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Dear Mr. Chairman:



We write in response to the announcement today of the discovery, during a recent scheduled outage, of more than 40 additional cracks in the steam dryer at Vermont Yankee. We understand that a Region 1 Nuclear Regulatory Commission (NRC) inspector was dispatched to assist the resident inspector in the determining whether these cracks pose safety and operational concerns for the plant's current power production. We request that the condition of the steam dryer be fully evaluated, using the techniques of the most recent inspection and any other appropriate means, as the NRC considers Entergy Nuclear's request to produce an additional 100 megawatts of power from Vermont Yankee.

We understand that these cracks were discovered through the use of enhanced visual inspection techniques. As you know, these cracks are in addition to some 18 cracks, both hairline and larger, that were discovered through visual inspections of the plant's steam dryer in April and May of 2004. Steam dryer cracking is of concern at many boiling water reactor facilities. We know that cracking problems have persisted at the Quad Cities facilities' steam dryers, despite repeated fixes, and that uprated power conditions at those facilities place additional stresses on dryer performance. While the steam dryer itself is not a safety-related piece of equipment, its proper functioning is important to the plant's safe and reliable operation. Steam dryer cracking could result in pieces breaking off, and falling back into the steam lines that lead out of the reactor. In the case of the Quad Cities reactors, these plants have been forced to shut down because of cracking, making their operation less reliable.

As the NRC reviews the Vermont Yankee power uprate request, we believe it is essential that our constituents receive needed information about whether the plant's steam dryer will be able to withstand boosted power conditions and operate safely and reliably. The functioning of this piece of equipment should receive the Commission's full and thorough attention during the review of the uprate application.

We look forward to a prompt reply.

Sincerely,



Diaz, pg. 2
November 10, 2005

Burt A. A.

John W. Oliver

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
ENTERGY NUCLEAR VERMONT YANKEE L.L.C.) Docket No. 50-271-OLA
and ENTERGY NUCLEAR OPERATIONS, INC.)
)
Vermont Yankee Nuclear Power Station))
)
(Operating License Amendment))

CERTIFICATE OF SERVICE

I hereby certify that copies of the foregoing LETTERS FROM ANNETTE L. VIETTI-COOK AND LUIS A. REYES ADDRESSED TO CONGRESSMAN JOHN W. OLVER, AS WELL AS THE LETTER FROM CONGRESSMAN JOHN W. OLVER DATED NOVEMBER 10, 2005 have been served upon the following persons by U.S. mail, first class, or through NRC internal distribution.

Office of Commission Appellate
Adjudication
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Administrative Judge
Alex S. Karlin, Chair
Atomic Safety and Licensing Board Panel
Mail Stop - T-3 F23
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Administrative Judge
Anthony J. Baratta
Atomic Safety and Licensing Board Panel
Mail Stop - T-3 F23
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Administrative Judge
Lester S. Rubenstein
4270 E Country Villa Drive
Tucson, AZ 85718

Robert M. Weisman, Esq.
Sherwin E. Turk, Esq.
Jason C. Zorn, Esq.
Office of the General Counsel
Mail Stop - O-15 D21
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Raymond Shadis
New England Coalition
P.O. Box 98
Edgecomb, ME 04556

Docket No. 50-271-OLA
LETTERS FROM ANNETTE L. VIETTI-COOK AND LUIS A. REYES
ADDRESSED TO CONGRESSMAN JOHN W. OLVER, AS WELL
AS THE LETTER FROM CONGRESSMAN JOHN W. OLVER DATED
NOVEMBER 10, 2005


John M. Fulton, Esq.
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Sarah Hofmann, Esq.
Special Counsel
Department of Public Service
112 State Street - Drawer 20
Montpelier, VT 05620-2601

Anthony Z. Roisman, Esq.
National Legal Scholars Law Firm
84 East Thetford Rd.
Lyme, NH 03768

Jay E. Silberg, Esq.
Matias F. Travieso-Diaz, Esq.
Pillsbury Winthrop Shaw Pittman LLP
2300 N Street, NW
Washington, DC 20037-1128

Jonathan M. Rund, Esq.
Law Clerk
Atomic Safety and Licensing Board Panel
Mail Stop - T-3 F23
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001


Office of the Secretary of the Commission

Dated at Rockville, Maryland,
this 20th day of December 2005