



U.S. NUCLEAR REGULATORY COMMISSION

STANDARD REVIEW PLAN

6.2.1.3 MASS AND ENERGY RELEASE ANALYSIS FOR POSTULATED LOSS-OF-COOLANT ACCIDENTS (LOCAs)

REVIEW RESPONSIBILITIES

Primary - Organization responsible for the review of containment integrity

Secondary - None

I. AREAS OF REVIEW

The analyses of the mass and energy release are reviewed to assure that the data used to evaluate the containment and subcompartment functional design are acceptable for that purpose.

The specific areas of review are as follows:

1. The energy sources that are available for release to the containment.
2. The mass and energy release rate calculations for the initial blowdown phase of the accident.
3. For pressurized water reactor (PWR) plants, because of the additional steam generator stored energy available for release, the mass and energy release rate calculations for the core reflood and post-reflood phases of the accident.

Revision 3 - March 2007

USNRC STANDARD REVIEW PLAN

This Standard Review Plan, NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The Standard Review Plan is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The standard review plan sections are numbered in accordance with corresponding sections in Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of Regulatory Guide 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to NRR_SRP@nrc.gov.

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to DISTRIBUTION@nrc.gov. Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML053560191.

4. Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC). For design certification (DC) and combined license (COL) reviews, the staff reviews the applicant's proposed ITAAC associated with the structures, systems, and components (SSCs) related to this SRP section in accordance with SRP Section 14.3, "Inspections, Tests, Analyses, and Acceptance Criteria." The staff recognizes that the review of ITAAC cannot be completed until after the rest of this portion of the application has been reviewed against acceptance criteria contained in this SRP section. Furthermore, the staff reviews the ITAAC to ensure that all SSCs in this area of review are identified and addressed as appropriate in accordance with SRP Section 14.3.
5. COL Action Items and Certification Requirements and Restrictions. For a DC application, the review will also address COL action items and requirements and restrictions (e.g., interface requirements and site parameters).

For a COL application referencing a DC, a COL applicant must address COL action items (referred to as COL license information in certain DCs) included in the referenced DC. Additionally, a COL applicant must address requirements and restrictions (e.g., interface requirements and site parameters) included in the referenced DC.

Review Interfaces

Other SRP sections interface with this section as follows:

1. Review of the acceptability of piping design criteria, selected break locations and break sizes based on the provisions made to limit pipe motion, for breaks postulated to occur within subcompartments is performed under SRP Section 3.6.2.

The specific acceptance criteria and review procedures are contained in the referenced SRP sections.

II. ACCEPTANCE CRITERIA

Acceptance criteria are based on meeting the relevant requirements of the following Commission regulations:

1. General Design Criterion 50, as it relates to the containment and subcompartments being designed with sufficient margin, requires that the containment and its associated systems can accommodate, without exceeding the design leakage rate, and the containment and subcompartment design can withstand the calculated pressure and temperature conditions resulting from any LOCA.
2. 10 CFR Part 50, Appendix K, as it relates to sources of energy during the LOCA, provides requirements to assure that all the energy sources have been considered.
3. 10 CFR 52.47(b)(1), which requires that a DC application contain the proposed inspections, tests, analyses, and acceptance criteria (ITAAC) that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design

certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act, and the NRC's regulations.

4. 10 CFR 52.80(a), which requires that a COL application contain the proposed inspections, tests, and analyses, including those applicable to emergency planning, that the licensee shall perform, and the acceptance criteria that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, the facility has been constructed and will operate in conformity with the combined license, the provisions of the Atomic Energy Act, and the NRC's regulations.

SRP Acceptance Criteria

Specific SRP acceptance criteria acceptable to meet the relevant requirements of the NRC's regulations identified above are as follows for the review described in this SRP section. The SRP is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide acceptable methods of compliance with the NRC regulations.

1. General Design Criterion 50 and Appendix K to 10 CFR Part 50

- A. Sources of Energy. The sources of stored and generated energy that should be considered in analyses of LOCAs include: reactor power; decay heat; stored energy in the core; stored energy in the reactor coolant system metal, including the reactor vessel and reactor vessel internals; metal-water reaction energy; and stored energy in the secondary system (PWR plants only), including the steam generator tubing and secondary water.

Calculations of the energy available for release from the above sources should be done in general accordance with the requirements of 10 CFR Part 50, Appendix K, paragraph I.A. However, additional conservatism should be included to maximize the energy release to the containment during the blowdown and reflood phases of a LOCA. An example of this would be accomplished by maximizing the sensible heat stored in the reactor coolant system (RCS) and steam generator metal and increasing the RCS and steam generator secondary mass to account for uncertainties and thermal expansion.

The requirements of paragraph I.B in Appendix K to 10 CFR Part 50, concerning the prediction of fuel clad swelling and rupture should not be considered. This will maximize the energy available for release from the core.

- B. Break Size and Location

- i. The staff's review of the applicant's choice of break locations and types is discussed in SRP Section 3.6.2.

- ii. Of several breaks postulated on the basis of a., above, the break selected as the reference case for subcompartment analysis should yield the highest mass and energy release rates, consistent with the criteria for establishing the break location and area.
 - iii. Containment design basis calculations should be performed for a spectrum of possible pipe break sizes and locations to assure that the worst case has been identified.
- C. Calculations. In general, calculations of the mass and energy release rates for a LOCA should be performed in a manner that conservatively establishes the containment internal design pressure (i.e., maximizes the post-accident containment pressure and the containment subcompartment response). The criteria given below for each phase of the accident indicate the conservatism that should exist.

i. Subcompartment Analysis

The analytical approach used to compute the mass and energy release profile will be accepted if both the computer program and volume nodding of the piping system are similar to those of an approved emergency core cooling system (ECCS) analysis. The computer programs that are currently acceptable include SATAN-V CRAFT-2, CE FLASH-4, and RELAP4, when a flow multiplier of 1.0 is used with the applicable choked flow correlation. An alternate approach, which is also acceptable, is to assume a constant blowdown profile using the initial conditions with an acceptable choked flow correlation.

ii. Initial Blowdown Phase Containment Design Basis

The initial mass of water in the reactor coolant system should be based on the reactor coolant system volume calculated for the temperature and pressure conditions assuming that the reactor has been operating continuously at a power level at least 1.02 times the licensed power level (to allow for instrumentation error). An assumed power level lower than the level specified (but not less than the licensed power level) may be used provided the proposed alternative value has been demonstrated to account for uncertainties due to power level instrumentation error.

Mass release rates should be calculated using a model that has been demonstrated to be conservative by comparison to experimental data.

Calculations of heat transfer from surfaces exposed to the primary coolant should be based on nucleate boiling heat transfer. For surfaces exposed to steam, heat transfer calculations should be based on forced convection.

Calculations of heat transfer from the secondary coolant to the steam generator tubes for PWRs should be based on natural convection heat transfer for tube surfaces immersed in water and condensing heat transfer for the tube surfaces exposed to steam.

iii. PWR Core Reflood Phase (Cold Leg Breaks Only)

Following initial blowdown, which includes the period from the accident initiation (when the reactor is in a steady-state full power operation condition) to the time that the reactor coolant system broken loop pressure equalizes to the containment pressure, the water remaining in the reactor vessel should be assumed to be saturated. Justification should be provided for the refill period, which is the time from the end of the blowdown to the time when the emergency core cooling system (ECCS) refills the vessel lower plenum. An acceptable approach is to assume a water level at the bottom of the active core at the end of blowdown so there is no refill time.

Calculations of the core flooding rate should be based on the ECCS operating condition during the core reflood phase, which begins when the water starts to flood the core and continues until the core is completely quenched, or the post-reflood phase, which is the period after the core has been quenched and energy is released to the RCS primary system by the RCS metal, core decay heat, and the steam generators, that maximizes the containment pressure.

Calculations of liquid entrainment, i.e., the carryout rate fraction, which is the mass ratio of liquid exiting the core to the liquid entering the core, should be based on the PWR full length emergency cooling heat transfer experiments. Liquid entrainment should be assumed to continue until the water level in the core is 61 cm (2 feet) from the top of the core. An acceptable approach is to assume a carryout rate fraction (CRF) of 0.05 to the 46 cm (18-inch) core level, a linearly increasing CRF to 0.80 at the 61 cm (24-inch) level, and a constant CRF of 0.80 until the water level is 61 cm (2 feet) from the top of the core. Above this level, a CRF of 0.05 may be used.

The assumption of steam quenching should be justified by comparison with applicable experimental data. Liquid entrainment calculations should consider the effect on the CRF of the increased core inlet water temperature caused by steam quenching assumed to occur from mixing with the ECCS water.

Steam leaving the steam generators should be assumed to be superheated to the temperature of the secondary coolant.

iv. PWR Post-Reflood Phase

All remaining stored energy in the primary and secondary systems should be removed during the post-reflood phase.

Steam quenching should be justified by comparison with applicable experimental data.

The results of post-reflood analytical models should be compared to applicable experimental data.

v. PWR Decay Heat Phase

The dissipation of core decay heat should be considered during this phase of the accident. The fission product decay energy model is acceptable if it is equal to or more conservative than the decay energy model given in SRP Section 9.2.5.

Steam from decay heat boiling in the core should be assumed to flow to the containment by the path which produces the minimum amount of mixing with ECCS injection water.

The following methods and computer models are acceptable for calculating the mass and energy releases for containment design basis calculations:

Babcock and Wilcox / Framatome ANP: CRAFT, CRAFT-2, RELAP5/MOD2-B&W, Revision 1 and RELAP5/MOD2-B&W, Revision 4.

Combustion Engineering: CEFLASH-4A and CESSAR System 80.

General Electric: M3CPT, NEDO-20533, and SHEX.

Westinghouse: WCAP-8312, SATAN-V, WCAP-10325, SATAN-VI, and WREFLOOD.

These codes and methods have been referenced in licensee submittals and on a case by case basis have been found to be acceptable for these purposes.

Other methods will be acceptable if they are found to be conservative for these calculations.

2. 10 CFR 52.47(b)(1), which requires that a DC application contain the proposed inspections, tests, analyses, and acceptance criteria (ITAAC) that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act, and the NRC's regulations.

3. 10 CFR 52.80(a), which requires that a COL application contain the proposed inspections, tests, and analyses, including those applicable to emergency planning, that the licensee shall perform, and the acceptance criteria that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, the facility has been constructed and will operate in conformity with the combined license, the provisions of the Atomic Energy Act, and the NRC's regulations. 10 CFR 52.47(a)(1)(vi) provides the requirement for ITAAC for design certification reviews.

Technical Rationale

The technical rationale for application of these acceptance criteria to the areas of review addressed by this SRP section is discussed in the following paragraphs:

1. GDC 50 requires the containment structure and associated heat removal system to be designed with margin to accommodate any LOCA such that the containment design leak rate is not exceeded. A LOCA potentially causes the greatest pressure surge and release of fission products when compared to any other accident. Since it is the most severe challenge expected, containment must be designed to definitively withstand this accident. Following GDC 50 will ensure that containment integrity is maintained under the most severe accident conditions thus precluding the release of radioactivity to the environment.
2. Appendix K to 10 CFR 50 provides required and acceptable features of evaluation models used to analyze various circumstances applicable to the ECCS. Section I.A of Appendix K provides a comprehensive list of LOCA heat (energy) sources and the reactor operating history assumptions associated with those heat sources. Since the mass and energy release analysis for postulated LOCAs is used to design containment and containment subcompartments such that they will withstand the worst case LOCA, it is critical that all potential energy sources are taken into account. Following 10 CFR 50 Appendix K will ensure that containment and containment subcompartments are designed to accommodate all energy sources for the worst case LOCA, thus precluding the potential release of radioactivity to the environment following such a LOCA.

III. REVIEW PROCEDURES

The reviewer will select material from the procedures described below, as may be appropriate for a particular case.

These review procedures are based on the identified SRP acceptance criteria. For deviations from these acceptance criteria, the staff should review the applicant's evaluation of how the proposed alternatives provide an acceptable method of complying with the relevant NRC requirements identified in Subsection II.

The reviewer confirms, with the lead reviewer for SRP Section 3.6.2, the validity of the applicant's analysis of pipe break size, type and locations for subcompartments containing high energy lines by using elevation and plan drawings of the containment showing the routing of lines containing high energy fluids. The reviewer determines that an appropriate reference case for subcompartment analysis has been identified. In the event a pipe break other than a

double-ended pipe rupture is postulated by the applicant, the lead reviewer for SRP Section 3.6.2 will evaluate the applicant's justification for assuming a limited displacement pipe break.

The reviewer compares the sources of energy considered in the loss-of-coolant analysis and the methods and assumptions used to calculate the energy available for release from the various sources with the acceptance criteria listed in Section II, above. The reviewer determines the acceptability of the analytical models and the assumptions used to calculate the rates of mass and energy release during the initial blowdown, core reflood, and post-reflood phases of a LOCA. The reviewer also compares energy inventories at various times during a LOCA to ensure that the energy from the various sources has been accounted for and has been transferred to the containment on an appropriate time scale.

The reviewer reviews comparisons made by the applicant to experimental data and makes comparisons to other available experimental data to determine the amount of conservatism in the mass and energy release models.

The reviewer may perform confirmatory analyses of the mass and energy profiles. The purpose of the analysis is to confirm the predictions of the mass and energy release rates appearing in the safety analysis report, and to confirm that an appropriate break location has been considered in these analyses.

For review of a DC application, the reviewer should follow the above procedures to verify that the design, including requirements and restrictions (e.g., interface requirements and site parameters), set forth in the final safety analysis report (FSAR) meets the acceptance criteria. DCs have referred to the FSAR as the design control document (DCD). The reviewer should also consider the appropriateness of identified COL action items. The reviewer may identify additional COL action items; however, to ensure these COL action items are addressed during a COL application, they should be added to the DC FSAR.

For review of a COL application, the scope of the review is dependent on whether the COL applicant references a DC, an early site permit (ESP) or other NRC approvals (e.g., manufacturing license, site suitability report or topical report).

For review of both DC and COL applications, SRP Section 14.3 should be followed for the review of ITAAC. The review of ITAAC cannot be completed until after the completion of this section.

IV. EVALUATION FINDINGS

The conclusions reached on completion of the review of this SRP section are presented in SRP Section 6.2.1.

V. IMPLEMENTATION

The staff will use this SRP section in performing safety evaluations of DC applications and license applications submitted by applicants pursuant to 10 CFR Part 50 or 10 CFR Part 52. Except when the applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the staff will use the method described herein to evaluate conformance with Commission regulations.

The provisions of this SRP section apply to reviews of applications submitted six months or more after the date of issuance of this SRP section, unless superseded by a later revision.

VI. REFERENCES

(As this is the first SRP section of 6.2.1 being updated, references, in sequence, are provided here for completeness)

1. WCAP-7750, "SATAN-V, A Computer Space Time Dependent Analysis of Loss of Coolant."
2. BAW-10092, "CRAFT-2 Fortran Program for Digital Simulation of a Multinode Reactor Plant During a Loss-of-Coolant Accident," Babcock and Wilcox Company.
3. CENPD-133 Supplement 5-A, "CEFLASH-4A — A Fortran77 Digital Computer Program for Reactor Blowdown Analysis."
4. W. H. Retting, G. A. Jayne, K. Y. Moore, C. E. Slater, and M. L. Uptmor, "RELAP3 - A Computer Program for Reactor Slowdown Analysts," IN-1321, Idaho Nuclear Corporation.
5. F. C. Cadek, et al., "PWR FLECHT (Full Length Emergency Cooling Heat Transfer), Final Report," UCAP-7665, Westinghouse Electric Corporation.
6. BAW-10030, "CRAFT - Description of Model for Equilibrium LOCA Analysis Program," Babcock and Wilcox, Lynchburg, VA.
7. B&W-10164P, Revision 1, "RELAP5/MOD2-B&W - An Advanced Computer Program for Light Water Reactor LOCA and Non-LOCA Transient Analysis," Babcock and Wilcox.
8. BAW-10164P-A, Revision 4, "RELAP5-MOD2-B&W - An Advanced Computer Program for Light Water Reactor LOCA and Non-LOCA Transient Analysis."
9. Combustion Engineering letter DP-456, F. M. Stern to E. Case, Chapter 6, Appendix 6B to CESSAR System 80 PSAR.
10. "NRC Safety Evaluation Report - Standard Reference System, CESSAR System 80," Combustion Engineering Inc.
11. NEDO-10320, "The General Electric Pressure Suppression Containment Analytical Model," General Electric Company, April 1971; Supplement 1, May 1971; Supplement 2.
12. NEDO-20533, "The General Electric Mark III Pressure Suppression Containment System Analytical Model."
13. "SHEX Model Description," PDR ADOCK 050000321, 9807130260, 980706. (Proprietary, not available for public release).

14. NEDE-30911, "SHEX-04 User's Manual," Class II, General Electric Company, August 1985. And "SHEX-04V User's Manual (Addendum to SHEX-04 User's Manual)," NEDE-30911-1.
15. "Use of SHEX Computer Program and ANSI/ANS 5.1-1979 Decay Heat Source Term for Containment Long-Term Pressure and Temperature Analysis," NRC Letter from A. Thadani (NRC) to G. L. Sozzi (GE).
16. WCAP-8264-P-A, "Westinghouse Mass and Energy Release Data for Containment Design," Westinghouse Electric Corporation, (Proprietary, not available for public release), WCAP-8312-A (Non-Proprietary).
17. WCAP-10325-P-A "Westinghouse LOCA Mass and Energy Release Model For Containment Design - March 1979 Version," (Proprietary, not available for public release), WCAP-10326-A (Non-Proprietary).
18. WCAP-8302, "SATAN-VI Program: Comprehensive Space-Time Dependent Analysis of Loss-of-Coolant," (Proprietary, not available for public release), WCAP-8306 (Non-Proprietary).
19. WCAP-8170, "Calculational Model for Core Reflooding after a Loss-of-Coolant Accident (WREFLOOD Code)," (Proprietary, not available for public release), WCAP-8171 (Non-Proprietary).

PAPERWORK REDUCTION ACT STATEMENT

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.
