



DEC 14 2005

L-2005-253
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report – November 2005

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the November 2005 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

A handwritten signature in black ink that reads "Terry O. Jones" with a large, sweeping flourish at the end.

Terry O. Jones
Vice President
Turkey Point Plant

RLE

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-250
 UNIT: Turkey Point Unit 3
 DATE: 12/7/2005
 COMPLETED BY: Ronald Everett
 TELEPHONE: (305) 246-6190

Reporting Period November 2005

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	720	7766	217379.7
No. of hours generator was on line (service hours)	720	7671.2	214747
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	510989	5315035	140853700

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 was returned to 100% power November 2, 2005, after having restored the 240 kV switchyard. Unit 3 operated at essentially 100% power the remainder of the month of November.

DOCKET NO.: 50-251
 UNIT: Turkey Point Unit 4
 DATE: 12/7/2005
 COMPLETED BY: Ronald Everett
 TELEPHONE: (305) 246-6190

Reporting Period: November, 2005

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	453.2	5661.5	213802.7
No. of hours generator was on line (service hours)	433.2	5501.42	209142.72
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	285189	3699597	138300348

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20050048	11/01/2005	F	25.1	A	4	Unusual event declared due to loss of offsite power / loss of unit 4 startup transformer
20050048	11/02/2005	F	261.7	A	4	Condenser tube sheet plug leaks

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 was offline due to a loss of offsite power and startup transformer and condenser tube sheet plug leaks until November 12, 2005. Unit 4 was held at 30% power to adjust secondary chemistry. The unit was restored to 100% power November 14, 2005 and operated at essentially 100% power the remainder of November.