

**From:** Jerry Wilson  
**To:** Lindgren, Donald  
**Date:** Tue, Oct 18, 2005 2:01 PM  
**Subject:** Re: AP1000 Tier 1 information

Don: In the changes to Tier 1 information, Westinghouse proposed changes to Sections 1.1 and 1.4. Those changes are acceptable. As part of the changes to the Introduction to Tier 1, I also request that you make a minor clarification to the discussion in the 4th paragraph under "Implementation of ITAAC" (Section 1.2) so that it is consistent with the discussion under "Treatment of Individual Items."

Specifically:

"Many of the acceptance criteria include the words "A report exists and concludes that ...". When these words are used, it indicates that the ITAAC for that design commitment will be met when it is confirmed that appropriate documentation exists **and meets the design commitment**. Appropriate documentation can be a single document or a collection of documents that meet the stated acceptance criteria. Examples of appropriate documentation include design reports, test reports, inspection reports, analysis reports, evaluation reports, design and manufacturing procedures, certified data sheets, commercial dedication procedures and records, quality assurance records, calculation notes, and equipment qualification data packages."

The proposed change is in bold type

**CC:** Quinones, Lauren; Vijuk, Ron

**Mail Envelope Properties** (43553884.6BF : 9 : 736)

**Subject:** Re: AP1000 Tier 1 information  
**Creation Date:** Tue, Oct 18, 2005 2:01 PM  
**From:** Jerry Wilson

**Created By:** JNW@nrc.gov

**Recipients**

westinghouse.com  
vijukrp CC (Ron Vijuk)

nrc.gov  
owf4\_po.OWFN\_DO  
LNQ CC (Lauren Quinones)

westinghouse.com  
lindg1da (Lindgren, Donald)

**Post Office**

westinghouse.com  
owf4\_po.OWFN\_DO

**Route**

internet  
nrc.gov  
westinghouse.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1684	Tuesday, October 18, 2005 2:01 PM

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard