

**From:** "Lindgren, Donald A." <lindg1da@westinghouse.com>  
**To:** "jnw@nrc.gov" <jnw@nrc.gov>, "LNQ@nrc.gov" <LNQ@nrc.gov>  
**Date:** Tue, Oct 25, 2005 2:22 PM  
**Subject:** AP1000 Tier 1 Revisions

Based on our phone call of this morning, here is the suggested rewrite of the note for Table 2.3.2-2.

Special seismic requirements include only the portion of piping normally exposed to RCS pressure. Piping beyond the first normally closed isolation valve is evaluated as seismic Category II extending to an interface anchor or rigid support as necessary to satisfy analysis requirements for piping connected to seismic Category I piping systems.

I understand that we are not permitted to explicitly reference Tier 2 material from Tier 1. I have tried to use the words from the Tier 2 text to provide clarity for the requirements to which we are referring.

We propose to withdraw most of the changes in 2.2.2 and 2.3.7 that would replace the PCS tank volume criteria with a flowrate.

In Table 2.2.2-3, Item 7.f) return the inspection and volume criteria for the PCCWST that was proposed to be deleted.

In other words keep

Inspections, Tests, Analyses

ii) Inspection of the PCCWST will be performed.

And

Acceptance Criteria

ii) The volume of the PCCWST is greater than 756,700 gallons

In Table 2.3.7-4 Item 7.b) the Acceptance Criteria v) should read as follows:

See Tier 1 Material Table 2.2.2-3, item 7.f) acceptance criteria for the volume of the passive containment cooling system water storage tank.

In Table 2.3.7-4 Item 7.b) the Inspections, Tests, Analyses vi) should read as follows:

See Tier 1 Material Table 2.2.2-3 Items 8.a., and 8.b. for inspection, testing, and acceptance criteria to verify that the passive containment cooling system ancillary water storage tank includes a sufficient volume of water.

In Table 2.3.7-4 Item 7.b) the Acceptance Criteria vi) should read as follows:

See Tier 1 Material Table 2.2.2-3 Items 8.a., and 8.b. for inspection, testing, and acceptance criteria for the volume of the passive containment cooling system ancillary water storage tank.

D. A. Lindgren

**CC:** "Cummins, Ed" <cumminwe@westinghouse.com>, "Winters, James W." <winterjw@westinghouse.com>, "Vijuk, Ronald P." <vijukrp@westinghouse.com>, "Conway, Lawrence E." <conwayle@westinghouse.com>, "Meneely, Timothy K." <meneeltk@westinghouse.com>

**Mail Envelope Properties** (435E77B6.6A9 : 4 : 13993)

**Subject:** AP1000 Tier 1 Revisions  
**Creation Date:** Tue, Oct 25, 2005 2:21 PM  
**From:** "Lindgren, Donald A." <lindg1da@westinghouse.com>

**Created By:** lindg1da@westinghouse.com

**Recipients**

nrc.gov

owf4\_po.OWFN\_DO  
JNW (Jerry Wilson)  
LNQ (Lauren Quinones)

westinghouse.com

meneelk CC (Timothy K. Meneely)  
conwayle CC (Lawrence E. Conway)  
vijukrp CC (Ronald P. Vijuk)  
winterjw CC (James W. Winters)  
cumminwe CC (Ed Cummins)

**Post Office**

owf4\_po.OWFN\_DO

**Route**

nrc.gov  
westinghouse.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1928	Tuesday, October 25, 2005 2:21 PM
Mime.822	3168	

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard