

December 15, 2005

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop P1-137
Washington, DC 20555-0001

Ladies and Gentlemen:

ULNRC-05236
10 CFR 50.55a

**DOCKET NUMBER 50-483
UNION ELECTRIC COMPANY
CALLAWAY PLANT
WITHDRAWAL OF 10 CFR 50.55a(a)(3) REQUEST FOR RELIEF FROM
ASME OM CODE PUMP TESTING REQUIREMENTS
FOR RESIDUAL HEAT REMOVAL PUMPS**



By letter ULNRC-05184, dated August 9, 2005, Union Electric Company (AmerenUE) requested NRC approval of four relief requests submitted pursuant to 10 CFR 50.55a(a)(3) for Callaway's Inservice Test Program, as applicable to the third 10-year inservice testing interval for Callaway.

Of the four relief requests submitted, the one identified as PR-04 concerned conformance to testing requirements/provisions of ISTB-1400(b). Specifically, the requested relief was to allow Callaway's Residual Heat Removal pumps to be tested as standby (Group B) pumps for when the plant is in Mode 1, 2, 3, or 4, and as routinely operated (Group A) pumps for when the plant is in Mode 5 or 6. Although supporting information and justification was provided in the request, upon further consideration of the matter, AmerenUE has determined that the relief request should be withdrawn. Therefore, by this letter, AmerenUE respectfully requests withdrawal of the relief request identified as PR-04. This request does not affect the other Relief Requests (PR-01, PR-02 and PR-03) submitted via the August 9, 2005 letter.

Please contact me at 573-676-8659 or Dave Shafer at 314-554-3104 for any questions you may regarding this matter.

Sincerely,

A handwritten signature in black ink that reads "Keith D. Young".

Keith D. Young
Manager - Regulatory Affairs

TBE/jdg

A 047

ULNRC-05236
December 15, 2005
Page 2

cc: U.S. Nuclear Regulatory Commission (Original and 1 copy)
Attn: Document Control Desk
Mail Stop P1-137
Washington, DC 20555-0001

Mr. Bruce S. Mallett
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Mr. Jack N. Donohew (2 copies)
Licensing Project Manager, Callaway Plant
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop 7E1
Washington, DC 20555-2738

Missouri Public Service Commission
Governor Office Building
200 Madison Street
PO Box 360
Jefferson City, MO 65102-0360