



RONALD A JONES
Vice President
Oconee Nuclear Site

Duke Power
ON01VP / 7800 Rochester Hwy.
Seneca, SC 29672

864 885 3158
864 885 3564 fax

December 21, 2005

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Subject: Duke Energy Corporation
Oconee Nuclear Station, Unit 2
Docket No. 50-270
Steam Generator Inservice Inspection 2EOC21
Steam Generator Tube Plugging and Repair 30-day Report

The Oconee Nuclear Station Technical Specification (TS) 5.5.10 establishes the Steam Generator (SG) tube surveillance program requirements for SGs. TS 5.6.8, a, requires reporting of the number of SG tubes requiring plugging or repairs.

Both of the original Oconee Unit 2 SGs were replaced with new SGs in 2EOC20 (2004).

The tables below identify the number of tubes removed from service during 2EOC21.

<u>Steam Generator</u>	<u>No. of Tubes Repaired</u>	<u>Reason/Repair Method</u>
A	2	Investigation of Tube Wear, Tubes Pulled and Tubesheets Plugged.
B	3	Eddy Current Wear Indications Tubes Plugged and Stabilized.

Please address any questions to Randall P. Todd at (864) 885-3418.

Very Truly Yours,

R. A. Jones,
Site Vice President,
Oconee Nuclear Station

A047

US Nuclear Regulatory Commission
December 21, 2005

Page 2

cc: Mr. William D. Travers
Administrator, Region II
U.S. Nuclear Regulatory Commission
61 Forsyth Street, S. W., Suite 23T85
Atlanta, GA 30303

Mr. L. N. Olshan
Project Manager
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

Mr. M. C. Shannon
NRC Senior Resident Inspector
Oconee Nuclear Station