

EMERGENCY CORE COOLING SYSTEMS

TRISODIUM PHOSPHATE (TSP)

LIMITING CONDITION FOR OPERATION

3.5.5 The TSP baskets shall contain $\geq 282 \text{ ft}^3$ of active TSP.

APPLICABILITY: MODES 1, 2, and 3

ACTION:

With the quantity of TSP less than required, restore the TSP quantity within 72 hours, or be in MODE 3 within the next 6 hours and MODE 4 within the following 6 hours. |

SURVEILLANCE REQUIREMENTS

4.5.5.1 Verify that the TSP baskets contain $\geq 282 \text{ ft}^3$ of TSP at least once per 18 months. |

4.5.5.2 Verify that a sample from the TSP baskets provides adequate pH adjustment of borated water at least once per 18 months.