



Christopher B. Burke Engineering, Ltd.

National City Center, Suite 1368 South
115 West Washington Street
Indianapolis, IN 46204
(317) 266-8000
(317) 632-3306 (FAX)
Email: cbbel@cbbel-in.com
Internet: www.cbbel-in.com

FACSIMILE TRANSMISSION NOTICE

TO: COLLEEN CAROL CASEY

FAX NUMBER: 630-829-9782

CBBEL PROJECT NO:

NO. OF PAGES: # 3
WITH COVER SHEET

HARD COPY SENT: YES _____ NO X UPON REQUEST _____

IMPORTANT: THIS MESSAGE IS INTENDED ONLY FOR THE USE OF THE INDIVIDUAL OR ENTITY TO WHICH IT IS ADDRESSED AND MAY CONTAIN INFORMATION THAT IS PRIVILEGED AND CONFIDENTIAL. IF THE READER OF THIS MESSAGE IS NOT THE INTENDED RECIPIENT, OR THE EMPLOYEE OR AGENT RESPONSIBLE FOR DELIVERING THE MESSAGE TO THE INTENDED RECIPIENT, YOU ARE HEREBY NOTIFIED THAT ANY DISSEMINATION, DISTRIBUTION OR COPYING OF THIS COMMUNICATION IS STRICTLY PROHIBITED. IF YOU HAVE RECEIVED THIS COMMUNICATION IN ERROR, PLEASE NOTIFY US IMMEDIATELY BY TELEPHONE, AND RETURN THE ORIGINAL MESSAGE TO US AT THE ABOVE ADDRESS VIA THE UNITED STATES POSTAL SERVICE. THANK YOU!

IF YOU DO NOT RECEIVE THE SPECIFIED NUMBER OF PAGES, PLEASE CONTACT US IMMEDIATELY

DATE: 12-15-05 BY: KEN BOSAR

NOTES:

COLLEEN:

HERE ARE THE LEAK TEST CERTIFICATES FOR BEFORE AND AFTER OUR LEASE OF THE GUAGE. We HAD the machine for 10 months (I thought it was about 6). We only used it about 6 mos. the tests indicate that there were NO leaks of radioactivity. Sorry about all the difficulty.

KSO



Troxler Electronic Laboratories, Inc.

3008 Cornwallis Rd., P.O. Box 12057
Research Triangle Park, NC 27709
Tel: (877) 876-9537 Fax: (919) 485-2250

License: NC 032-0182-1

LEAK TEST CERTIFICATE

DEVICE:

Model: 3440 Serial No: 31523

SEALED SOURCES:

SERIAL NO.	MEASURE DATE	NUCLIDE	ACTIVITY	
			(GBq)	(mCi)
750-6311	02/03/2000	CS-137	0.296	8
47-28171	12/01/1988	AM-241:BE	1.48	40

LEAK TEST ANALYSIS:

Sample collected on:

Sample analyzed on: 10/02/2002 at 1:45:52 PM

Analyzed by:

	ALPHA	BETA-GAMMA
Conversion factor (cpm/Bq)	1.30E+01	2.09E+01
Background measurement (cpm)	0	25
Sample measurement (cpm)	0	28
Activity (Bq)	< MDA	< MDA
Min. Detectable Activity (Bq)	2.1E-01	1.2E+00

This certifies that the above leak test results are:

- Less than 185 Bq (0.005 uCi) Greater than 185 Bq (0.005 uCi)

If greater than 185 Bq (0.005 uCi):

Person Notified _____ Date _____

Phone _____ and/or Fax _____



Troxler Electronic Laboratories, Inc.

3008 Cornwallis Rd., P.O. Box 12057
Research Triangle Park, NC 27709
Tel: (877) 876-9537 Fax: (919) 485-2250

License: NC 032-0182-1

LEAK TEST CERTIFICATE

DEVICE:

Model: 3440 Serial No: 31523

SEALED SOURCES:

SERIAL NO.	MEASURE DATE	NUCLIDE	ACTIVITY	
			(Bq)	(mCi)
750-8311	02/03/2000	CS-137	0.296	8
47-28171	12/01/1998	AM-241:BE	1.48	40

LEAK TEST ANALYSIS:

Sample collected on:

Sample analyzed on: 08/11/2003 at 10:47:52 AM

Analyzed by:

	ALPHA	BETA-GAMMA
Conversion factor (cpm/Bq)	1.27E+01	2.00E+01
Background measurement (cpm)	0	23
Sample measurement (cpm)	2	18
Activity (Bq)	< MDA	< MDA
Min. Detectable Activity (Bq)	2.1E-01	1.3E+00

This certifies that the above leak test results are:

Less than 185 Bq (0.005 uCi)

Greater than 185 Bq (0.005 uCi)

If greater than 185 Bq (0.005 uCi):

Person Notified _____ Date _____

Phone _____ and/or Fax _____



Christopher B. Burke Engineering, Ltd.

National City Center, Suite 1368 South

115 West Washington Street

Indianapolis, IN 46204

(317) 266-8000

(317) 632-3306 (FAX)

Email: cbbel@cbbel-in.com

Internet: www.cbbel-in.com

FACSIMILE TRANSMISSION NOTICE

TO: Colleen Casey

FAX NO: 630-829-9782

CBBEL PROJECT NO: Jk

NO. PAGES (INCLUDING THIS COVER SHEET):

3 PAGES

HARD COPY TO BE SENT?

YES NO per request of C.C.

IMPORTANT: THIS MESSAGE IS INTENDED ONLY FOR THE USE OF THE INDIVIDUAL OR ENTITY TO WHICH IT IS ADDRESSED AND MAY CONTAIN INFORMATION THAT IS PRIVILEGED AND CONFIDENTIAL. IF THE READER OF THIS MESSAGE IS NOT THE INTENDED RECIPIENT, OR THE EMPLOYEE OR AGENT RESPONSIBLE FOR DELIVERING THE MESSAGE TO THE INTENDED RECIPIENT, YOU ARE HEREBY NOTIFIED THAT ANY DISSEMINATION, DISTRIBUTION OR COPYING OF THIS COMMUNICATION IS STRICTLY PROHIBITED. IF YOU HAVE RECEIVED THIS COMMUNICATION IN ERROR, PLEASE NOTIFY US IMMEDIATELY BY TELEPHONE, AND RETURN THE ORIGINAL MESSAGE TO US AT THE ABOVE ADDRESS VIA THE UNITED STATES POSTAL SERVICE. THANK YOU!

IF YOU DO NOT RECEIVE THE SPECIFIED NUMBER OF PAGES, PLEASE CONTACT US IMMEDIATELY

DATE: 10-17-05

BY: Mandy W. for
Ken Bosal



CHRISTOPHER B. BURKE ENGINEERING, LTD.

National City Center Suite 1368 South 115 West Washington Street Indianapolis, Indiana 46204 TEL (317) 266-8000 FAX (317) 632-3306

October 17, 2005

United States Nuclear Regulatory Commission
2443 Warrenville Road, Suite 210
Lisle, IL 60532-4352

Attention: Ms. Colleen Casey

Subject: Acknowledgement of Disposal of Nuclear Gauge
Control No. 314866
Christopher B. Burke Engineering, Ltd.

Dear Ms. Casey:

As you requested, I have attached a copy of acknowledgement of proper disposal of the nuclear gauge we leased from Troxler Electronics. We have not leased another gauge since August, 2003. We have never owned a gauge.

If any more information is needed regarding this matter, please feel free to contact me at (317) 266-8000. Thank you for your assistance.

Sincerely,

A handwritten signature in black ink, appearing to read 'Ken Bosar', written over a horizontal line.

Ken Bosar, P.E.
Head, Design Department



Troxler Electronic Laboratories, Inc.

3008 Cornwallis Rd., P.O. Box 12057
Research Triangle Park, NC 27709
Tel: (877) 876-9537 Fax: (919) 485-2250

10/17/2005

Christopher B. Burke EN
115 W. Washington Street
Indianapolis, IN 45204

Attention: Dave Walker

This is a letter of notification to confirm receipt and acknowledgement of proper disposal of the below referenced nuclear gauge(s) under the North Carolina Radioactive Materials License #032-0182-1. You should retain this letter for your records to document transfer of this gauge.

Received Date: 8/8/2003

Repair Order	Model Number:	Serial Number:
75165	3440	31523

Thank you,
Terri Pjura
Service/Repair Department
Troloxer Electronic Laboratories, Inc.

REF: CONFIRMATION
CONTROL # 314866