



Scott A. Bauer  
Department Leader  
Regulatory Affairs  
Palo Verde Nuclear  
Generating Station

**Technical Specification 5.6.5.d**

Tel: 623/393-5978  
Fax: 623/393-5442  
e-mail: sbauer@apsc.com

Mail Station 7636  
P.O. Box 52034  
Phoenix, AZ 85072-2034

102-05392-SAB/TNW/GAM  
December 27, 2005

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)  
Unit 1  
Docket No. STN 50-528  
Unit 1 Core Operating Limits Report (COLR), Revision 16**

Pursuant to PVNGS Technical Specifications, Section 5.6.5.d, enclosed is Unit 1 Core Operating Limits Report (COLR), Revision 16, which was made effective on December 14, 2005. This COLR revision incorporated editorial changes.

By copy of this letter and the enclosure, this COLR revision is being provided to the NRC Region IV Administrator and the PVNGS Senior Resident Inspector.

This letter does not make any commitments to the NRC. Please contact Thomas N. Weber at (623) 393-5764 if you have any questions or require additional information.

Sincerely,

SAB/TNW/GAM/ca

Enclosure: PVNGS Unit 1 Core Operating Limits Report (COLR), Revision 16

cc: B. S. Mallett NRC Region IV Regional Administrator  
M. B. Fields NRC NRR Project Manager  
G. G. Warnick NRC Senior Resident Inspector for PVNGS

A001

**Enclosure**

**PVNGS Unit 1 Core Operating Limits Report (COLR)  
Revision 16**

# PALO VERDE NUCLEAR GENERATING STATION (PVNGS)

## UNIT 1

### CORE OPERATING LIMITS REPORT

#### Revision 16

Responsible Engineer Date	Digitally signed by: Petro, Nicole M (ZC3341) Date: 12/07/2005 15:21:38 Reason: I am the author of this document Location: PVNGS
Independent Reviewer Date	Digitally signed by: Delorenzi, Mark J (Z01931) Date: 12/07/2005 15:45:4 Reason: I have reviewed this document Location: PVNGS
Responsible Section Leader Date	Digitally signed by: Cannon, Thomas C (Z20485) Date: 12/07/2005 16:18:39 Reason: I am approving this document Location: PVNGS

**List of Figures**

<u>Description</u>	<u>Page</u>
Figure 3.1.1-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Open	11
Figure 3.1.2-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Closed	12
Figure 3.1.4-1 MTC Acceptable Operation, Modes 1 and 2	13
Figure 3.1.5-1 Core Power Limit After CEA Deviation	14
Figure 3.1.7-1 CEA Insertion Limits Versus Thermal Power (COLSS in Service)	15
Figure 3.1.7-2 CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)	16
Figure 3.1.8-1 Part Strength CEA Insertion Limits Versus Thermal Power	17
Figure 3.2.3-1 Azimuthal Power Tilt Versus Thermal Power (COLSS in Service)	18
Figure 3.2.4-1 COLSS DNBR Operating Limit Allowance for Both CEACs Inoperable In Any Operable CPC Channel	19
Figure 3.2.4-2 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEAC(s) Operable)	20
Figure 3.2.4-3 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, Both CEACs Inoperable In Any Operable CPC Channel)	21

**List of Tables**

<u>Description</u>	<u>Page</u>
Table 3.3.12-1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} > 0.98$	22
Table 3.3.12-2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{eff} > 0.97$	23
Table 3.3.12-3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{eff} > 0.96$	24
Table 3.3.12-4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{eff} > 0.95$	25
Table 3.3.12-5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} \leq 0.95$	26

This Report has been prepared in accordance with the requirements of Technical Specification 5.6.5. The Core Operating Limits have been developed using the NRC approved methodologies specified in Section 5.6.5 b of the Palo Verde Unit 1 Technical Specifications.

**AFFECTED PVNGS TECHNICAL SPECIFICATIONS**

- 3.1.1 Shutdown Margin (SDM) - Reactor Trip Breakers Open
- 3.1.2 Shutdown Margin (SDM) - Reactor Trip Breakers Closed
- 3.1.4 Moderator Temperature Coefficient (MTC)
- 3.1.5 Control Element Assembly (CEA) Alignment
- 3.1.7 Regulating CEA Insertion Limits
- 3.1.8 Part Strength CEA Insertion Limits
- 3.2.1 Linear Heat Rate (LHR)
- 3.2.3 Azimuthal Power Tilt ( $T_q$ )
- 3.2.4 Departure From Nucleate Boiling Ratio (DNBR)
- 3.2.5 Axial Shape Index (ASI)
- 3.3.12 Boron Dilution Alarm System (BDAS)
- 3.9.1 Boron Concentration

**ANALYTICAL METHODS**

The COLR contains the complete identification for each of the Technical Specification referenced topical reports (i.e., report number, title, revision, date, and any supplements) that provide the NRC-approved analytical methods used to determine the core operating limits, described in the following documents:

<u>Title</u>	<u>Report No.</u>	<u>Rev</u>	<u>Date</u>	<u>Supplement</u>
1) CE Method for Control Element Assembly Ejection Analysis (13-N001-1301-01204-1)	CENPD-0190-A	N.A.	January 1976	N.A.
2) The ROCS and DIT Computer Codes for Nuclear Design (13-N001-1900-01412-0)	CENPD-266-P-A	N.A.	April 1983	N.A.
3) Modified Statistical Combination of Uncertainties (13-N001-1303-01747-2)	CEN-356(V)-P-A	01-P-A (AR1)	May 1988 (April 1996)	N.A.
4) System 80 <sup>TM</sup> Inlet Flow Distribution (13-N001-1301-01228-0)	Enclosure 1-P to LD- 82-054	N.A.	February 1993	1-P
5) Calculative Methods for the CE Large Break LOCA Evaluation Model for the Analysis of CE and W Designed NSSS (13-N001-1900-01192-3)	CENPD-132	N.A.	March 2001	4-P-A
6) Calculative Methods for the CE Small Break LOCA Evaluation Model (13-N001-1900-01185-3)	CENPD-137-P	N.A.	April 1998	2-P-A
7) Fuel Rod Maximum Allowable Pressure (13-N001-0201-00026-1)	CEN-372-P-A	N.A.	May 1990	N.A.
8) Arizona Public Service Company PWR Reactor Physics Methodology Using CASMO-4/SIMULATE-3 (NFM-002)	N.A.	N.A.	September 1999	N.A.
9) Technical Description Manual for the CENTS Code (13-N001-1303-02349-2 for Vol. 1-4)	CE-NPD 282-P-A Vols. 1-4	1	April 2004	N.A.

<u>Title</u>	<u>Report No.</u>	<u>Rev</u>	<u>Date</u>	<u>Supplement</u>
10) Implementation of ZIRLO™ Cladding Material in CE Nuclear Power Fuel Assembly Designs (13-N001-1900-01329-0)	CENPD-404-P-A	0	November 2001	N.A.



The cycle-specific operating limits for the specifications listed are presented below.

3.1.1 - Shutdown Margin (SDM) - Reactor Trip Breakers Open

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.1-1.

3.1.2 - Shutdown Margin (SDM) - Reactor Trip Breakers Closed

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.2-1.

3.1.4 - Moderator Temperature Coefficient (MTC)

The moderator temperature coefficient (MTC) shall be within the area of Acceptable Operation shown in Figure 3.1.4-1.

3.1.5 - Control Element Assembly (CEA) Alignment

With one or more full-strength or part-strength CEAs misaligned from any other CEAs in its group by more than 6.6 inches, the minimum required MODES 1 and 2 core power reduction is specified in Figure 3.1.5-1.

3.1.7 - Regulating CEA Insertion Limits

With COLSS IN SERVICE, regulating CEA groups shall be limited to the withdrawal sequence and to the insertion limits<sup>1</sup> shown in Figure 3.1.7-1<sup>2</sup>; with COLSS OUT OF SERVICE, regulating CEA groups shall be limited to the withdrawal sequence and to the insertion limits<sup>1</sup> shown in Figure 3.1.7-2<sup>2</sup>. Regulating Groups 1 and 2 CEAs shall be maintained fully withdrawn<sup>3</sup> while in Modes 1 and 2 (except while performing SR 3.1.5.3).

<sup>1</sup> A reactor power cutback will cause either (Case 1) Regulating Group 5 or Regulating Group 4 and 5 to be dropped with no sequential insertion of additional Regulating Groups (Groups 1, 2, 3, and 4) or (Case 2) Regulating Group 5 or Regulating Group 4 and 5 to be dropped with all or part of the remaining Regulating Groups (Groups 1, 2, 3, and 4) being sequentially inserted. In either case, the Transient Insertion Limit and withdrawal sequence specified in the CORE OPERATING LIMITS REPORT can be exceeded for up to 2 hours.

<sup>2</sup> The Separation between Regulating Groups 4 and 5 may be reduced from the 90 inch value specified in Figures 3.1.7-1 and 3.1.7-2 provided that each of the following conditions are satisfied:

- a) Regulating Group 4 position is between 60 and 150 inches withdrawn.
- b) Regulating Group 5 position is maintained at least 10 inches lower than Regulating Group 4 position.

c) Both Regulating Group 4 and Regulating Group 5 positions are maintained above the Transient Insertion Limit specified in Figure 3.1.7-1 (COLSS In Service) or Figure 3.1.7-2 (COLSS Out of Service).

<sup>3</sup> Fully withdrawn -  $\geq 147.75''$  (Pulse Counter indication) and  $\geq 145.25''$  (RSPT indication)

**3.1.8 - Part Strength CEA Insertion Limits**

The part strength CEA groups shall be limited to the insertion limits shown in Figure 3.1.8-1.

**3.2.1 - Linear Heat Rate (LHR)**

The linear heat rate limit of 13.1 kW/ft shall be maintained.

**3.2.3 - Azimuthal Power Tilt ( $T_q$ )**

The AZIMUTHAL POWER TILT ( $T_q$ ) shall be less than or equal to 10% with COLSS IN SERVICE when power is greater than 20% and less than or equal to 50%. Additionally, the AZIMUTHAL POWER TILT ( $T_q$ ) shall be less than or equal to 5% with COLSS IN SERVICE when power is greater than 50%. See Figure 3.2.3-1.

**3.2.4 - Departure From Nucleate Boiling Ratio (DNBR)**

**COLSS IN SERVICE and Both CEACs INOPERABLE in Any OPERABLE CPC Channel - Maintain COLSS calculated core power less than or equal to COLSS calculated core power operation limit based on DNBR decreased by the allowance shown in Figure 3.2.4-1.**

**COLSS OUT OF SERVICE and CEAC(s) OPERABLE - Operate within the region of acceptable operation of Figure 3.2.4-2 using any operable CPC channel.**

**COLSS OUT OF SERVICE and Both CEACs INOPERABLE in Any OPERABLE CPC Channel - Operate within the region of acceptable operation of Figure 3.2.4-3 using any operable CPC channel with both CEACs**

**INOPERABLE.**

### 3.2.5 - Axial Shape Index (ASI)

The core average AXIAL SHAPE INDEX (ASI) shall be maintained within the following limits:

#### COLSS OPERABLE

$-0.18 \leq \text{ASI} \leq 0.18$  for power  $\geq 50\%$

$-0.28 \leq \text{ASI} \leq 0.18$  for power  $>20\%$  and  $< 50\%$

#### COLSS OUT OF SERVICE (CPC)

$-0.10 \leq \text{ASI} \leq 0.10$  for power  $>20\%$

### 3.3.12 - Boron Dilution Alarm System (BDAS)

With one or both start-up channel high neutron flux alarms inoperable, the RCS boron concentration shall be determined at the applicable monitoring frequency specified in Tables 3.3.12-1 through 3.3.12-5.

### 3.9.1 - Boron Concentration

The boron concentration of all filled portions of the Reactor Coolant System and the refueling canal shall be maintained at a uniform concentration  $\geq 3000$  ppm.

**FIGURE 3.1.1-1**  
**SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE**  
**REACTOR TRIP BREAKERS OPEN**




FIGURE 3.1.2-1  
 SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE  
 REACTOR TRIP BREAKERS CLOSED




FIGURE 3.1.4-1

MTC ACCEPTABLE OPERATION, MODES 1 AND 2






FIGURE 3.1.5-1  
CORE POWER LIMIT AFTER CEA DEVIATION\*



\* WHEN CORE POWER IS REDUCED TO 55% OF RATED THERMAL POWER PER THIS LIMIT CURVE, FURTHER REDUCTION IS NOT REQUIRED.


FIGURE 3.1.7-1  
 CEA INSERTION LIMITS VERSUS THERMAL POWER  
 (COLSS IN SERVICE)



\*Fully Withdrawn (FW) is defined as  $\geq 147.75''$  (Pulse Counter) and  $\geq 145.25''$  (RSPT).



FIGURE 3.1.7-2  
CEA INSERTION LIMITS VERSUS THERMAL POWER  
(COLSS OUT OF SERVICE)



\*Fully Withdrawn (FW) is defined as  $\geq 147.75''$  (Pulse Counter) and  $\geq 145.25''$  (RSPT).

FIGURE 3.1.8-1  
 PART STRENGTH CEA INSERTION LIMITS  
 VERSUS THERMAL POWER




FIGURE 3.2.3-1  
 AZIMUTHAL POWER TILT VERSUS THERMAL POWER  
 (COLSS IN SERVICE)




FIGURE 3.2.4-1  
 COLSS DNBR OPERATING LIMIT  
 ALLOWANCE FOR BOTH CEACs INOPERABLE  
 IN ANY OPERABLE CPC CHANNEL




FIGURE 3.2.4-2  
 DNBR MARGIN OPERATING LIMIT BASED ON  
 THE CORE PROTECTION CALCULATORS  
 (COLSS OUT OF SERVICE, CEAC(s) OPERABLE)




FIGURE 3.2.4-3  
 DNBR MARGIN OPERATING LIMIT BASED ON  
 THE CORE PROTECTION CALCULATORS  
 (COLSS OUT OF SERVICE, BOTH CEACs INOPERABLE  
 IN ANY OPERABLE CPC CHANNEL)




Table 3.3.12-1

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON  
DILUTION DETECTION AS A FUNCTION OF OPERATING  
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR  $K_{eff} > 0.98$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	0.5 hours	ONA	ONA
4 not on SCS	12 hours	0.5 hours	ONA	ONA
5 not on SCS	8 hours	0.5 hours	ONA	ONA
4 & 5 on SCS	ONA	ONA	ONA	ONA

Notes: SCS = Shutdown Cooling System  
ONA = Operation Not Allowed

Table 3.3.12-2

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON  
DILUTION DETECTION AS A FUNCTION OF OPERATING  
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR  $0.98 \geq K_{eff} > 0.97$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	1 hour	0.5 hours	ONA
4 not on SCS	12 hours	1.5 hours	0.5 hours	ONA
5 not on SCS	8 hours	1.5 hours	0.5 hours	ONA
4 & 5 on SCS	8 hours	0.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System  
ONA = Operation Not Allowed



Table 3.3.12-3

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON  
DILUTION DETECTION AS A FUNCTION OF OPERATING  
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR  $0.97 \geq K_{eff} > 0.96$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	2.5 hours	1 hour	ONA
4 not on SCS	12 hours	2.5 hours	1 hour	0.5 hours
5 not on SCS	8 hours	2.5 hours	1 hour	0.5 hours
4 & 5 on SCS	8 hours	1 hour	ONA	ONA

Notes: SCS = Shutdown Cooling System  
ONA = Operation Not Allowed

Table 3.3.12-4

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON  
 DILUTION DETECTION AS A FUNCTION OF OPERATING  
 CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR  $0.96 \geq K_{eff} > 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	3 hours	1 hour	0.5 hours
4 not on SCS	12 hours	3.5 hours	1.5 hours	0.75 hours
5 not on SCS	8 hours	3.5 hours	1.5 hours	0.75 hours
4 & 5 on SCS	8 hours	1.5 hours	0.5 hours	ONA

Notes: SCS = Shutdown Cooling System  
 ONA = Operation Not Allowed

Table 3.3.12-5

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON  
DILUTION DETECTION AS A FUNCTION OF OPERATING  
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR  $K_{eff} \leq 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	4 hours	1.5 hours	1 hour
4 not on SCS	12 hours	4.5 hours	2 hours	1 hour
5 not on SCS	8 hours	4.5 hours	2 hours	1 hour
4 & 5 on SCS	8 hours	2 hours	0.75 hours	ONA
6	24 hours	1.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System  
ONA = Operation Not Allowed