

---

**CONTAINMENT SYSTEMS**

**PRIMARY CONTAINMENT**

**CONTAINMENT AIR-LOCKS**

**SURVEILLANCE REQUIREMENTS**

---

**4.6.1.3 Each containment air lock shall be demonstrated OPERABLE:**

- a. With the leakage rate in accordance with the Containment Leakage Rate Testing Program.
- b. At least once per 24 months by verifying that only one door in each air lock can be opened at a time. |