

January 11, 2006

Mr. David Hinds, Manager, ESBWR  
General Electric Company  
P.O. Box 780, M/C L60  
Wilmington, NC 28402-0780

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 5 FOR THE  
ESBWR DESIGN CERTIFICATION APPLICATION

Dear Mr. Hinds:

By letter dated August 24, 2005, General Electric Company (GE) submitted an application for final design approval and standard design certification of the economic simplified boiling water reactor (ESBWR) standard plant design. The Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application. The NRC staff has determined that additional information is needed to continue portions of the review.

Enclosure 1 contains a request for additional information (RAI) regarding ESBWR design information needed for TRACE model analyses. This RAI was sent to you via electronic mail on December 6, and December 15, 2005. This RAI was discussed with you on December 15, 2005. On December 19, 2005, you agreed to provide a response to the requested information within thirty days.

If you have any questions or comments concerning this matter, you may contact me at (301) 415-2863 or [lwr@nrc.gov](mailto:lwr@nrc.gov) or you may contact Amy Cubbage at (301) 415-2875 or [aec@nrc.gov](mailto:aec@nrc.gov).

Sincerely,

*/RA/*

Lawrence Rossbach, Project Manager  
New Reactor Licensing Branch  
Division of New Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 52-010

Enclosure: As stated

cc: See next page

Mr. David Hinds, Manager, ESBWR  
General Electric Company  
P.O. Box 780, M/C L60  
Wilmington, NC 28402-0780

January 11, 2006

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 5 FOR THE  
ESBWR DESIGN CERTIFICATION APPLICATION

Dear Mr. Hinds:

By letter dated August 24, 2005, General Electric Company (GE) submitted an application for final design approval and standard design certification of the economic simplified boiling water reactor (ESBWR) standard plant design. The Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application. The NRC staff has determined that additional information is needed to continue portions of the review.

Enclosure 1 contains a request for additional information (RAI) regarding ESBWR design information needed for TRACE model analyses. This RAI was sent to you via electronic mail on December 6, and December 15, 2005. This RAI was discussed with you on December 15, 2005. On December 19, 2005, you agreed to provide a response to the requested information within thirty days.

If you have any questions or comments concerning this matter, you may contact me at (301) 415-2863 or [lwr@nrc.gov](mailto:lwr@nrc.gov) or you may contact Amy Cubbage at (301) 415-2875 or [aec@nrc.gov](mailto:aec@nrc.gov).

Sincerely,

*/RA/*

Lawrence Rossbach, Project Manager  
New Reactor Licensing Branch  
Division of New Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 52-010

Enclosure: As stated

cc: See next page

ACCESSION NO. ML060090494

OFFICE	NRBA/PM	SNPB/BC	NRBA/BC
NAME	LRossbach	FAkstulewicz	LDudes
DATE	01/10/06	01/10/06	01/11/06

**OFFICIAL RECORD COPY**

Distribution for DCD RAI Letter No. 5 dated January 11, 2006

Hard Copy

PUBLIC

NRBA R/F

ACubbage

LRossbach

E-Mail

LDudes

FAkstulewicz

VKlein

RLandry

ACRS

OGC

JDanna

JHan

ACubbage

LRossbach

LQuinones

JWilliams

## ESBWR Design Certification Request for Additional Information (RAI) for TRACE

RAI Number	Reviewer	RAI Summary
6.3-2	Klein V.	Provide design information for the PCCS, ICS, GDCS, SRVs and DPVs. Verify L1 and L2 positions.

### Full Text of RAI:

The staff requires design information in order to perform confirmatory analyses using the TRACE model. Please provide the following information for the Passive Containment Cooling System (PCCS), Isolation Condenser System (ICS), Gravity-Driven Cooling System (GDCS), Safety Relief Valves (SRVs) and Depressurization Valves (DPVs). Also, verify or correct the values of the Level 1 (L1) and Level 2 (L2) positions:

#### PCCS Design Information:

1. Number of PCCS condensation tubes for a single unit.
2. Diameter of PCCS condensation tubes.
3. Volume and flow area of Upper Plenum for the PCCS.
4. Volume and flow area of the Lower Plenum for the PCCS.
5. PCCS drain tank volume
6. PCCS tube length

#### ICS Design Information:

1. Number of ICS condensation tubes.
2. Diameter of ICS condensation tubes.
3. Elevation change between ICS lower plenum and RPV connection.

#### GDCS Design Information:

1. Flow area of the connection between the GDCS airspace and the drywell.

#### SRV and DPV Design Information:

1. SRV and DPV flow areas.
2. Specific sequence of ADS valve opening. [Table 6.3-1 in the DCD provided the ECCS-LOCA sequence, which includes the sequence of ADS valve opening. However, it doesn't explain which specific valves open on which steam lines, i.e. which 5 SRVs open at 0 sec, which 5 open at 10 sec, and which DPVs open at 50, 100, 150 and 200 sec? There is 1 DPV for each of the 4 steam lines and 4 DPVs connected directly to the RPV.]

#### L1 and L2 Design Information:

1. Verify or correct the value of L1. Table 6.3-1 lists the L1 position as 3.547 meters above TAF, where TAF is given in Table 5.3-3 as 7.453 m. This gives an L1 position of 11.0 m. However, Table 15.2-1 lists the L1 position as 10.0 m.
2. Verify or correct the value of L2. Table 15.2-1 lists the L2 position as 16.05 m.

Enclosure

ESBWR

cc:

Mr. David H. Hinds, Manager  
ESBWR  
P.O. Box 780, M/C L60  
Wilmington, NC 28402-0780

Mr. George B. Stramback  
Manager, Regulatory Services  
GE Nuclear Energy  
1989 Little Orchard Street, M/C 747  
San Jose, CA 95125

Mr. David Lochbaum, Nuclear Safety Engineer  
Union of Concerned Scientists  
1707 H Street, NW., Suite 600  
Washington, DC 20006-3919

Mr. Paul Gunter  
Nuclear Information & Resource Service  
1424 16th Street, NW, Suite 404  
Washington, DC 20036

Mr. James Riccio  
Greenpeace  
702 H Street, Suite 300  
Washington, DC 20001

Mr. Adrian Heymer  
Nuclear Energy Institute  
Suite 400  
1776 I Street, NW  
Washington, DC 20006-3708

Mr. Paul Leventhal  
Nuclear Control Institute  
1000 Connecticut Avenue, NW  
Suite 410  
Washington, DC 20036

Dr. Jack W. Roe  
Nuclear Energy Institute  
1776 I Street, NW  
Washington, DC 20006-3708

Mr. Ron Simard  
6170 Masters Club Drive  
Suwanne, GA 30024

Mr. Brendan Hoffman  
Research Associate on Nuclear Energy  
and Environmental Program  
215 Pennsylvania Avenue, SE  
Washington, DC 20003

Mr. Tom Clements  
6703 Gude Avenue  
Takoma Park, MD 20912

Ms. Patricia Campbell  
Morgan, Lewis & Bockius, LLP  
1111 Pennsylvania Avenue, NW  
Washington, DC 20004

Mr. Glenn H. Archinoff  
AECL Technologies  
481 North Frederick Avenue  
Suite 405  
Gaithersburg, MD. 20877

Mr. Gary Wright, Director  
Division of Nuclear Facility Safety  
Illinois Emergency Management Agency  
1035 Outer Park Drive  
Springfield, IL 62704

Mr. Charles Brinkman  
Westinghouse Electric Co.  
Washington Operations  
12300 Twinbrook Pkwy., Suite 330  
Rockville, MD 20852

Mr. Ronald P. Vijuk  
Manager of Passive Plant Engineering  
AP1000 Project  
Westinghouse Electric Company  
P. O. Box 355  
Pittsburgh, PA 15230-0355

Mr. Ed Wallace, General Manager  
Projects  
PBMR Pty LTD  
PO Box 9396  
Centurion 0046  
Republic of South Africa

Mr. Russell Bell  
Nuclear Energy Institute  
Suite 400  
1776 I Street, NW  
Washington, DC 20006-3708

Mr. Jerald S. Holm  
Framatome ANP, Inc.  
3315 Old Forest Road  
P.O. Box 10935  
Lynchburg, VA 24506-0935

Ms. Kathryn Sutton, Esq.  
Morgan, Lewis & Bockius, LLP  
1111 Pennsylvania Avenue, NW  
Washington, DC 20004

Mr. Robert E. Sweeney  
IBEX ESI  
4641 Montgomery Avenue  
Suite 350  
Bethesda, MD 20814

Mr. Eugene S. Grecheck  
Vice President, Nuclear Support Services  
Dominion Energy, Inc.  
5000 Dominion Blvd.  
Glen Allen, VA 23060

Mr. George A. Zinke  
Manager, Project Management  
Nuclear Business Development  
Entergy Nuclear, M-ECH-683  
1340 Echelon Parkway  
Jackson, MS 39213

E-Mail:

tom.miller@hq.doe.gov or  
tom.miller@nuclear.energy.gov  
mwetterhahn@winston.com  
whorin@winston.com  
gcesare@enercon.com  
jerald.holm@framatome-anp.com  
eddie.grant@exeloncorp.com  
joseph\_hegner@dom.com  
steven.hucik@ge.com  
david.hinds@ge.com  
chris.maslak@ge.com  
james1beard@ge.com  
louis.quintana@gene.ge.com  
wayne.massie@ge.com  
kathy.sedney@ge.com  
george.stramback@gene.ge.com