

# Missouri Department of Natural Resources



## PUBLIC NOTICE

### DRAFT MISSOURI STATE OPERATING PERMIT

DATE: January 6, 2006

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the Department of Natural Resources, St. Louis Regional Office, 7545 South Lindbergh, Suite 210, St. Louis, Missouri 63125, ATTN: Thomas M. Siegel, Chief, Permits and Engineering. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curdt v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by February 5, 2006 or received in our office by 5:00 p.m. on February 8, 2006. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at DNR's website, <http://www.dnr.mo.gov/wpscd/wpcp/wp-index.html>, or at the Department of Natural Resources, St. Louis Regional Office, 7545 S. Lindbergh, Suite 210, St. Louis, Missouri 63125, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.


Public Notice Date: January 6, 2005

Permit Number: MO-00000761

St. Louis Regional Office

FACILITY NAME AND ADDRESS	NAME AND ADDRESS OF OWNER
Westinghouse Electric Co. LLC 3300 State Road P Festus, MO 63028	Westinghouse Electric Co. LLC 3300 State Road P Festus, MO 63028
RECEIVING STREAM & LEGAL DESCRIPTION	TYPE OF DISCHARGE
Unnamed tributary to Joachim Creek U.S. Survey 423, SW ¼, Sec. 9 proj. T40N, R5E, Jefferson Co.	Domestic/industrial (reissue)

STATE OF MISSOURI  
DEPARTMENT OF NATURAL RESOURCES  
MISSOURI CLEAN WATER COMMISSION



## MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No. MO-0000761

Owner: Westinghouse Electric Co. LLC  
Address: 3300 State Road P, Festus, MO 63028

Continuing Authority: Same as above  
Address: Same as above

Facility Name: Westinghouse Electric Co. LLC  
Facility Address: 3300 State Road P, Festus, MO 63028

Legal Description: See page 2  
Latitude/Longitude: See page 2

Receiving Stream: Unnamed tributaries to Joachim Creek (U)  
First Classified Stream and ID: Joachim Creek (P) (ID # 1719)  
USGS Basin & Sub-watershed No.: (07140101-150004)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

### FACILITY DESCRIPTION

See page two for facility/outfall descriptions.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date

Doyle Childers, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

Expiration Date

Mohamad Alhalabi, P.E., Director, St. Louis Regional Office

## Facility and Outfall Descriptions

### Outfall 001 – Treated sanitary/domestic wastewater. SIC #4952

Facility is an extended aeration treatment system with effluent filtration and chlorination/dechlorination. Discharge is to unnamed creek on south side of site behind the dam.

Design population equivalent is 71.  
Design flow is 6,000 gallons/day.  
Actual flow is approx. 1,000 gallons/day.

Legal Description: SE ¼, SW ¼, Sec. 19, T40N, R5E, Jefferson County  
Latitude/Longitude: 38.20675 / -90.47714

### Outfall 002 – Storm water from pond on west side of site after passing over dam. SIC # 1795 (formerly 2819)

Actual flow is dependent upon precipitation.

Legal Description: SE ¼, SW ¼, Sec. 19, T40N, R5E, Jefferson County  
Latitude/Longitude: 38.20675 / -90.47714

### Outfall 003 – Storm water released into pond. SIC # 1795 (formerly 2819)

Actual flow is dependent upon precipitation.

Legal Description: NE ¼, SW ¼, Sec. 19, T40N, R5E, Jefferson County  
Latitude/Longitude: 38.20767 / -90.47717

### Outfall 004 – Storm water discharge from east side of site. SIC # 1795 (formerly 2819)

Actual flow is dependent upon precipitation.

Legal Description: NE ¼, SW ¼, Sec. 19, T40N, R5E, Jefferson County  
Latitude/Longitude: 38.20983 / -90.47439

### Outfall 005 - Storm water discharge from south side of site. SIC # 1795 (formerly 2819)

Actual flow is dependent upon precipitation.

Legal Description: NE ¼, SW ¼, Sec. 19, T40N, R5E, Jefferson County  
Latitude/Longitude: 38.20812 / -90.47531

### Outfall 006 – In-stream monitoring site. SIC # 1795 (formerly 2819)

Actual flow is dependent upon precipitation.

Legal Description: NE ¼, SW ¼, Sec. 19, T40N, R5E, Jefferson County  
Latitude/Longitude: 38.20967 / -90.47233

<b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b>					PAGE NUMBER 3 of 5	
					PERMIT NUMBER MO-0000761	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
(OUTFALL NUMBER AND EFFLUENT PARAMETERS)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	Once/month	Totalizing Ultrasonic
Biochemical Oxygen Demand <sub>5</sub>	mg/L		45	30	Once/quarter	Composite**
Total Suspended Solids	mg/L		45	30	Once/quarter	Composite**
pH – Units	SU	***		***	Once/quarter	Grab
Ammonia as N	mg/L	*		*	Once/quarter	Grab
Fecal Coliform (Note 1)	#/100 mL	1000		400	Once/quarter	Grab
Total Residual Chlorine (Notes 1 & 2)	mg/L	0.019 (.13ML)		0.01 (.13 ML)	Once/quarter	Grab
Radioactive Materials (Special Condition #8)						
<u>Outfalls #002, 003, 004, 005, &amp; 006</u>						
Flow	MGD	*			Once/quarter	Grab
Total Suspended Solids	mg/L		45	30	Once/quarter	Grab
pH	SU	***		***	Once/quarter	Grab
Radioactive Materials (Special Condition #8)						
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED Parts I & III STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

MO 780-0010 (8/91)

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (Continued)**

- \* Monitoring requirement only.
- \*\* A composite sample made up from a minimum of four grab samples collected within a 24-hour period with a minimum of two hours between each grab sample.
- \*\*\* pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0 to 9.0 pH units

Note 1 – Final limitations and monitoring requirements for Fecal Coliform and Total Residual Chlorine are applicable only during the recreational season from April 1 through October 31.

Note 2 - This permit contains a Total Residual Chlorine (TRC) limit.

- a. This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 0.13 mg/L when using the DPD Colorimetric Method #4500-CL G. from Standard Methods for the Examination of Water and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 0.13 mg/L will be considered violations of the permit and values less than the minimum quantification level of 0.13 mg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.
- b. Disinfection is required year-round unless the permit specifically states that "Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31." If your permit does not require disinfection during the non-recreational months, do not chlorinate in those months.

### C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - a. Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - b. Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - c. Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances.  
The permittee shall notify the Director as soon as it knows or has reason to believe:
  - a. That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
    - (1) One hundred micrograms per liter (100 µg/L);
    - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
    - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
    - (4) The level established in Part A of the permit by the Director.
  - b. That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
  - c. That the effluent limit established in part A of the permit will be exceeded.
5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards.

- a. Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- b. General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
  - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
  - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
  - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
  - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
  - (5) There shall be no significant human health hazard from incidental contact with the water;
  - (6) There shall be no acute toxicity to livestock or wildlife watering;
  - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
  - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities

- a. Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
- b. If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

8. The permittee shall monitor for gross alpha and gross beta radiation at outfalls #001 through #006 and also the locations listed below in accordance Section A of this permit and also with the Nuclear Regulatory Commission License #SNM-33.

<u>Location</u>	<u>Frequency</u>	<u>Sample Type</u>
Outfalls # 001 - #006	Once/quarter	Grab
Hematite water supply well	Once/quarter	Grab

A summary of all radiological monitoring data shall be submitted to the Department on a quarterly basis by April 28 for the months January through March; by July 28 for the months April, May, and June; by October 28 for the months July, August, and September; and by January 28 for the months October, November, and December.

9. Industrial Sludge Disposal - (Outfall #001)

- a. Disposal of industrial sludge is not authorized by this permit. Industrial sludge shall be disposed at a permitted solid waste disposal facility in accordance with 10 CSR 80; or if the sludge is determined to be hazardous waste, shall be disposed at a permitted hazardous waste disposal facility pursuant to 10 CSR 25.
- b. Non-hazardous sludge that is disposed on site or that is exempted under 10 CSR 80 must obtain applicable permits under 10 CSR 20-6.015 and 10 CSR 20-6.200.
- c. Each effluent monitoring report shall also specify the date any sludge is removed from the facility, who removed the sludge and the number of gallons or quantity of sludge removed. The final disposal location shall be reported, including the name of the disposal facility, the solid waste or hazardous waste disposal permit number, and date of permit issuance.
- d. This permit may (after due process) be modified, or alternatively revoked and reissued, to comply with any applicable sludge disposal standard or limitation issued or approved under Section 405(d) of the Clean Water Act.

Date of Fact Sheet: November 22, 2005

Date of Public Notice: January 6, 2006

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT  
FACT SHEET**

This Fact Sheet explains the applicable regulations, rationale for development of this permit and the public participation process.

NPDES PERMIT NUMBER: MO-0000761

FACILITY NAME: Westinghouse Electric Co. LLC

OWNER NAME: Westinghouse Electric Co. LLC

LOCATION: U.S. Survey 423 (SW ¼, Sec. 9, proj.), T40N, R5E, Jefferson County:

RECEIVING STREAM: Unnamed tributaries to Joachim Creek

FACILITY CONTACT PERSON: Dustin Miller TELEPHONE: (314) 810-3325

**FACILITY DESCRIPTION AND RATIONALE**

The Westinghouse Electric Co. LLC is in the process of closing its operations in Hematite which formerly were used to manufacture fuel rods for nuclear power plants. The plant has ceased operation in June, 2001. The pre-existing uranium and chemical inventory, consisting of production excess, scrap, low level radioactive wastes and corrosives and compressed gases, has essentially been eliminated to residual concentrations. Removal and off-site disposal of interior building equipment is currently underway. The facility maintains a small activated sludge wastewater treatment facility to treat domestic wastes from restrooms inside the remaining structures and offices. The permit primarily requires monitoring of the discharge from the domestic wastewater treatment facility and also monitoring of the storm water runoff from the site.

This permit will be issued for a period of five years.



## Location Map