



FPL Energy
Seabrook Station

FPL Energy Seabrook Station
P.O. Box 300
Seabrook, NH 03874
(603) 773-7000

January 12, 2006

Docket No. 50-443

SBK-L-06013

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Seabrook Station
2005 Annual Report of Challenges to Pressurizer
Power-Operated Relief Valves and Pressurizer Safety Valves

Seabrook Station Technical Specification 6.8.1.2.c requires an annual report of challenges to pressurizer power-operated relief valves and pressurizer safety valves. In accordance with this requirement, FPL Energy Seabrook, LLC hereby reports that during 2005, there were no challenges to the Seabrook Station pressurizer power-operated relief valves and pressurizer safety valves.

Should you have any questions concerning this matter, please contact Mr. Michael Makowicz, Plant Engineering Manager, at (603) 773-7770.

Very truly yours,

FPL Energy Seabrook, LLC

Gene St. Pierre
Site Vice President

cc: S. J. Collins, NRC Region I Administrator
G. E. Miller, NRC Project Manager
G. T. Dentel, NRC Resident Inspector

A-001



FPL Energy
Seabrook Station

FPL Energy Seabrook Station
P.O. Box 300
Seabrook, NH 03874
(603) 773-7000

January 12, 2006

Docket No. 50-443

SBK-L- 06016

U. S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, DC 20555-0001


Seabrook Station
2005 Annual Report of Primary Coolant Specific Activity

Seabrook Station Technical Specification 6.8.1.2.b requires an annual report of primary coolant specific activity analyses which are required to be conducted if the limits of Technical Specification 3.4.8, "Specific Activity," are exceeded. In accordance with this requirement, FPL Energy Seabrook, LLC hereby reports that during 2005, primary coolant specific activity did not exceed the limits of Technical Specification 3.4.8.

Should you have any questions, please contact Mr. Peter J. Harvey, Chemistry Department Manager, at (603) 773-7320.

Very truly yours,

FPL Energy Seabrook, LLC



Gene St. Pierre
Site Vice President

cc: S. J. Collins, NRC Region I Administrator
G. E. Miller, NRC Project Manager
G. T. Dentel, NRC Resident Inspector