

MANUAL HARD COPY DISTRIBUTION
DOCUMENT TRANSMITTAL 2006-1583

USER INFORMATION:

GERLACH*ROSE M EML#:028401 CA#: 0363
Address: NUCSA2
Phone#: 254-3194

TRANSMITTAL INFORMATION:

TO: GERLACH*ROSE M 01/09/2006
LOCATION: USNRC
FROM: NUCLEAR RECORDS DOCUMENT CONTROL CENTER (NUCSA-2)
THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY OR ELECTRONIC MANUAL ASSIGNED TO YOU. HARDCOPY USERS MUST ENSURE THE DOCUMENTS PROVIDED MATCH THE INFORMATION ON THIS TRANSMITTAL. WHEN REPLACING THIS MATERIAL IN YOUR HARDCOPY MANUAL, ENSURE THE UPDATE DOCUMENT ID IS THE SAME DOCUMENT ID YOU'RE REMOVING FROM YOUR MANUAL. TOOLS FROM THE HUMAN PERFORMANCE TOOL BAG SHOULD BE UTILIZED TO ELIMINATE THE CHANCE OF ERRORS.
ATTENTION: "REPLACE" directions do not affect the Table of Contents, Therefore no TOC will be issued with the updated material.

TRM1 - TECHNICAL REQUIREMENTS MANUAL UNIT 1

REMOVE MANUAL TABLE OF CONTENTS DATE: 12/30/2005

ADD MANUAL TABLE OF CONTENTS DATE: 01/06/2006

CATEGORY: DOCUMENTS TYPE: TRM1

A001

ID: TEXT 3.0
REMOVE: REV:0

ADD: REV: 1

CATEGORY: DOCUMENTS TYPE: TRM1
ID: TEXT 3.11.4.1
REMOVE: REV:1

ADD: REV: 2

CATEGORY: DOCUMENTS TYPE: TRM1
ID: TEXT B3.0
REMOVE: REV:0

ADD: REV: 1

CATEGORY: DOCUMENTS TYPE: TRM1
ID: TEXT B3.11.4.1
REMOVE: REV:1

ADD: REV: 2

CATEGORY: DOCUMENTS TYPE: TRM1
ID: TEXT LOES
REMOVE: REV:24

ADD: REV: 25

CATEGORY: DOCUMENTS TYPE: TRM1
ID: TEXT TOC
REMOVE: REV:5

ADD: REV: 6

ANY DISCREPANCIES WITH THE MATERIAL PROVIDED, CONTACT DCS @ X3107 OR X3136 FOR ASSISTANCE. UPDATES FOR HARDCOPY MANUALS WILL BE DISTRIBUTED WITHIN 5 DAYS IN ACCORDANCE WITH DEPARTMENT PROCEDURES. PLEASE MAKE ALL CHANGES AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON COMPLETION OF UPDATES. FOR ELECTRONIC MANUAL USERS, ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

SSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

Table Of Contents

Issue Date: 01/06/2006

<u>Procedure Name</u>	<u>Rev</u>	<u>Issue Date</u>	<u>Change ID</u>	<u>Change Number</u>
TEXT LOES Title: LIST OF EFFECTIVE SECTIONS	25	01/06/2006		
TEXT TOC Title: TABLE OF CONTENTS	6	01/06/2006		
TEXT 1.1 Title: USE AND APPLICATION DEFINITIONS	0	11/18/2002		
TEXT 2.1 Title: PLANT PROGRAMS AND SETPOINTS PLANT PROGRAMS	1	02/04/2005		
TEXT 2.2 Title: PLANT PROGRAMS AND SETPOINTS INSTRUMENT TRIP SETPOINT TABLE	4	11/22/2005		
TEXT 3.0 Title: TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY & SURVEILLANCE (TRS) APPLICABILITY	1	01/06/2006		
TEXT 3.1.1 Title: REACTIVITY CONTROL SYSTEMS ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION	0	11/18/2002		
TEXT 3.1.2 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD DRIVE (CRD) HOUSING SUPPORT	0	11/18/2002		
TEXT 3.1.3 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD BLOCK INSTRUMENTATION	2	11/22/2005		
TEXT 3.1.4 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION & CHECK VALVE	0	11/18/2002		
TEXT 3.2.1 Title: CORE OPERATING LIMITS REPORT (COLR)	5	11/04/2005		

SSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT 3.3.1 0 11/18/2002
Title: INSTRUMENTATION RADIATION MONITORING INSTRUMENTATION

TEXT 3.3.2 0 11/18/2002
Title: INSTRUMENTATION SEISMIC MONITORING INSTRUMENTATION

TEXT 3.3.3 0 11/18/2002
Title: INSTRUMENTATION METEOROLOGICAL MONITORING INSTRUMENTATION

TEXT 3.3.4 1 07/06/2005
Title: INSTRUMENTATION TRM POST-ACCIDENT MONITORING INSTRUMENTATION

TEXT 3.3.5 0 11/18/2002
Title: INSTRUMENTATION THIS PAGE INTENTIONALLY LEFT BLANK

TEXT 3.3.6 2 10/19/2005
Title: INSTRUMENTATION TRM ISOLATION ACTUATION INSTRUMENTATION

TEXT 3.3.7 0 11/18/2002
Title: INSTRUMENTATION MAIN TURBINE OVERSPEED PROTECTION SYSTEM

TEXT 3.3.8 1 10/22/2003
Title: INSTRUMENTATION TRM RPS INSTRUMENTATION

TEXT 3.3.9 1 11/22/2004
Title: INSTRUMENTATION LPRM UPSCALE ALARM INSTRUMENTATION

TEXT 3.3.10 1 12/14/2004
Title: INSTRUMENTATION REACTOR RECIRCULATION PUMP MG SET STOPS

TEXT 3.3.11 1 10/22/2003
Title: INSTRUMENTATION MVP ISOLATION INSTRUMENTATION

TEXT 3.4.1 0 11/18/2002
Title: REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM CHEMISTRY

SSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT 3.7.5.3	0	11/18/2002	Title: PLANT SYSTEMS LIQUID HOLDUP TANKS
TEXT 3.7.6	1	03/01/2005	Title: PLANT SYSTEMS ESSW PUMPHOUSE VENTILATION
TEXT 3.7.7	0	11/18/2002	Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING
TEXT 3.7.8	1	12/14/2004	Title: PLANT SYSTEMS SNUBBERS
TEXT 3.7.9	0	11/18/2002	Title: PLANT SYSTEMS CONTROL STRUCTURE HVAC
TEXT 3.7.10	1	12/14/2004	Title: PLANT SYSTEMS SPENT FUEL STORAGE POOLS (SFSPS)
TEXT 3.8.1	1	02/04/2005	Title: ELECTRICAL POWER PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES
TEXT 3.8.2.1	1	12/14/2004	Title: ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS
TEXT 3.8.2.2	2	12/14/2004	Title: ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC
TEXT 3.8.3	0	11/18/2002	Title: ELECTRICAL POWER DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES
TEXT 3.8.4	0	11/18/2002	Title: ELECTRICAL POWER 24 VDC ELECTRICAL POWER SUBSYSTEM
TEXT 3.8.5	0	11/18/2002	Title: ELECTRICAL POWER DEGRADED VOLTAGE PROTECTION

SSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT 3.8.6	0	11/18/2002	Title: ELECTRICAL POWER EMERGENCY SWITCHGEAR ROOM COOLING
TEXT 3.9.1	0	11/18/2002	Title: REFUELING OPERATIONS DECAY TIME
TEXT 3.9.2	0	11/18/2002	Title: REFUELING OPERATIONS COMMUNICATIONS
TEXT 3.9.3	0	11/18/2002	Title: REFUELING OPERATIONS REFUELING PLATFORM
TEXT 3.10.1	0	11/18/2002	Title: MISCELLANEOUS SEAL SOURCE CONTAMINATION
TEXT 3.10.2	0	11/18/2002	Title: MISCELLANEOUS SHUTDOWN MARGIN TEST RPS INSTRUMENTATION
TEXT 3.10.3	0	11/18/2002	Title: MISCELLANEOUS INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)
TEXT 3.10.4	0	11/18/2002	Title: MISCELLANEOUS LEADING EDGE FLOW METER (LEFM)
TEXT 3.11.1.1	0	11/18/2002	Title: RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS CONCENTRATION
TEXT 3.11.1.2	0	11/18/2002	Title: RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS DOSE
TEXT 3.11.1.3	0	11/18/2002	Title: RADIOACTIVE EFFLUENTS LIQUID WASTE TREATMENT SYSTEM
TEXT 3.11.1.4	1	12/14/2004	Title: RADIOACTIVE EFFLUENTS LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION

SSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT 3.11.1.5 1 12/14/2004
Title: RADIOACTIVE EFFLUENTS RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION

TEXT 3.11.2.1 2 08/24/2005
Title: RADIOACTIVE EFFLUENTS DOSE RATE

TEXT 3.11.2.2 0 11/18/2002
Title: RADIOACTIVE EFFLUENTS DOSE - NOBLE GASES

TEXT 3.11.2.3 0 11/18/2002
Title: RADIOACTIVE EFFLUENTS DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATE FORM

TEXT 3.11.2.4 0 11/18/2002
Title: RADIOACTIVE EFFLUENTS GASEOUS RADWASTE TREATMENT SYSTEM

TEXT 3.11.2.5 1 05/20/2005
Title: RADIOACTIVE EFFLUENTS VENTILATION EXHAUST TREATMENT SYSTEM

TEXT 3.11.2.6 2 12/14/2004
Title: RADIOACTIVE EFFLUENTS RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

TEXT 3.11.3 0 11/18/2002
Title: RADIOACTIVE EFFLUENTS TOTAL DOSE

TEXT 3.11.4.1 2 01/06/2006
Title: RADIOACTIVE EFFLUENTS MONITORING PROGRAM

TEXT 3.11.4.2 1 12/14/2004
Title: RADIOACTIVE EFFLUENTS LAND USE CENSUS

TEXT 3.11.4.3 0 11/18/2002
Title: RADIOACTIVE EFFLUENTS INTERLABORATORY COMPARISON PROGRAM

TEXT 3.12.1 0 11/19/2002
Title: LOADS CONTROL PROGRAM CRANE TRAVEL-SPENT FUEL POOL STORAGE POOL

SSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT B3.5.1 0 11/19/2002

Title: ECCS AND RCIC BASES ADS MANUAL INHIBIT

TEXT B3.5.2 0 11/19/2002

Title: ECCS AND RCIC BASES ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION

TEXT B3.5.3 0 11/19/2002

Title: ECCS AND RCIC BASES LONG TERM NITROGEN SUPPLY TO ADS

TEXT B3.6.1 0 11/19/2002

Title: CONTAINMENT BASES VENTING OR PURGING

TEXT B3.6.2 0 11/19/2002

Title: CONTAINMENT BASES SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION

TEXT B3.6.3 0 11/19/2002

Title: CONTAINMENT BASES SUPPRESSION POOL ALARM INSTRUMENTATION

TEXT B3.6.4 1 12/14/2004

Title: CONTAINMENT BASES PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES

TEXT B3.7.1 0 11/19/2002

Title: PLANT SYSTEMS BASES EMERGENCY SERVICE WATER SYSTEM (SHUTDOWN)

TEXT B3.7.2 0 11/19/2002

Title: PLANT SYSTEMS BASES ULTIMATE HEAT SINK (UHS) GROUND WATER LEVEL

TEXT B3.7.3.1 0 11/19/2002

Title: PLANT SYSTEMS BASES FIRE SUPPRESSION WATER SUPPLY SYSTEM

TEXT B3.7.3.2 1 08/24/2005

Title: PLANT SYSTEMS BASES SPRAY AND SPRINKLER SYSTEMS

TEXT B3.7.3.3 0 11/19/2002

Title: PLANT SYSTEMS BASES CO2 SYSTEMS

SSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT B3.7.3.4 0 11/19/2002

Title: PLANT SYSTEMS BASES HALON SYSTEMS

TEXT B3.7.3.5 0 11/19/2002

Title: PLANT SYSTEMS BASES FIRE HOSE STATIONS

TEXT B3.7.3.6 0 11/19/2002

Title: PLANT SYSTEMS BASES YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT B3.7.3.7 0 11/19/2002

Title: PLANT SYSTEMS BASES FIRE RATED ASSEMBLIES

TEXT B3.7.3.8 1 01/12/2004

Title: PLANT SYSTEMS BASES FIRE DETECTION INSTRUMENTATION

TEXT B3.7.4 0 11/19/2002

Title: PLANT SYSTEMS BASES SOLID RADWASTE SYSTEM

TEXT B3.7.5.1 0 11/19/2002

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS HYDROGEN MONITOR

TEXT B3.7.5.2 0 11/19/2002

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE

TEXT B3.7.5.3 0 11/19/2002

Title: PLANT SYSTEMS BASES LIQUID HOLDUP TANKS

TEXT B3.7.6 1 03/01/2005

Title: PLANT SYSTEMS BASES ESSW PUMPHOUSE VENTILATION

TEXT B3.7.7 0 11/19/2002

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING INSTRUMENTATION

TEXT B3.7.8 1 12/14/2004

Title: PLANT SYSTEMS BASES SNUBBERS

SSSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT B3.7.9	1	12/14/2004	Title: PLANT SYSTEMS BASES CONTROL STRUCTURE HVAC
TEXT B3.7.10	1	12/14/2004	Title: PLANT SYSTEMS BASES SPENT FUEL STORAGE POOLS
TEXT B3.8.1	1	02/04/2005	Title: ELECTRICAL POWER BASES PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES
TEXT B3.8.2.1	0	11/19/2002	Title: ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS
TEXT B3.8.2.2	1	09/17/2004	Title: ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC
TEXT B3.8.3	0	11/19/2002	Title: ELECTRICAL POWER BASES DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES
TEXT B3.8.4	0	11/19/2002	Title: ELECTRICAL POWER BASES 24 VDC ELECTRICAL POWER SUBSYSTEM
TEXT B3.8.5	0	11/19/2002	Title: ELECTRICAL POWER BASES DEGRADED VOLTAGE PROTECTION
TEXT B3.8.6	1	02/04/2005	Title: ELECTRICAL POWER BASES EMERGENCY SWITCHGEAR ROOM COOLING
TEXT B3.9.1	0	11/19/2002	Title: REFUELING OPERATIONS BASES DECAY TIME
TEXT B3.9.2	0	11/19/2002	Title: REFUELING OPERATIONS BASES COMMUNICATIONS
TEXT B3.9.3	0	11/19/2002	Title: REFUELING OPERATIONS BASES REFUELING PLATFORM

SSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT B3.10.1	0	11/19/2002	Title: MISCELLANEOUS BASES SEALED SOURCE CONTAMINATION
TEXT B3.10.2	0	11/19/2002	Title: MISCELLANEOUS BASES SHUTDOWN MARGIN TEST RPS INSTRUMENTATION
TEXT B3.10.3	0	11/19/2002	Title: MISCELLANEOUS BASES INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)
TEXT B3.10.4	0	11/19/2002	Title: MISCELLANEOUS BASES LEADING EDGE FLOW METER (LEFM)
TEXT B3.11.1.1	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS CONCENTRATION
TEXT B3.11.1.2	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS DOSE
TEXT B3.11.1.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID WASTE TREATMENT SYSTEM
TEXT B3.11.1.4	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION
TEXT B3.11.1.5	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION
TEXT B3.11.2.1	1	12/14/2004	Title: RADIOACTIVE EFFLUENTS BASES DOSE RATE
TEXT B3.11.2.2	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES DOSE - NOBLE GASES
TEXT B3.11.2.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATES FORM

SSSES MANUAL

Manual Name: TRM1

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 1

TEXT B3.11.2.4	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES GASEOUS RADWASTE TREATMENT SYSTEM
TEXT B3.11.2.5	3	05/20/2005	Title: RADIOACTIVE EFFLUENTS BASES VENTILATION EXHAUST TREATMENT SYSTEM
TEXT B3.11.2.6	1	01/27/2004	Title: RADIOACTIVE EFFLUENTS BASES RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
TEXT B3.11.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES TOTAL DOSE
TEXT B3.11.4.1	2	01/06/2006	Title: RADIOACTIVE EFFLUENTS BASES MONITORING PROGRAM
TEXT B3.11.4.2	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LAND USE CENSUS
TEXT B3.11.4.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES INTERLABORATORY COMPARISON PROGRAM
TEXT B3.12.1	0	11/19/2002	Title: LOADS CONTROL PROGRAM BASES CRANE TRAVEL-SPENT FUEL STORAGE POOL
TEXT B3.12.2	0	11/19/2002	Title: LOADS CONTROL PROGRAM BASES HEAVY LOADS REQUIREMENTS
TEXT B3.12.3	0	11/19/2002	Title: LOADS CONTROL PROGRAM BASES LIGHT LOADS REQUIREMENTS
TEXT 4.1	0	08/31/1998	Title: ADMINISTRATIVE CONTROLS ORGANIZATION
TEXT 4.2	0	08/31/1998	Title: ADMINISTRATIVE CONTROLS REPORTABLE EVENT ACTION

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 25

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
TOC	TABLE OF CONTENTS	01/28/2005
1.0	USE AND APPLICATION Pages TRM / 1.0-1 through TRM / 1.0-3	10/04/2002
2.0	PLANT PROGRAMS Page 2.0-1 Pages TRM / 2.0-2 and TRM / 2.0-3 Page TRM / 2.0-4 Page TRM / 2.0-5 Pages TRM / 2.0-6 and TRM / 2.0-7 Page TRM / 2.0-8 Pages TRM / 2.0-9 through TRM / 2.0-11 Pages TRM / 2.0-12 through TRM / 2.0-15	08/31/1998 01/28/2005 06/25/2002 04/02/1999 11/15/2004 12/03/2004 11/15/2004 11/15/2005
3.0	APPLICABILITY Pages TRM / 3.0-1 and TRM / 3.0-2 Page TRM / 3.0-3 Page TRM / 3.0-4	04/08/1999 03/15/2002 11/30/2005
3.1	REACTIVITY CONTROL SYSTEMS Pages 3.1-1 through 3.1-6 Pages TRM / 3.1-7 and TRM / 3.1-8 Pages TRM / 3.1-9 and TRM / 3.1-9a Page TRM / 3.1-10	08/31/1998 11/15/2005 02/18/1999 02/18/1999
3.2	CORE OPERATING LIMITS REPORT Page TRM / 3.2-1 Pages TRM / 3.2-2 through TRM / 3.2-38	07/07/1999 10/31/2005
3.3	INSTRUMENTATION Pages TRM / 3.3-1 through TRM / 3.3-3 Page TRM / 3.3-4 Pages 3.3-5 through 3.3-8 Pages TRM / 3.3-9 and TRM / 3.3-9a Page TRM / 3.3-10 Pages TRM / 3.3-11 and TRM / 3.3-11a Page TRM / 3.3-12 Page TRM / 3.3-13 Page TRM / 3.3-14 Page TRM / 3.3-15 Page TRM / 3.3-16 Pages TRM / 3.3-17 and TRM / 3.3-18 Pages TRM / 3.3-19 through TRM / 3.3-21 Page TRM / 3.3-22 Pages TRM / 3.3-22a through TRM / 3.3-22d Page TRM / 3.3-23	07/16/1999 11/28/2000 08/31/1998 12/17/1998 12/17/1998 06/02/2005 03/30/2001 09/13/2005 12/14/1998 10/22/2003 06/27/2001 06/14/2002 10/22/2003 11/15/2004 11/15/2004 12/03/2004

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 25

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Pages TRM / 3.3-24 and TRM / 3.3-25	05/16/2003
	Page TRM / 3.3-26	10/22/2003
3.4	REACTOR COOLANT SYSTEM	
	Pages 3.4-1 through 3.4-5	10/23/1998
	Pages 3.4-6 through 3.4-11	08/31/1998
	Page TRM / 3.4-12	12/03/2004
	Page 3.4-13	08/31/1998
3.5	EMERGENCY CORE COOLING AND RCIC	
	Page TRM / 3.5-1	01/28/2005
	Pages 3.5-2 and 3.5-3	08/31/1998
	Page TRM / 3.5-4	04/17/2000
	Pages 3.5-5 through 3.5-7	08/31/1998
3.6	CONTAINMENT	
	Pages 3.6-1 through 3.6-3	08/31/1998
	Page TRM / 3.6-4	01/07/2002
	Page 3.6-5	08/31/1998
	Pages TRM / 3.6-6 through TRM / 3.6-8	12/31/2002
3.7	PLANT SYSTEMS	
	Pages 3.7-1 through 3.7-3	08/31/1998
	Pages TRM / 3.7-4 through TRM / 3.7-8	08/02/1999
	Pages TRM / 3.7-9 and TRM / 3.7-10	08/16/2005
	Page TRM / 3.7-11	12/29/1999
	Pages TRM / 3.7-12 and TRM / 3.7.13	08/02/1999
	Page TRM / 3.7-14	08/09/2005
	Pages TRM / 3.7-15 through TRM / 3.7-27	08/02/1999
	Pages TRM / 3.7-28 and TRM / 3.7-29	08/09/2005
	Page TRM / 3.7-30	08/25/2005
	Pages TRM / 3.7-31 and TRM 3.7-32	11/16/2001
	Page TRM / 3.7-33	01/09/2004
	Page TRM / 3.7-34	11/16/2001
	Page TRM / 3.7-34a	10/05/2002
	Pages TRM / 3.7-35 through TRM / 3.7-37	02/01/1999
	Pages 3.7-38 through 3.7-40	08/31/1998
	Pages TRM / 3.7-41 and TRM / 3.7-41a	02/14/2005
	Pages 3.7-42 and 3.7-43	08/31/1998
	Page TRM / 3.7-44	12/03/2004
	Pages 3.7-45 through 3.7-48	10/13/1998
	Page TRM / 3.7-49	03/08/2003
	Pages TRM / 3.7-50 and TRM / 3.7-51	03/09/2001
	Pages TRM / 3.7-52	12/03/2004
	Page TRM / 3.7-53	04/15/2003
	Page TRM / 3.7-54	07/29/1999

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 25

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.8	ELECTRICAL POWER	
	Page TRM / 3.8-1	04/02/2002
	Pages TRM / 3.8-2 through TRM / 3.8-4	01/28/2005
	Pages TRM / 3.8-5 and TRM / 3.8-6	04/02/2002
	Pages TRM / 3.8-7 through TRM / 3.8-10	12/03/2004
	Page TRM / 3.8-11	08/10/2004
	Page TRM / 3.8-12	12/03/2004
	Pages 3.8-13 and 3.8-14	08/31/1998
	Pages TRM / 3.8-15 through TRM / 3.8-17	04/02/2002
	Page 3.8-18	08/31/1998
	Page TRM / 3.8-19	04/02/2002
	Page 3.8-20	08/31/1998
	Pages TRM / 3.8-21 through TRM / 3.8-23	06/06/1999
	Pages 3.8-24 and 3.8-25	08/31/1998
3.9	REFUELING OPERATIONS	
	Pages 3.9-1 through 3.9-3	08/31/1998
3.10	MISCELLANEOUS	
	Pages 3.10-1 through 3.10-4	08/31/1998
	Page TRM / 3.10-5	03/08/2003
	Page TRM / 3.10-6	06/05/2002
	Page TRM / 3.10-7	04/07/2000
	Page TRM / 3.10-8	04/17/2002
3.11	RADIOACTIVE EFFLUENTS	
	Pages 3.11-1 through 3.11-9	08/31/1998
	Page TRM / 3.11-10	12/03/2004
	Pages 3.11-11 and 3.11-12	08/31/1998
	Page 3.11-13	09/01/1998
	Page TRM / 3.11-14	12/03/2004
	Pages 3.11-15 and 3.11-16	09/01/1998
	Pages 3.11-17 and 3.11-18	08/31/1998
	Page TRM / 3.11-19	08/15/2005
	Pages 3.11-20 and 3.11-21	08/31/1998
	Page TRM / 3.11-22	04/02/2002
	Pages TRM / 3.11-23 and TRM / 3.11-24	05/13/2005
	Page 3.11-25	09/01/1998
	Pages TRM / 3.11-26 through TRM / 3.11-28	01/21/2004
	Page TRM / 3.11-29	12/03/2004
	Pages TRM / 3.11.30 through TRM / 3.11.32	01/21/2004
	Pages 3.11-33 and 3.11-34	08/31/1998
	Pages TRM / 3.11-35 through TRM / 3.11-39	11/30/2005
	Pages 3.11-40 through 3.11-44	08/31/1998
	Page TRM / 3.11-45	12/03/2004
	Pages 3.11-46 and 3.11-47	08/31/1998

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.12	LOADS CONTROL PROGRAM Pages TRM / 3.12-1 through TRM / 3.12-5	02/05/1999
4.0	ADMINISTRATIVE CONTROLS Pages 4.0-1 through 4.0-8	08/31/1999

SUSQUEHANNA STEAM ELECTRIC STATION PPL Rev. 25
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.0	APPLICABILITY BASES Pages B 3.0-1 through B 3.0-10 Pages TRM / B 3.0-11 and TRM / B 3.0-12 Pages TRM / B 3.0-13 and TRM / B 3.0-14 Page TRM / B 3.0-15	08/31/1998 03/15/2002 11/30/2005 03/15/2002
B 3.1	REACTIVITY CONTROL SYSTEMS BASES Pages TRM / B 3.1-1 through TRM / B 3.1-3 Page B 3.1-4 Pages TRM / B 3.1-5 through TRM / B 3.1-7 Page TRM / B 3.1-8	07/13/1999 08/31/1998 11/15/2005 02/18/1999
B 3.2	CORE OPERATING LIMITS BASES Page B 3.2-1	08/31/1998
B 3.3	INSTRUMENTATION BASES Page TRM / B 3.3-1 Page B 3.3-2 Pages TRM / B 3.3-3 and TRM / B 3.3-3A Pages TRM / B 3.3-4 through TRM / B 3.3-6 Pages TRM / B 3.3-7 through TRM / B 3.3-9 Page B 3.3-10 Pages TRM / B 3.3-11 and TRM / B 3.3-12 Page TRM / B 3.3-13 Page TRM / B 3.3-14 Page TRM / B 3.3-14a Page TRM / B 3.3-14b Pages TRM / B 3.3-15 and TRM / B 3.3-16 Page TRM / B 3.3-17 Pages TRM / B 3.3-17a through TRM / B 3.3-17f Pages TRM / B3.3-18 and TRM / B 3.3-19 Page TRM / B 3.3-20 Page TRM / B 3.3-21	04/07/2000 08/31/1998 01/31/2005 06/02/2005 03/30/2001 08/31/1998 09/13/2005 12/03/2004 06/25/2002 06/14/2002 06/14/2002 10/22/2003 11/15/2004 11/15/2004 05/16/2003 10/22/2003 05/16/2003
B 3.4	REACTOR COOLANT SYSTEM BASES Pages B 3.4-1 through B 3.4-4 Page TRM / B 3.4-5 Page B 3.4-6	08/31/1998 10/15/1999 08/31/1998
B 3.5	ECCS AND RCIC BASES Pages B 3.5-1 through B 3.5-5	08/31/1998
B 3.6	CONTAINMENT BASES Page TRM / B 3.6-1 Page TRM / B 3.6-2 Page B 3.6-3 Page TRM / B 3.6-4 Page TRM / B 3.6-5	07/26/2001 02/01/1999 08/31/1998 09/23/1999 01/07/2002

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 25

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Pages TRM / B 3.6-6	12/03/2004
	Pages B.3.6-7 through TRM / B 3.6-11	12/31/2002
B 3.7	PLANT SYSTEMS BASES	
	Pages B 3.7-1 and B 3.7-2	08/31/1998
	Pages TRM / B 3.7-3 through TRM / B 3.7-5	08/02/1999
	Page TRM / B 3.7-6	08/16/2005
	Pages TRM / B 3.7-7 and TRM / B 3.7-7a	08/02/1999
	Pages TRM / B 3.7-8 through TRM / B 3.7-10	08/02/1999
	Page TRM / B 3.7-10a	08/02/1999
	Pages TRM / B 3.7-11 and TRM / B 3.7-11a	08/02/1999
	Pages TRM / B 3.7-12 through TRM / B 3.7-14	08/02/1999
	Page TRM / B 3.7-14a	08/02/1999
	Page TRM / B 3.7-14b	01/09/2004
	Pages TRM / B 3.7-15 and TRM / B 3.7-16	02/01/1999
	Pages B 3.7-17 through B 3.7-20	08/31/1998
	Pages TRM/B 3.7-21 and TRM/B 3.7-21a	02/14/2005
	Pages TRM/B 3.7-22 and TRM/B 3.7-23	04/07/2000
	Page B 3.7-24	08/31/1998
	Page TRM / B 3.7-25	12/03/2004
	Pages B 3.7-26 through B 3.7-30	08/31/1998
	Page TRM / B 3.7-31	12/03/2004
	Page TRM / B 3.7-32	03/09/2001
	Page TRM / B 3.7-33	04/15/2003
	Page TRM / B 3.7-34	12/03/2004
	Page TRM / B 3.7-35	07/05/2000
B 3.8	ELECTRICAL POWER BASES	
	Page TRM / B 3.8-1	04/02/2002
	Pages TRM / B 3.8-2 and TRM / B 3.8-2a	01/28/2005
	Page TRM / B 3.8-3	04/02/2002
	Page TRM / B 3.8-3a	04/02/2002
	Page TRM / B 3.8-4	08/10/2004
	Page TRM / B 3.8-4a	04/02/2002
	Page TRM / B 3.8-5	08/31/1998
	Pages TRM / B 3.8-6 through TRM / B 3.8-16	04/02/2002
	Page TRM / B 3.8-17	01/28/2005
B.3.9	REFUELING OPERATIONS BASES	
	Pages B 3.9-1 through B 3.9-7	08/31/1998
B 3.10	MISCELLANEOUS BASES	
	Pages B 3.10-1 through B 3.10-2	08/31/1998
	Page TRM / B 3.10-3	03/08/2003
	Pages TRM / B 3.10-4 and TRM / B 3.10-5	08/23/1999
	Pages TRM / B 3.10-6 and TRM / B 3.10-7	04/17/2002

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 25

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.11	RADIOACTIVE EFFLUENTS BASES	
	Pages B 3.11-1 through B 3.11-9	08/30/1998
	Page TRM / B 3.11-10	02/01/1999
	Pages TRM/B 3.11-11 and TRM/B 3.11-11a	04/07/2000
	Pages TRM/B 3.11-12 and TRM/B 3.11-13	02/01/1999
	Page TRM / B 3.11-14	12/03/2004
	Page TRM / B 3.11-15	02/01/1999
	Pages B 3.11-16 through B 3.11-19	08/30/1998
	Page TRM / B 3.11-20	04/02/2002
	Page TRM / B 3.11-20a	04/02/2002
	Pages TRM / B 3.11-21 through TRM / B 3.11.23a	05/13/2005
	Pages TRM / B 3.11-24 and TRM /B 3.11-25	01/21/2004
	Pages B 3.11-26 and B 3.11-27	08/30/1998
	Pages TRM / B 3.11-28 and TRM / B 3.11-29	11/30/2005
	Page TRM / B 3.11-30	12/03/2004
	Pages B 3.7-31 through B 3.7-35	08/30/1998
	Page TRM / B 3.11-36	02/12/1999
B.3.12	LOADS CONTROL PROGRAM BASES	
	Pages TRM / B 3.12-1 through TRM / B 3.12-3	02/05/1999

TRM1 text LOES
 11/9/05

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
1.0	USE AND APPLICATION	TRM/1.0-1
1.1	Definitions	TRM/1.0-2
2.0	PLANT PROGRAMS	2.0-1
2.1	Plant Programs	2.0-1
2.2	Instrument Trip Setpoint Table	TRM/2.0-5
3.0	APPLICABILITY	TRM/3.0-1
3.0	TRO) - TR for Operation (TRO) Applicability	TRM/3.0-1
3.0	(TRS) - TR Surveillance (TRS) Applicability	TRM/3.0-3
3.1	REACTIVITY CONTROL SYSTEMS.....	3.1-1
3.1.1	Alternate Rod Injection.....	3.1-1
3.1.2	CRD Housing Support.....	3.1-4
3.1.3	Control Rod Block Instrumentation.....	3.1-5
3.1.4	Control Rod Scram Accumulators Instrumentation and Check Valve.....	TRM/3.1-9
3.2	CORE OPERATING LIMITS REPORT	TRM/3.2-1
3.2.1	Core Operating Limits Report.....	TRM/3.2-1
3.3	INSTRUMENTATION.....	TRM/3.3-1
3.3.1	Radiation Monitoring Instrumentation.....	TRM/3.3-1
3.3.2	Seismic Monitoring Instrumentation.....	TRM/3.3-4
3.3.3	Meteorological Monitoring Instrumentation.....	3.3-7
3.3.4	TRM Post-Accident Monitoring Instrumentation.....	TRM/3.3-9
3.3.5	Section Not Used	TRM/3.3-12
3.3.6	TRM Containment Isolation Instrumentation.....	TRM/3.3-13
3.3.7	Turbine Overspeed Protection System.....	TRM/3.3-17
3.3.8	Section Not Used	TRM/3.3-19
3.3.9	OPRM Instrumentation.....	TRM/3.3-22
3.3.10	Reactor Recirculation Pump MG Set Electrical and Mechanical Stops.....	TRM/3.3-23
3.3.11	MVP Isolation Instrumentation.....	TRM/3.3-25
3.4	REACTOR COOLANT SYSTEM.....	3.4-1
3.4.1	Reactor Coolant System Chemistry.....	3.4-1
3.4.2	Structural Integrity.....	3.4-6
3.4.3	High/Low Pressure Interface Leakage Monitors	3.4-9
3.4.4	Reactor Recirculation Flow and Rod Line Limit.....	TRM/3.4-12
3.4.5	Reactor Vessel Material Surveillances Program.....	3.4-13

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
3.5	EMERGENCY CORE COOLING AND RCIC	TRM/3.5-1
3.5.1	ADS Manual Inhibit	TRM/3.5-1
3.5.2	ECCS and RCIC System Monitoring Instrumentation.....	3.5-3
3.5.3	Long Term Nitrogen Supply to ADS	3.5-6
3.6	CONTAINMENT.....	3.6-1
3.6.1	VENTING or PURGING	3.6-1
3.6.2	Suppression Chamber-to-Drywell Vacuum Breaker Position Indication.....	3.6-2
3.6.3	Suppression Pool Alarm Instrumentation.....	3.6-3
3.6.4	Primary Containment Closed System Boundaries	TRM/3.6-6
3.7	PLANT SYSTEMS	3.7-1
3.7.1	Emergency Service Water System (Shutdown).....	3.7-1
3.7.2	Ultimate Heat Sink and Ground Water Level.....	3.7-3
3.7.3.1	Fire Suppression Water Supply System	TRM/3.7-4
3.7.3.2	Spray and Sprinkler Systems	TRM/3.7-8
3.7.3.3	CO2 systems	TRM/3.7-12
3.7.3.4	Halon Systems.....	TRM/3.7-16
3.7.3.5	Fire Hose Stations.....	TRM/3.7-18
3.7.3.6	Yard Fire Hydrants and Hydrant Hose Houses.....	TRM/3.7-22
3.7.3.7	Fire Rated Assemblies	TRM/3.7-24
3.7.3.8	Fire Detection Instrumentation	TRM/3.7-26
3.7.4	Solid Radwaste System	TRM/3.7-35
3.7.5.1	Main Condenser Offgas Hydrogen Monitor	3.7-38
3.7.5.2	Main Condenser Explosive Gas Mixture.....	3.7-39
3.7.5.3	Liquid Holdup Tanks	3.7-40
3.7.6	ESSW Pumphouse Ventilation.....	TRM/3.7-41
3.7.7	Main Condenser Offgas Pretreatment Logarithmic Radiation Monitoring Instrumentation.....	3.7-42
3.7.8	Snubbers.....	TRM/3.7-44
3.7.9	Control Structure HVAC	TRM/3.7-50
3.7.10	Spent Fuel Storage Pools	TRM/3.7-52

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
3.8	ELECTRICAL POWER	TRM/3.8-1
3.8.1	Primary Containment Penetration Conductor Overcurrent Protective Devices	TRM/3.8-1
3.8.2.1	Motor Operated Valves Thermal Overload Protection - Continuous.....	TRM/3.8-5
3.8.2.2	Motor Operated Valves Thermal Overload Protection - Automatic.....	TRM/3.8-11
3.8.3	Diesel Generator (DG) Maintenance Activities	3.8-13
3.8.4	24VDC Electrical Power Subsystem.....	TRM/3.8-15
3.8.5	Degraded Voltage Protection	TRM/3.8-21
3.8.6	Emergency Switchgear Room Cooling	3.8-24
3.9	REFUELING OPERATIONS	3.9-1
3.9.1	Decay Time.....	3.9-1
3.9.2	Communications	3.9-2
3.9.3	Refueling Platform.....	3.9-3
3.10	MISCELLANEOUS	3.10-1
3.10.1	Sealed Source Contamination.....	3.10-1
3.10.2	MODE 5 Shutdown Margin Test RPS Instrumentation	3.10-4
3.10.3	Independent Spent Fuel Storage Installation (ISFSI).....	TRM/3.10-7
3.10.4	Leading Edge Flow Meter (LEFM).....	TRM/3.10-8
3.11	RADIOACTIVE EFFLUENTS.....	3.11-1
3.11.1.1	Liquid Effluents Concentration.....	3.11-1
3.11.1.2	Liquid Effluents Dose	3.11-4
3.11.1.3	Liquid Waste Treatment System	3.11-6
3.11.1.4	Liquid Radwaste Effluent Monitoring Instrumentation.....	3.11-8
3.11.1.5	Radioactive Liquid Process Monitoring Instrumentation	3.11-13
3.11.2.1	Dose Rate.....	3.11-17
3.11.2.2	Dose - Noble Gases.....	3.11-20
3.11.2.3	Dose - Iodine, Tritium, and Radionuclides in Particulate Form.....	3.11-21
3.11.2.4	Gaseous Radwaste Treatment System	TRM/3.11-22
3.11.2.5	Ventilation Exhaust Treatment System.....	TRM/3.11-23
3.11.2.6	Radioactive Gaseous Effluent Monitoring Instrumentation	3.11-25
3.11.3	Total Dose.....	3.11-33
3.11.4.1	Monitoring Program.....	TRM/3.11-35
3.11.4.2	Land Use Census.....	TRM/3.11-45
3.11.4.3	Interlaboratory Comparison Program	3.11-47

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
3.12	LOADS CONTROL PROGRAM.....	TRM/3.12-1
3.12.1	Crane Travel - Spent Fuel Storage Pool	TRM/3.12-1
3.12.2	Heavy Loads Requirements.....	TRM/3.12-3
3.12.3	Light Loads Requirements.....	TRM/3.12-5
4.0	ADMINISTRATIVE CONTROLS.....	4.0-1
4.1	Organization	4.0-1
4.2	Reportable Event Action	4.0-2
4.3	Safety Limit Violation	4.0-3
4.4	Procedures and Programs.....	4.0-4
4.5	Reporting Requirements.....	4.0-5
4.6	Radiation Protection Program.....	4.0-7
4.7	Training.....	4.0-8

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
B 3.0	Applicability	B 3.0-1
B 3.0	(TRO) - TR for Operation (TRO) Applicability	B 3.0-1
B 3.0	(TRS) - TR Surveillance (TRS) Applicability	B 3.0-9
B 3.1.1	Alternate Rod Injection	TRM/B 3.1-1
B 3.1.2	CRD Housing Support	TRM/B 3.1-4
B 3.1.3	Control Rod Block Instrumentation	TRM/B 3.1-5
B 3.1.4	Control Rod Scram Accumulators Instrumentation and Check Valve	TRM/B 3.1-8
B 3.2.1	Core Operating Limits Report (COLR)	B 3.2-1
B 3.3.1	Radiation Monitoring Instrumentation	TRM/B 3.3-1
B 3.3.2	Seismic Monitoring Instrumentation	B 3.3-2
B 3.3.3	Meteorological Monitoring Instrumentation	TRM/B 3.3-3
B 3.3.4	TRM Post-Accident Monitoring Instrumentation	TRM/B 3.3-4
B 3.3.5	Section Not Used	TRM/B 3.3-7
B 3.3.6	TRM Containment Isolation Instrumentation	B 3.3-10
B 3.3.7	Turbine Overspeed Protection System	TRM/B 3.3-14
B 3.3.8	Section Not Used	TRM/B 3.3-15
B 3.3.9	OPRM Instrumentation	TRM/B 3.3-17
B 3.3.10	Reactor Recirculation Pump MG Set Electrical and Mechanical Stops	TRM/B 3.3-18
B 3.3.11	MVP Isolation Instrumentation	TRM/B 3.3-20
B 3.4.1	Reactor Coolant System Chemistry	B 3.4-1
B 3.4.2	Structural Integrity	B 3.4-2
B 3.4.3	High/Low Pressure Interface Leakage Monitors	B 3.4-4
B 3.4.4	Reactor Recirculation Flow and Rod Line Limit	TRM/B 3.4-5
B 3.4.5	Reactor Vessel Material Surveillances Program	B 3.4-6
B 3.5.1	ADS Manual Inhibit	B 3.5-1
B 3.5.2	ECCS and RCIC System Monitoring Instrumentation	B 3.5-3
B 3.5.3	Long Term Nitrogen Supply to ADS	B 3.5-4

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
B 3.6.1	VENTING or PURGING	TRM/B 3.6-1
B 3.6.2	Suppression Chamber-to-Drywell Vacuum Breaker Position Indication.....	B 3.6-3
B 3.6.3	Suppression Pool Alarm Instrumentation.....	TRM/B 3.6-4
B 3.6.4	Primary Containment Closed System Boundaries.....	TRM/B 3.6-6
B 3.7.1	Emergency Service Water System (Shutdown).....	B 3.7-1
B 3.7.2	Ultimate Heat Sink and Ground Water Level.....	B 3.7-2
B 3.7.3.1	Fire Suppression Water Supply System.....	TRM/B 3.7-3
B 3.7.3.2	Spray and Sprinkler Systems.....	TRM/B 3.7-5
B 3.7.3.3	CO2 systems.....	TRM/B 3.7-7
B 3.7.3.4	Halon Systems.....	TRM/B 3.7-8
B 3.7.3.5	Fire Hose Stations.....	TRM/B 3.7-10
B 3.7.3.6	Yard Fire Hydrants and Hydrant Hose Houses.....	TRM/B 3.7-11
B 3.7.3.7	Fire Rated Assemblies.....	TRM/B 3.7-12
B 3.7.3.8	Fire Detection Instrumentation.....	TRM/B 3.7-14
B 3.7.4	Solid Radwaste System.....	TRM/B 3.7-15
B 3.7.5.1	Main Condenser Offgas Hydrogen Monitor.....	B 3.7-17
B 3.7.5.2	Main Condenser Explosive Gas Mixture.....	B 3.7-19
B 3.7.5.3	Liquid Holdup Tanks.....	B 3.7-20
B 3.7.6	ESSW Pumphouse Ventilation.....	TRM/B 3.7-21
B 3.7.7	Main Condenser Offgas Pretreatment Logarithmic Radiation Monitoring Instrumentation.....	TRM/B 3.7-22
B 3.7.8	Snubbers.....	B 3.7-24
B 3.7.9	Control Structure HVAC.....	TRM/B 3.7-31
B 3.7.10	Spent Fuel Storage Pools.....	TRM/B 3.7-33
B 3.8.1	Primary Containment Penetration Conductor Overcurrent Protective Devices.....	TRM/B 3.8-1
B 3.8.2.1	Motor Operated Valves Thermal Overload Protection - Continuous.....	TRM/B 3.8-3
B 3.8.2.2	Motor Operated Valves Thermal Overload Protection - Automatic.....	TRM/B 3.8-4
B 3.8.3	Diesel Generator (DG) Maintenance Activities.....	B 3.8-5
B 3.8.4	24VDC Electrical Power Subsystem.....	B 3.8-6
B 3.8.5	Degraded Voltage Protection.....	TRM/B 3.8-16
B 3.8.6	Emergency Switchgear Room Cooling.....	TRM/B 3.8-17
B.3.9.1	Decay Time.....	B 3.9-1
B 3.9.2	Communications.....	B 3.9-2

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
B 3.9.3	Refueling Platform.....	B 3.9-3
B 3.10.1	Sealed Source Contamination.....	B 3.10-1
B 3.10.2	MODE 5 Shutdown Margin Test RPS Instrumentation	B 3.10-2
B 3.10.3	Independent Spent Fuel Storage Installation (ISFSI).....	TRM/B 3.10-4
B 3.10.4	Leading Edge Flow Meter (LEFM).....	TRM/B 3.10-6
B 3.11.1.1	Liquid Effluents Concentration.....	B 3.11-1
B 3.11.1.2	Liquid Effluents Dose	B 3.11-4
B 3.11.1.3	Liquid Waste Treatment System	B 3.11-6
B 3.11.1.4	Liquid Radwaste Effluent Monitoring Instrumentation.....	B 3.11-7
B 3.11.1.5	Radioactive Liquid Process Monitoring Instrumentation	TRM/B 3.11-10
B 3.11.2.1	Dose Rate.....	TRM/B 3.11-12
B 3.11.2.2	Dose - Noble Gases.....	B 3.11-16
B 3.11.2.3	Dose - Iodine, Tritium, and Radionuclides in Particulate Form.....	B 3.11-18
B 3.11.2.4	Gaseous Radwaste Treatment System.....	TRM/B 3.11-20
B 3.11.2.5	Ventilation Exhaust Treatment System.....	TRM/B 3.11-21
B 3.11.2.6	Radioactive Gaseous Effluent Monitoring Instrumentation	TRM/B 3.11-24
B 3.11.3	Total Dose.....	B 3.11-26
B 3.11.4.1	Monitoring Program.....	TRM/B 3.11-28
B 3.11.4.2	Land Use Census.....	B 3.11-34
B 3.11.4.3	Interlaboratory Comparison Program	TRM/B 3.11-36
B.3.12.1	Crane Travel - Spent Fuel Storage Pool	TRM/B 3.12-1
B.3.12.2	Heavy Loads Requirements	TRM/B 3.12-2
B.3.12.3	Light Loads Requirements	TRM/B 3.12-3

TRM text TOC
 2/2/05

3.0 TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY

TRO 3.0.1 TROs shall be met during the MODES or other specified conditions in the Applicability, except as provided in TRO 3.0.2.

TRO 3.0.2 Upon discovery of a failure to meet an TRO, the Required Actions of the associated Conditions shall be met, except as provided in TRO 3.0.5 and TRO 3.0.6.

If the TRO is met or is no longer applicable prior to expiration of the specified Completion Time(s), completion of the Required Action(s) is not required, unless otherwise stated.

TRO 3.0.3 When a TRO is not met, and the associated ACTIONS are not met, an associated ACTION is not provided, or if directed by the associated ACTIONS, initiate a Condition Report to document the condition, initiate immediate corrective actions as required and within 14 days issue a change to the appropriate TRM sections to describe committed actions to be taken.

TRO 3.0.4 When a TRO is not met, entry into a MODE or other specified condition in the Applicability shall not be made except when the associated ACTIONS to be entered permit continued operation in the MODE or other specified condition in the Applicability for an unlimited period of time. If such situations are discovered and a different action is deemed appropriate, issue a change to the appropriate TRM sections to describe committed actions to be taken.

Exceptions to this Requirement are stated in the individual Requirements. These exceptions allow entry into MODES or other specified conditions in the Applicability when the associated ACTIONS to be entered allow unit operation in the MODE or other specified condition in the Applicability only for a limited period of time. TRO 3.0.4 is only applicable for entry into a MODE or other specified condition in the Applicability in MODES 1, 2, and 3.

This Specification shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

(continued)

3.0 TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY

TRO 3.0.5 Equipment removed from service or declared inoperable to comply with ACTIONS may be returned to service under administrative control solely to perform testing required to demonstrate its OPERABILITY, the OPERABILITY of other equipment or variables to be within limits. This is an exception to TRO 3.0.2 for the system returned to service under administrative control to perform the testing required to demonstrate OPERABILITY.

TRO 3.0.6 When a supported system TRO is not met solely due to a support system TRO not being met, the Conditions and Required Actions associated with this supported system are not required to be entered. Only the support system TRO ACTIONS are required to be entered. This is an exception to TRO 3.0.2 for the supported system.

When a support system's Required Action directs a supported system to be declared inoperable or directs entry into Conditions and Required Actions for a supported system. The applicable Conditions and Required Actions shall be entered in accordance with TRO 3.0.2.

3.0 Technical Requirement Surveillance (TRS) Applicability

TRS 3.0.1 TRS shall be met during the MODES or other specified conditions in the Applicability for individual TROs, unless otherwise stated in the TRS. Failure to meet a Surveillance, whether such failure is experienced during the performance of the Surveillance or between performances of the Surveillance, shall be failure to meet the TRO. Failure to perform a Surveillance within the specified Frequency shall be failure to meet the TRO except as provided in TRS 3.0.3. Surveillances do not have to be performed on inoperable equipment or variables outside specified limits.

TRS 3.0.2 The specified Frequency for each TRS is met if the Surveillance is performed within 1.25 times the interval specified in the Frequency, as measured from the previous performance or as measured from the time a specified condition of the Frequency is met.

For Frequencies specified as "once," the above interval extension does not apply.

If a Completion Time requires periodic performance on a "once per . . ." basis, the above Frequency extension applies to each performance after the initial performance.

Exceptions to this Requirement are stated in the individual Requirements.

TRS 3.0.3 If it is discovered that a Surveillance was not performed within its specified Frequency, then compliance with the requirement to declare the TRO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified Frequency, whichever is greater. In the event it is determined that a Surveillance cannot be performed within its specified Frequency, compliance with the requirement to declare the TRO not met may be delayed, from the expiration of the current Surveillance test interval, up to 24 hours or up to the limit of the specified Frequency, whichever is greater. This delay period is permitted to allow performance of the Surveillance. A risk evaluation shall be performed for any Surveillance delayed greater than 24 hours and the risk impact shall be managed.

(continued)

3.0 Technical Requirement Surveillance (TRS) Applicability

TRS 3.0.3 (continued) If the Surveillance is not performed within the delay period, the TRO must immediately be declared not met, and the applicable Condition(s) must be entered.

When the Surveillance is performed within the delay period and the Surveillance is not met, the TRO must immediately be declared not met, and the applicable Condition(s) must be entered.

Exceptions to this Requirement are stated in the individual Requirements.

TRS 3.0.4 Entry into a MODE or other specified condition in the Applicability of a TRO shall not be made unless the TRO's Surveillances have been met within their specified Frequency. This provision shall not prevent entry into MODES or other specified conditions in the Applicability that are required to comply with Actions or that are part of a shutdown of the unit.

TRS 3.0.4 is only applicable for entry into a MODE or other specified condition in the Applicability in MODES 1, 2, and 3.

3.11 Radioactive Effluents

3.11.4 Radiological Environmental Monitoring

3.11.4.1 Monitoring Program

TRO 3.11.4.1 The radiological environmental monitoring program shall be conducted as specified in Table 3.11.4.1-1.

APPLICABILITY: At all times

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Radiological environmental monitoring program not being conducted as specified in Table 3.11.4.1-1	A.1 Generate a Condition Report to describe the deficiency and any actions taken to prevent their recurrence in the applicable Annual Radiological Environmental Operating Report	72 hours
B. The average level of radioactivity over any calendar quarter as the result of an individual radionuclide in plant effluents in a particular environmental exposure pathway in a particular environmental sampling medium, at a specified location exceeds the applicable reporting level of Table 3.11.4.1-2	B.1 Generate a Condition Report to prepare and submit a Special Report to the Commission within 30 days of identification of the Condition.	72 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. More than one of the radionuclides in Table 3.11.4.1-2 are detected in a particular environmental exposure pathway at a specified monitoring location and are the result of plant effluents</p> <p><u>AND</u></p> <p>The sum of the ratios of the quarterly average activity levels to their corresponding reporting levels of each detected radionuclide, from Table 3.11.4.1-2, is ≥ 1.0</p>	<p>C.1 Generate a Condition Report to prepare and submit a Special Report to the Commission within 30 days of identification of the Condition.</p>	<p>72 hours</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. One or more Radionuclide(s) other than those in Table 3.11.4.1-2 are detected in a particular environmental exposure pathway at a specified location and are the result of plant effluents</p> <p><u>AND</u></p> <p>The potential annual dose to a MEMBER OF THE PUBLIC from all detected radionuclides that are the result of plant effluents is greater than or equal to the calendar year limits of TROs 3.11.1.2, 3.11.2.2 and 3.11.2.3</p>	<p>D.1 Generate a Condition Report to prepare and submit a Special Report to the Commission within 30 days of identification of the Condition.</p>	<p>72 hours</p>
<p>E. All requirements for a Special Report per either Condition B, C, or D are met except that the radionuclides detected are not the result of plant effluents</p>	<p>E.1 Generate a Condition Report to describe the reasons for not attributing identified radionuclides to plant effluents in the applicable Annual Radiological Environmental Operating Report.</p>	<p>72 hours</p>

(continued)

NOTE: The provisions of TRS 3.0.3 are not applicable to the below surveillances.

TECHNICAL REQUIREMENT SURVEILLANCE

SURVEILLANCE		FREQUENCY
TRS 3.11.4.1.1	Collect the radiological environmental monitoring samples pursuant to Table 3.11.4.1-1	As required by Table 3.11.4.1-1
TRS 3.11.4.1.2	Analyze samples pursuant to the requirements of Table 3.11.4.1-1 with equipment meeting the detection capabilities required by Table 3.11.4.1-3	As required by Table 3.11.4.1-1
TRS 3.11.4.1.3	Determine annual cumulative potential dose contributions from radionuclides detected in environmental samples in accordance with the methodology and parameters in the ODCM.	Annually

TABLE 3.11.4.1-1 (Page 1 of 3)
RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
1. DIRECT RADIATION	40 routine monitoring stations with two or more dosimeters or with one instrument for measuring and recording dose rate continuously placed as follows: <ol style="list-style-type: none"> 1. An inner ring of stations, one in each meteorological sector, in the general area of the SITE BOUNDARY 2. An outer ring of stations, one in each meteorological sector, in the 3 to 9 mile range from the site 3. The balance of the stations placed in special interest areas such as population centers, nearby residences, schools, and in 1 or 2 areas to serve as control stations 	Quarterly	Gamma dose quarterly
2. AIRBORNE Radioiodine and Particulates	Samples from 5 locations: <ol style="list-style-type: none"> a. 1 sample from close to each of the 3 SITE BOUNDARY locations (in different sectors) with the highest calculated annual average groundlevel χ/Q b. 1 sample from the vicinity of the community having one of the highest calculated annual ground level χ/Q c. 1 sample from a control location, between 15 and 30 km distant and in the least prevalent wind direction of wind blowing from the plant 	Continual sampler operation with sample collection weekly, or more frequently if required by dust loading	<u>Radioiodine Canister:</u> I-131 Analysis weekly <u>Particulate Sampler:</u> Gross Beta radio activity analysis following filter change ^(a) Gamma isotopic analysis of composite (by location) quarterly

(continued)

(a) Airborne particulate sample filters shall be analyzed for gross beta radioactivity 24 hours or more after sampling to allow for radon and thorn daughter decay. If gross beta activity in air particulate samples is greater than ten times the yearly mean of control samples, gamma isotopic analysis shall be performed on the individual samples.

TABLE 3.11.4.1-1 (Page 2 of 3)
RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
3. WATERBORNE			
a. Surface	1 sample upstream 1 sample downstream	Composite sample over one-month period	Gamma isotopic analysis monthly. Composite for tritium analyses quarterly
b. Ground	Samples from 1 or 2 sources only if likely to be affected	Quarterly	Gamma isotopic and tritium analyses quarterly
c. Drinking	1 sample from each of 1 to 3 of the nearest water supplies that could be affected by its discharge 1 sample from a control location	Composite sample over 2-week period when I-131 analysis is performed, monthly composite otherwise	I-131 analysis on each composite when the dose calculated for the consumption of the water is greater than 1 mrem per year. Composite for gross beta and gamma isotopic analyses monthly. Composite for tritium analyses quarterly
d. Sediment from shoreline	1 sample from downstream area with existing or potential recreational value	Semiannually	Gamma isotopic analyses semiannually

(continued)

TABLE 3.11.4.1-1 (Page 3 of 3)
RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
4. INGESTION			
a. Milk	<p>a. Samples from milking animals in 3 locations within 5km from the plant having the highest dose potential. If there are none, then, 1 sample from milking animals in each of 3 areas between 5 and 8km distant where doses are calculated to be greater than 1 mrem per year.</p> <p>1 sample from milking animals at a control location (between 15 and 30km from the plant preferably in the least prevalent direction for wind blowing from the plant).</p>	Semimonthly when animals are on pasture, monthly at other times.	Gamma isotopic and I-131 analysis semimonthly when animals are on pasture; monthly at other times.
b. Fish and/or Invertebrates	<p>b. 1 sample of each of two recreationally important species in vicinity of plant discharge area.</p> <p>1 sample of same species in areas not influenced by plant discharge.</p>	Sample in season, or semiannually if they are not seasonal.	Gamma isotopic analysis on edible portions.
c. Food Products	<p>c. 1 sample of each principal class of food products from any area which is irrigated by water in which liquid plant wastes have been discharged.</p> <p>Samples of 3 different kinds of broad leaf vegetation grown nearest each of two different offsite locations of highest predicted annual average ground level D/Q if milk sampling is not performed.</p> <p>1 sample of each of the similar broad leaf vegetation grown between 15 to 30km from the plant, preferably, in the least prevalent direction for wind blowing from the plant if milk sampling is not performed.</p>	<p>At time of harvest</p> <p>Monthly when available</p> <p>Monthly when available</p>	<p>Gamma isotopic analysis on edible portions.</p> <p>Gamma isotopic and I-131 analysis.</p> <p>Gamma isotopic and I-131 analysis.</p>

TABLE 3.11.4.1-2
REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES
Reporting Levels

Analysis	Water (pCi/l)	Airborne Particulate or Gases (pCi/m ³)	Fish (pCi/kg, wet)	Milk (pCi/l)	Food Products (pCi/kg, wet)
H-3	20,000 ^(a)				
Mn-54	1,000		30,000		
Fe-59	400		10,000		
Co-58	1,000		30,000		
Co-60	300		10,000		
Zn-65	300		20,000		
Zr-Nb-95	400 ^(b)				
I-131	2	0.9		3	100
Cs-134	30	10	1,000	60	1,000
Cs-137	50	20	2,000	70	2,000
Ba-La-140	200 ^(b)			300	

(a) For drinking water samples. This is 40 CFR Part 141 value. If no drinking water pathway exists, a value of 30,000 pCi/l may be used.

(b) Total for parent and daughter.

TABLE 3.11.4.1-3
DETECTION CAPABILITIES FOR ENVIRONMENTAL SAMPLE ANALYSIS
LOWER LIMIT OF DETECTION (LLD)

Analysis	Water (pCi/l)	Airborne Particulate Or Gases (pCi/m ³)	Fish (pCi/kg, wet)	Milk (pCi/l)	Food Products (pCi/kg, wet)	Sendiments (Ci/kg, dry)
Gross Beta	4	0.01				
H-3	2000					
Mn-54	15		130			
Fe-59	30		260			
Co-58, 60	15		130			
Zn-65	30		260			
Zr-95	30					
Nb-95	15					
I-131	1 ^(a)	0.07		1	60	
Cs-134	15	0.05	130	15	60	150
Cs-137	18	0.06	150	18	80	180
Ba-140	60			60		
La-140	15			15		

(a) LLD drinking water samples

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TROs TRO 3.0.1 through TRO 3.0.6 establish the general requirements applicable to all Requirements and apply at all times, unless otherwise stated.

TRO 3.0.1 TRO 3.0.1 establishes the Applicability statement within each individual Requirement as the requirement for when the TRO is required to be met (i.e., when the unit is in the MODES or other specified conditions of the Applicability statement of each Requirement).

TRO 3.0.2 TRO 3.0.2 establishes that upon discovery of a failure to meet a TRO, the associated ACTIONS shall be met. The Completion Time of each Required Action for an ACTIONS Condition is applicable from the point in time that an ACTIONS Condition is entered. The Required Actions establish those remedial measures that must be taken within specified Completion Times when the requirements of a TRO are not met. This Requirement establishes that:

- a. Completion of the Required Actions within the specified Completion Times constitutes compliance with a Requirement; and
- b. Completion of the Required Actions is not required when a TRO is met within the specified Completion Time, unless otherwise specified.

There are two basic types of Required Actions. The first type of Required Action specifies a time limit in which the TRO must be met. This time limit is the Completion Time to restore an inoperable system or component to OPERABLE status or to restore variables to within specified limits. If this type of Required Action is not completed within the specified Completion Time, a shutdown may be required to place the unit in a MODE or condition in which the Specification is not applicable.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.2
(continued)

Whether stated as a Required Action or not, correction of the entered Condition is an action that may always be considered upon entering ACTIONS. The second type of Required Action specifies the remedial measures that permit continued operation of the unit that is not further restricted by the Completion Time. In this case, compliance with the Required Actions provides an acceptable level of safety for continued operation.

Completing the Required Actions is not required when a TRO is met or is no longer applicable, unless otherwise stated in the individual Requirements.

The nature of some Required Actions of some Conditions necessitates that, once the Condition is entered, the Required Actions must be completed even though the associated Conditions no longer exist. The individual TRO's Actions specify the Required Actions where this is the case. An example of this is in Technical Requirement TRO 3.4.1, "Chemistry."

The Completion Times of the Required Actions are also applicable when a system or component is removed from service intentionally. The reasons for intentionally relying on the ACTIONS include, but are not limited to, modifications, performance of Surveillances, preventive maintenance, corrective maintenance, or investigation of operational problems. Entering ACTIONS for these or for any other reasons must be done in a manner that does not compromise safety.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.2
(continued)

Individual Requirements may specify a time limit for performing a TRS when equipment is removed from service or bypassed for testing. In this case, the Completion Times of the Required Actions are applicable when this time limit expires, if the equipment remains removed from service or bypassed.

When a change in MODE or other specified condition is required to comply with Required Actions, the unit may enter a MODE or other specified condition in which another Requirement becomes applicable. In this case, the Completion Times of the associated Required Actions would apply from the point in time that the new Requirement becomes applicable and the ACTIONS Condition(s) are entered.

TRO 3.0.3

TRO 3.0.3 establishes the actions that must be implemented when a TRO is not met and:

- a. An associated Required Action and Completion Time is not met and no other Condition applies; or
- b. The condition of the unit is not specifically addressed by the associated ACTIONS. This means that no combination of Conditions stated in the ACTIONS can be made that exactly corresponds to the actual condition of the unit. Certain combinations of Conditions may exist such that entering TRO 3.0.3 is warranted; in such cases, the Actions specifically state a Condition corresponding to such combinations and also that TRO 3.0.3 be entered immediately.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.3
(continued) Because entry into the 3.0.3 ACTION is an escalation of the system, structure, component, or unit condition, a new Condition Report is required. The Condition Report will address plant safety given the nonconformance with the Technical Requirement. TROs which affect OPERABILITY of TS Functions will have an immediate assessment of TS OPERABILITY. Changes to the Requirement, or compensatory actions to be taken in response to the Condition are documented in the TRO or its Bases.

TRO 3.0.4 TRO 3.0.4 establishes limitations on changes in MODES or other specified conditions in the Applicability when a TRO is not met. It precludes placing the unit in a MODE or other specified condition stated in that Applicability (e.g., Applicability desired to be entered) when the following exist:

- a. Unit conditions are such that the requirements of the TRO would not be met in the Applicability desired to be entered; and
- b. Continued noncompliance with the TRO requirements, if the Applicability were entered, would result in the unit being required to exit the Applicability desired to be entered to comply with the Required Actions.

Compliance with Required Actions that permit continued operation of the unit for an unlimited period of time in a MODE or other specified condition provides an acceptance level of safety for continued operation. This is without regard to the status of the unit before or after the MODE change. Therefore, in such cases, entry into a MODE or other specified condition in the Applicability may be made in accordance with the provisions of the Required Actions. The provisions of this Requirement should not be interpreted as endorsing the failure to exercise the good practice of restoring systems or components to OPERABLE status before entering an associated MODE or other specified condition in the Applicability.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASESTRO 3.0.4
(continued)

The provisions of TRO 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS. In addition, the provisions of TRO 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that result from any unit shutdown.

TRO 3.0.4 is not applicable to TROs that are identified as APPLICABLE "At all times." This term is considered to constitute one inclusive operating condition that corresponds to and encompasses all MODES as defined in the Technical Specification, as well as all special operating conditions, including when the reactor vessel is defueled. Entry into any MODE or other special condition is done within the context of "all times," and, therefore, is not a change within the Applicability to which TRO 3.0.4 applies.

Other exceptions to TRO 3.0.4 are stated in the individual Requirements. Exceptions may apply to all the ACTIONS or to a specific Required Action of a Requirement. TRO 3.0.4 is only applicable when entering MODE 3 from MODE 4, MODE 2 from MODE 3 or 4, or MODE 1 from MODE 2. Furthermore, TRO 3.0.4 is applicable when entering any other specified condition in the Applicability only while operating in MODE 1, 2, or 3. The requirements of TRO 3.0.4 do not apply in MODES 4 and 5, or in other specified conditions of the Applicability (unless in MODE 1, 2, or 3) because the ACTIONS of individual Requirements sufficiently define the remedial measures to be taken.

Surveillances do not have to be performed on the associated inoperable equipment (or on variables outside the specified limits), as permitted by TRS 3.0.1. Therefore, changing MODES or other specified conditions while in an ACTIONS Condition, either in compliance with TRO 3.0.4 or where an

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.4
(continued) exception to TRO 3.0.4 is stated, is not a violation of TRS 3.0.1 or TRS 3.0.4 for those surveillances that do not have to be performed due to the associated inoperable equipment. However, TRSs must be met to ensure OPERABILITY prior to declaring the associated equipment OPERABLE (or variable within limits) and restoring compliance with the affected TRO.

TRO 3.0.5 TRO 3.0.5 establishes the allowance for restoring equipment to service under administrative controls when it has been removed from service or declared inoperable to comply with ACTIONS. The sole purpose of this Requirement is to provide an exception to TRO 3.0.2 (e.g., to not comply with the applicable Required Action(s) to allow the performance of TRSs to demonstrate:

- a. The OPERABILITY of the equipment being returned to service; or
- b. The OPERABILITY of other equipment; or
- c. That variables are within limits

The administrative controls ensure the time the equipment is returned to service in conflict with the requirements of the ACTIONS is limited to the time absolutely necessary to perform the allowed TRSs. This Requirement does not provide time to perform any other preventive or corrective maintenance.

An example of demonstrating the OPERABILITY of the equipment being returned to service is reopening a containment isolation valve that has been closed to comply with Required Actions and must be reopened to perform the TRSs.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.5 (continued) An example of demonstrating the OPERABILITY of other equipment is taking an inoperable channel or trip system out of the tripped condition to prevent the trip function from occurring during the performance of a TRS on another channel in the other trip system. A similar example of appropriate response during the performance of an TRS on another channel in the same trip system.

TRO 3.0.6 TRO 3.0.6 establishes an exception to TRO 3.0.2 for support systems that have a TRO specified in the Technical Requirement Specifications (TRS). This exception is provided because TRO 3.0.2 would require that the Conditions and Required Actions of the associated inoperable supported system TRO be entered solely due to the inoperability of the support system. This exception is justified because the actions that are required to ensure the plant is maintained in a safe condition are specified in the support system TRO's Required Actions. These Required Actions may include entering the supported system's Conditions and Required Actions or may specify other Required Actions.

When a support system is inoperable and there is a TRO specified for it in the TRS, the supported system(s) are required to be declared inoperable if determined to be inoperable as a result of the support system inoperability. However, it is not necessary to enter into the supported systems' Conditions and Required Actions unless directed to do so by the support system's Required Actions. The potential confusion and inconsistency of requirements related to the entry into multiple support and supported systems' TROs' Conditions and Required Actions are eliminated by providing all the actions that are necessary to ensure the plant is maintained in a safe condition in the support system's Required Actions.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.6
(continued)

However, there are instances where a support system's Required Action may either direct a supported system to be declared inoperable or direct entry into Conditions and Required Actions for the supported system. This may occur immediately or after some specified delay to perform some other Required Action. Regardless of whether it is immediate or after some delay, when a support system's Required Action directs a supported system to be declared inoperable or directs entry into Conditions and Required Actions for a supported system, the applicable Conditions and Required Actions shall be entered in accordance with TRO 3.0.2.

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRS TRS 3.0.1 through TRS 3.0.4 establish the general requirements applicable to all Requirements and apply at all times, unless otherwise stated.

TRS 3.0.1 TRS 3.0.1 establishes the requirement that TRSs must be met during the MODES or other specified conditions in the Applicability for which the requirements of the TRO apply, unless otherwise specified in the individual TRSs. This Requirement is to ensure that Surveillances are performed to verify the OPERABILITY of systems and components, and that variables are within specified limits. Failure to meet a Surveillance within the specified Frequency, in accordance with TRS 3.0.2, constitutes a failure to meet a TRO.

Systems and components are assumed to be OPERABLE when the associated TRSs have been met. Nothing in this Requirement, however, is to be construed as implying that systems or components are OPERABLE when:

- a. The systems or components are known to be inoperable, although still meeting the TRSs; or
- b. The requirements of the Surveillance(s) are known to be not met between required Surveillance performances.

Surveillances do not have to be performed when the unit is in a MODE or other specified condition for which the requirements of the associated TRO are not applicable, unless otherwise specified.

Surveillances, including Surveillances invoked by Required Actions, do not have to be performed on inoperable equipment because the ACTIONS define the remedial measures that apply. Surveillances have to be met and performed in

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY**BASES**

**TRS 3.0.1
(continued)**

accordance with TRS 3.0.2, prior to returning equipment to OPERABLE status. Upon completion of maintenance, appropriate post maintenance testing is required to declare equipment OPERABLE. This includes ensuring applicable Surveillances are not failed and their most recent performance is in accordance with TRS 3.0.2. Post maintenance testing may not be possible in the current MODE or other specified conditions in the Applicability due to the necessary unit parameters not having been established. In these situations, the equipment may be considered OPERABLE provided testing has been satisfactorily completed to the extent possible and the equipment is not otherwise believed to be incapable of performing its function. This will allow operation to proceed to a MODE or other specified condition where other necessary post maintenance tests can be completed.

TRS 3.0.2

TRS 3.0.2 establishes the requirements for meeting the specified Frequency for Surveillances and any Required Action with a Completion Time that requires the periodic performance of the Required Action on a "once per ..." interval.

TRS 3.0.2 permits a 25% extension of the interval specified in the Frequency. This extension facilitates Surveillance scheduling and considers plant operating conditions that may not be suitable for conducting the Surveillance (e.g., transient conditions or other ongoing Surveillance or maintenance activities).

The 25% extension does not significantly degrade the reliability that results from performing the Surveillance at its specified Frequency. This is based on the recognition that the most probable result of any particular Surveillance being performed is the verification of conformance with the TRSs. The exceptions to TRS 3.0.2 are

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRO 3.0.2
(continued)

those Surveillances for which the 25% extension of the interval specified in the Frequency does not apply. These exceptions are stated in the individual Requirements. As stated in TRS 3.0.2, the 25% extension also does not apply to the initial portion of a periodic Completion Time that requires performance on a "once per ..." basis. The 25% extension applies to each performance after the initial performance. The initial performance of the Required Action, whether it is a particular Surveillance or some other remedial action, is considered a single action with a single Completion Time. One reason for not allowing the 25% extension to this Completion Time is that such an action usually verifies that no loss of function has occurred by checking the status of redundant or diverse components or accomplishes the function of the inoperable equipment in an alternative manner.

The provisions of TRS 3.0.2 are not intended to be used repeatedly merely as an operational convenience to extend Surveillance intervals (other than those consistent with refueling intervals) or periodic Completion Time intervals beyond those specified.

TRS 3.0.3

TRS 3.0.3 establishes the flexibility to defer declaring affected equipment inoperable or an affected variable outside the specified limits when a Surveillance has not been completed within the specified Frequency. A delay period of up to 24 hours or up to the limit of the specified Frequency, whichever is greater, applies from the point in time that it is discovered that the Surveillance has not been performed in accordance with TRS 3.0.2, and not at the time that the specified Frequency was not met.

If a Surveillance cannot be performed within its specified Frequency due to unusual conditions, such as a structure, system, or component configuration that prevents performance of a test, or performance of the test would have an adverse impact on plant risk, compliance with the requirement to declare the TRO not met may be delayed. This delay period starts at the expiration of the current Surveillance test interval. The delay can be up to 24 hours or up to the limit of the specified Frequency, whichever is greater.

This delay period provides adequate time to complete Surveillances that have been missed. This delay period permits the completion of a Surveillance before complying with Required Actions or other remedial measures that might preclude completion of the Surveillance.

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRS 3.0.3
(continued)

The basis for this delay period includes consideration of unit conditions, adequate planning, availability of personnel, the time required to perform the Surveillance, the safety significance of the delay in completing the required Surveillance, and the recognition that the most probable result of any particular Surveillance being performed is the verification of conformance with the requirements.

When a Surveillance with a Frequency based not on time intervals, but upon specified unit conditions, operating situations, or requirements of regulations (e.g., prior to entering MODE 1 after each fuel loading, or in accordance with 10 CFR 50, Appendix J, as modified by approved exemptions, etc.) is discovered to not have been performed when specified, TRS 3.0.3 allows for the full delay period of up to the specified Frequency to perform the Surveillance. However, since there is not a time interval specified, the missed Surveillance should be performed at the first reasonable opportunity.

TRS 3.0.3 provides a time limit for, and allowances for the performance of, Surveillances that become applicable as a consequence of MODE changes imposed by Required Actions.

Failure to comply with specified Frequencies for TRSs is expected to be an infrequent occurrence. Use of the delay period established by TRS 3.0.3 is a flexibility which is not intended to be used as an operational convenience to extend Surveillance intervals. While up to 24 hours or the limit of the specified Frequency is provided to perform the missed Surveillance, it is expected that the missed Surveillance will be performed at the first reasonable opportunity. The determination of the first reasonable opportunity should include consideration of the impact on plant risk (from delaying the Surveillance as well as any plant configuration changes required or shutting the plant down to perform the Surveillance) and impact on any analysis assumptions, in addition to unit conditions, planning, availability of

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASESTRS 3.0.3
(continued)

personnel, and the time required to perform the Surveillance. This risk impact should be managed through the program in place to implement 10 CFR 50.65(a)(4) and its implementation guidance, NRC Regulatory Guide 1.182, "Assessing and Managing Risk Before Maintenance Activities at Nuclear Power Plants." This Regulatory Guide addresses consideration of temporary and aggregate risk impacts, determination of risk management action thresholds, and risk management action up to and including plant shutdown. The missed Surveillance should be treated as an emergent condition as discussed in the Regulatory Guide. The risk evaluation may use quantitative, qualitative, or blended methods. The degree of depth and rigor of the evaluation should be commensurate with the importance of the component. Missed Surveillances for important components should be analyzed quantitatively. If the results of the risk evaluation determine the risk increase is significant, this evaluation should be used to determine the safest course of action. All Surveillances who's Frequency has been extended in accordance with TRS 3.0.3 will be placed in the Corrective Action Program.

If a Surveillance is not completed within the allowed delay period, then the equipment is considered inoperable or the variable is considered outside the specified limits and the Completion Times of the Required Actions for the applicable TRO Conditions begin immediately upon expiration of the delay period. If a Surveillance is failed within the delay period, then the equipment is inoperable, or the variable is outside the specified limits and the Completion Times of the Required Actions for the applicable TRO Conditions begin immediately upon the failure of the Surveillance.

Completion of the Surveillance within the delay period allowed by this Requirement, or within the Completion Time of the ACTIONS, restores compliance with TRS 3.0.1.

Exceptions to TRS 3.0.3 are provided in instances where requiring equipment to be considered inoperable, in accordance with TRS 3.0.3, would not provide appropriate remedial measures for the associated condition. An example of this is in TRO 3.11.4.1, "Radiological Environmental Monitoring." TRO 3.11.4.1 has surveillances that implement required environmental sampling and analysis. If a portion of the sampling or analysis is not completed as required, the programmatic response is to report the condition to the Nuclear Regulatory Commission and in most instances describe the corrective actions taken to correct the condition. There are no result

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRS 3.0.3
(continued) thresholds built into the monitoring and analysis program that would result in declaring equipment inoperable or in a plant shutdown. Therefore, it is appropriate that the provisions of TRO 3.0.3 be waived for this TRO. These exceptions are addressed in the individual Requirements.

TRS 3.0.4 TRS 3.0.4 establishes the requirement that all applicable TRSs must be met before entry into a MODE or other specified condition in the Applicability. This Requirement ensures that system and component OPERABILITY requirements and variable limits are met before entry into MODES or other specified conditions in the Applicability for which these systems and components ensure safe operation of the unit.

The provisions of this Requirement should not be interpreted as endorsing the failure to exercise the good practice of restoring systems or components to OPERABLE status before entering an associated MODE or other specified condition in the Applicability.

However, in certain circumstances, failing to meet a TRS will not result in TRS 3.0.4 restricting a MODE change or other specified condition change. When a system, subsystem, division, component, device, or variable is inoperable or outside its specified limits, the associated TRS(s) are not required to be performed per TRS 3.0.1, which states that Surveillances do not have to be performed on inoperable equipment. When equipment is inoperable, TRS 3.0.4 does not apply to the associated TRS(s) since the requirement for the TRS(s) to be performed is removed. Therefore, failing to perform the Surveillance(s) within the specified Frequency does not result in an TRS 3.0.4 restriction to changing MODES or other specified conditions of the Applicability. However, since the TRO is not met in this instance, TRO 3.0.4 will govern any restrictions that may (or may not) apply to MODE or other specified condition changes. The provisions of TRS 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS. In addition, the provisions of TRO 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that result from any unit shutdown. The precise requirements for performance of TRSs are specified such that exceptions to TRS 3.0.4 are not necessary. The specific time frames and conditions necessary for meeting the TRSs are specified in the Frequency, in the Surveillance, or both.

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRS 3.0.4
(continued)

This allows performance of Surveillances when the prerequisite condition(s) specified in a Surveillance procedure require entry into the MODE or other specified condition in the Applicability of the associated TRO prior to the performance or completion of a Surveillance. A Surveillance that could not be performed until after entering the TRO Applicability would have its Frequency specified such that it is not "due" until the specific conditions needed are met. Alternately, the Surveillance may be stated in the form of a Note as not required (to be met or performed) until a particular event, condition, or time has been reached. Further discussion of the specific formats of TRS's annotation is found in Section 1.4, Frequency.

TRS 3.0.4 is only applicable when entering MODE 3 from MODE 4, MODE 2 from MODE 3 or 4, or MODE 1 from MODE 2. Furthermore, TRS 3.0.4 is applicable when entering any other specified condition in the Applicability only while operating in MODE 1, 2, or 3. The requirements of TRS 3.0.4 do not apply in MODES 4 and 5, or in other specified conditions of the Applicability (unless in MODE 1, 2, or 3) because the ACTIONS of individual Requirements sufficiently define the remedial measures to be taken.

B 3.11.4.1 Monitoring Program

BASES

TRO The radiological environmental monitoring program required by this Requirement provides representative measurements of radiation and of radioactive materials in those environmental exposure pathways and for those radionuclides that lead to the highest potential radiation exposures of MEMBERS OF THE PUBLIC resulting from the station operation. This monitoring program thereby supplements the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and modeling of the environmental exposure pathways. Changes to the radiological environmental monitoring program specified in Table 3.11.4.1-1 may be made based on expected SSES operation and the results of radiological environmental monitoring during SSES operation.

The required detection capabilities for environmental sample analyses are tabulated in terms of the lower limits of detection (LLDs). The LLDs required by Table 3.11.4.1-3 are considered optimum for routine environmental measurements in industrial laboratories. It should be recognized that the LLD is defined as an *a priori* (before the fact) limit representing the capability of a measurement system and not as an *a posteriori* (after the fact) limit for a particular measurement.

Detailed discussion of the LLD, and other detection limits, can be found in HASL Procedures Manual, HASL-300 (revised annually); Currie, L. A., "Limits for Qualitative Detection and Quantitative Determination - Application to Radiochemistry" Anal. Chem. 40, 586-93 (1968); and Hartwell, J. K., "Detection Limits for Radioanalytical Counting Techniques," Atlantic Richfield Hanford Company Report ARH-SA-215 (June 1975). (Reference 1)

This section of the TRM is also part of the ODCM (Reference 2).

ACTIONS The Actions are defined to ensure proper corrective measures are taken when requirements are not met. Once a Condition Report is generated (per the applicable Action), the TRO may be exited because at that time, the Condition that caused the TRO is no longer out of compliance with the program.

(continued)

B 3.11.4.1 Monitoring Program

BASESACTIONS
(continued)

Per Action A. 1, the Annual Radiological Environmental Operating Report shall provide a description of the reasons for not conducting the program as required and the plans for preventing a recurrence.

The Special Report submitted per Action B.1 shall identify the cause(s) for exceeding the limit(s) and define the corrective actions to be taken to reduce radioactive effluents so that the potential annual dose to a MEMBER OF THE PUBLIC is less than the calendar year limits of Requirements 3.11.1.2, 3.11.2.2 and 3.11.2.3.

Include revised figure(s) and table for the ODCM reflecting the new locations for obtaining samples per Action F.1 in the next Radioactive Effluent Release Report.

TRS

The TRSs are defined to be performed at the specified frequency to ensure that the requirements are implemented. Monitoring samples collected per TRS 3.11.4.1.1 shall be from the specific locations given in the table and figure in the ODCM. (Reference 2)

The TRSs are modified by a Note to take exception to TRS 3.0.3.

Table 3.11.4.1-1

Sample Locations Specific parameters of distance and direction sector from the centerline of one reactor, and additional description where pertinent, shall be provided for each and every sample location in this Table and in a table and figure(s) in the ODCM. Refer to NUREG-0133, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants," October 1978, and to Radiological Assessment Branch Technical Position, Revision 1, November 1979. (Reference 3) Deviations are permitted from the required sampling schedule if specimens are unobtainable due to hazardous conditions, seasonal unavailability, malfunction of automatic sampling equipment and other legitimate reasons. If specimens are unobtainable due to sampling equipment malfunction, every effort shall be made to complete corrective action prior to the end of the next sampling

(continued)

B 3.11.4.1 Monitoring Program

BASESTRS
(continued)

period. All deviations from the sampling schedule shall be documented in the Annual Radiological Environmental Operating Report. It is recognized that, at times, it may not be possible or practicable to continue to obtain samples of the media of choice at the most desired location or time.

In these instances suitable alternative media and locations may be chosen for the particular pathway in question and appropriate substitutions made within 30 days in the radiological environmental monitoring program. Identify the cause of the unavailability of samples for that pathway and identify the new location(s) for obtaining replacement samples in the next Radioactive Effluent Release Report and also include in the report a revised figure(s) and table for the ODCM reflecting the new location(s).

Direct Radiation One or more instruments, such as a pressurized ion chamber, for measuring and recording dose rate continuously may be used in place of, or in addition to, integrating dosimeters. For the purposes of this table, a thermoluminescent dosimeter (TLD) is considered to be one phosphor; two or more phosphors in a packet are considered as two or more dosimeters. Film badges shall not be used as dosimeters for measuring direct radiation.

Radioiodine and Particulates - Sampling and Collection Frequency

The charcoal cartridges used in the airborne radioiodine sampling conducted as part of the radiological environmental monitoring program are designed and tested by the manufacturer to assure a high efficiency in the capture of radioiodine. Certificates from the manufacturer of the cartridges are provided with each batch of cartridges certifying the percent retention of the radiodine for stated air flows.

Radioiodine and Particulates - Particulate Sample: Waterborne -Surface, Ground, Sediment; Food Products Gamma isotopic analysis means the identification and quantification of gamma-emitting radionuclides that may be attributable to the effluents from the facility.

Waterborne - Surface The "upstream sample" shall be taken at a distance beyond significant influence of the discharge. The "downstream" sample shall be taken in the discharge line.

(continued)

B 3.11.4.1 Monitoring Program

BASES

TRS
(continued)

Waterborne - Drinking - Sampling and Collection Frequency A composite sample is one in which the quantity (aliquot) of liquid sampled is proportional to the quantity of flowing liquid and in which the method of sampling employed results in a specimen that is representative of the liquid flow. In this program composite samples shall be collected at time intervals that are very short (e.g., hourly) relative to the compositing period (e.g., monthly) in order to assure obtaining a representative sample.

Waterborne - Ground - Samples and Sample Locations Groundwater samples shall be taken when this source is tapped for drinking or irrigation purposes in areas where the hydraulic gradient or recharge properties are suitable for contamination.

Drinking Water - I-131 Analyses Calculation of the dose projected from I-131 in drinking water to determine if I-131 analyses of the water are required shall be performed for the maximum organ and age group using the methodology and parameters of the ODCM.

Food Products - Sampling and Collection Frequency If harvest occurs more than once a year, sampling shall be performed during each discrete harvest. If harvest occurs continuously, sampling shall be monthly. Attention shall be paid to including samples of tuborous and root food products.

Table 3.11.4.1-3

This list does not mean that only these nuclides are to be considered. Other peaks that are identifiable at 95% confidence level together with those of the above nuclides, shall also be analyzed and reported in the Annual Radiological Environmental Operating report.

Required detection capabilities for thermoluminescent dosimeters used for environmental measurements are given in Regulatory Guide 4.13.
(Reference 4)

(continued)

B 3.11.4.1 Monitoring Program

BASES

TRS
(continued)

The LLD is defined, for purpose of these Requirements, as the smallest concentration of radioactive material in a sample that will yield a net count (above system background) that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66s_b}{E \cdot V \cdot 2.22 \cdot Y \cdot \exp(-\lambda\Delta t)}$$

Where:

LLD is the *a priori* lower limit of detection as defined above (as picocuries per unit mass or volume),

s_b is the standard deviation of the background counting rate or of the countingrate of a blank sample as appropriate (as counts per minute),

E is the counting efficiency, as counts per disintegration,

V is the sample size, in units of mass or volume,

2.22 is the number of disintegrations per minute per picocurie,

Y is the fractional radiochemical yield, when applicable,

λ is the radioactive decay constant for the particular radionuclide, and

Δt for environmental samples is the elapsed time between sample collection (or end of the sample collection period) and time of counting.

Typical values of E, V, Y, and Δt should be used in the calculation.

(continued)

B 3.11.4.1 Monitoring Program

BASES

TRS
(continued)

It should be recognized that the LLD is defined as a *priori* (before the fact) limit representing the capability of a measurement system and not as an a *posteriori* (after the fact) limit for a particular measurement. Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDS unachievable. In such cases, the contributing factors shall be identified and described in the Annual Radiological Environmental Operating Report.

REFERENCES

1. HASL Procedures Manual, HASL-300 (revised annually); Curie, L.A., "Limits for Qualitative Detection and Quantitative Determination - Application to Radiochemistry" Anal. Chem. 40, 586-93 (1968); and Hartwell, J. K., "Detection Limits for Radioanalytical Counting Techniques," Atlantic Richfield Hanford Company Report ARH-SA-215 (June 1975) Offsite Dose Calculation Manual.
 2. Technical Specification 5.5.1 - Offsite Dose Calculation Manual
 3. NUREG-0133, "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants," October 1978, and to Radiological Assessment Branch Technical Position, Revision 1, November 1979.
 4. Regulatory Guide 4.13
-