

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.11 Verify the combined leakage rate for all secondary containment bypass leakage paths that are not provided with a seal system is $\leq 0.10 L$ when pressurized to ≥ 56.5 psig.</p>	<p>In accordance with the Primary Containment Leakage Rate Testing Program and Inservice Testing Program</p>
<p>SR 3.6.1.3.12 Verify combined MSIV leakage rate for all four main steam lines is ≤ 250 scfh and ≤ 100 scfh for any one steam line when tested at ≥ 25 psig.</p>	<p>In accordance with the Primary Containment Leakage Rate Testing Program</p>
<p>SR 3.6.1.3.13 -NOTE-..... Only required to be met in MODES 1, 2, and 3.</p> <p>Verify combined leakage rate through hydrostatically tested lines that penetrate the primary containment is within limits.</p>	<p>In accordance with the Primary Containment Leakage Rate Testing Program</p>