

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.4.1 Determine OPERABLE EDG(s) are not inoperable due to common cause failure.	24 hours
	<u>OR</u>	
	A.4.2 Perform SR 3.8.1.2 for OPERABLE EDG(s).	24 hours
	<u>AND</u>	
	A.5 Restore availability of CTG 11-1.	72 hours from discovery of Condition A concurrent with CTG 11-1 not available
	<u>AND</u>	
	A.6 Restore both EDGs in the division to OPERABLE status.	7 days <u>AND</u> 10 days from discovery of failure to meet LCO
B. One or both EDGs in both divisions inoperable.	B.1 Restore both EDGs in one division to OPERABLE status.	2 hours
C. One offsite circuit inoperable.	C.1 Perform SR 3.8.1.1 for OPERABLE offsite circuit.	1 hour <u>AND</u> Once per 8 hours thereafter
	<u>AND</u>	(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.2 Declare required feature(s) with no offsite power available inoperable when the redundant required feature(s) are inoperable.	24 hours from discovery of no offsite power to one division concurrent with inoperability of redundant required feature(s)
	<u>AND</u> C.3 Restore offsite circuit to OPERABLE status.	72 hours <u>AND</u> 10 days from discovery of failure to meet LCO
D. Two offsite circuits inoperable.	D.1 Declare required feature(s) inoperable when the redundant required feature(s) are inoperable.	12 hours from discovery of Condition D concurrent with inoperability of redundant required feature(s)
	<u>AND</u> D.2 Restore one offsite circuit to OPERABLE status.	24 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. One offsite circuit inoperable.</p> <p><u>AND</u></p> <p>One or both EDGs in one Division inoperable.</p>	<p>-----NOTE-----</p> <p>Enter applicable Conditions and Required Actions of LCO 3.8.7, "Distribution Systems - Operating," when Condition E is entered with no AC power source to one or more 4160 V buses 64B, 64C, 65E or 65F.</p> <p>-----</p>	
	<p>E.1 Restore offsite circuit to OPERABLE status.</p>	12 hours
	<p><u>OR</u></p> <p>E.2 Restore both EDGs in the Division to OPERABLE status.</p>	12 hours
<p>F. Required Action and Associated Completion Time of Condition A, B, C, D or E not met.</p>	<p>F.1 Be in MODE 3.</p>	12 hours
	<p><u>AND</u></p> <p>F.2 Be in MODE 4.</p>	36 hours