



FEB 02 2006

SERIAL: HNP-06-027

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
ANNUAL REPORT IN ACCORDANCE WITH TECHNICAL SPECIFICATION 6.9.1.2

Ladies and Gentlemen:

In accordance with Harris Nuclear Plant (HNP) Technical Specification 6.9.1.2, Carolina Power & Light Company, doing business as Progress Energy Carolinas, Inc., provides the following information regarding primary coolant specific activity limits for 2005.

During 2005, activity levels in the HNP primary coolant did not exceed 1.0 $\mu\text{Ci}/\text{gram}$ dose equivalent I-131 or 100/E-bar $\mu\text{Ci}/\text{gram}$ gross radioactivity as set forth in HNP Technical Specification 3.4.8.

If you have questions regarding this submittal, please contact me at (919) 362-3137.

Sincerely,

D. H. Corlett
Supervisor – Licensing/Regulatory Programs
Harris Nuclear Plant

DHC/mgw

~~Enclosure~~

- c: Mr. R. A. Musser (NRC Senior Resident Inspector, HNP)
- Mr. C. P. Patel (NRR Project Manager, HNP)
- Dr. W. D. Travers (NRC Regional Administrator, Region II)