

February 22, 2006

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNIT 3 AND 4 - WITHDRAWAL OF AN AMENDMENT
REQUEST REGARDING REACTOR TRIP SYSTEM TECHNICAL
SPECIFICATION CHANGES (MC6460 AND MC6461)

Dear Mr. Stall:

By letter dated March 22, 2005, Florida Power & Light applied for an amendment to the Turkey Point, Units 3 and 4, Facility Renewed Operating License Nos. DPR-31 and DPR-41, respectively. The proposed change would have modified the facility technical specifications pertaining to the Reactor Protection System functional units. Specifically, the steam/feedwater flow mismatch coincident with steam generator water level - low reactor trip would be deleted, the reactor trip on turbine trip interlock would be changed from P-7 to P-8, and the value of the P-8 interlock setpoint would be changed from 45 percent rated thermal power (RTP) to 40 percent RTP. Subsequently, by letter dated January 25, 2006, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Brendan T. Moroney, Project Manager
Project Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure: Notice of Withdrawal

cc w/encl: See next page

February 22, 2006

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNIT 3 AND 4 - WITHDRAWAL OF AN AMENDMENT
REQUEST REGARDING REACTOR TRIP SYSTEM TECHNICAL
SPECIFICATION CHANGES (MC6460 AND MC6461)

Dear Mr. Stall:

By letter dated March 22, 2005, Florida Power & Light applied for an amendment to the Turkey Point, Units 3 and 4, Facility Renewed Operating License Nos. DPR-31 and DPR-41, respectively. The proposed change would have modified the facility technical specifications pertaining to the Reactor Protection System functional units. Specifically, the steam/feedwater flow mismatch coincident with steam generator water level - low reactor trip would be deleted, the reactor trip on turbine trip interlock would be changed from P-7 to P-8, and the value of the P-8 interlock setpoint would be changed from 45 percent rated thermal power (RTP) to 40 percent RTP. Subsequently, by letter dated January 25, 2006, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Brendan T. Moroney, Project Manager
Project Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure: Notice of Withdrawal

cc w/encl: See next page

Distribution:

PUBLIC	LPL2-2 R/F	BSingal	RidsAcrcsAcnwMailCenter
YHsii	PO'Reilly	AHowe	RidsNrrDorlLpld
SMazumdar	JNakoski	RidsOgcRp	RidsNrrPMBMoroney
RidsRgn2MailCenter			

ADAMS Accession No: ML060470213

NRR-106

ORGANIZATION	LPL2-2/PM	LPL2-2/LA	LPL2-2/BC
NAME	BMoroney	BClayton	MMarshall
DATE	02/16/06	02/16/06	02/22/06

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSION

FLORIDA POWER AND LIGHT COMPANY

DOCKET NOS. 50-250 AND 50-251

NOTICE OF WITHDRAWAL OF APPLICATION FOR

AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Florida Power and Light Company (the licensee) to withdraw its March 22, 2005, application for proposed amendment to Facility Operating License Nos. DPR-31 and DPR-41 for the Turkey Point Nuclear Plant, Unit Nos. 3 and 4, located in Miami-Dade County, Florida.

The proposed amendment would have revised the Technical Specifications pertaining to the Reactor Protection System functional units. Specifically, the steam/feedwater flow mismatch coincident with steam generator water level - low reactor trip would be deleted, the reactor trip on turbine trip interlock would be changed from P-7 to P-8, and the value of the P-8 interlock setpoint would be changed from 45 percent rated thermal power (RTP) to 40 percent RTP.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on May 10, 2005 (70 FR 24651). However, by letter dated January 25, 2006, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated March 22, 2005, and the licensee's letter dated January 25, 2006, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area 01 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems

(ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams/html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by email to pdr@nrc.gov.

Dated at Rockville, Maryland, this 22nd day of February 2006.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Brendan T. Moroney, Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Mr. J. A. Stall
Florida Power and Light Company

TURKEY POINT PLANT

cc:

M. S. Ross, Managing Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Marjan Mashhadi, Senior Attorney
Florida Power & Light Company
801 Pennsylvania Avenue, NW.
Suite 220
Washington, DC 20004

Michael O. Pearce
Plant General Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

T. O. Jones, Site Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

Walter Parker
Licensing Manager
Turkey Point Nuclear Plant
9760 SW 344th Street
Florida City, FL 33035

County Manager
Miami-Dade County
111 Northwest 1 Street, 29th Floor
Miami, Florida 33128

Mark Warner, Vice President
Nuclear Operations Support
Florida Power and Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Senior Resident Inspector
Turkey Point Nuclear Plant
U.S. Nuclear Regulatory Commission
9762 SW. 344th Street
Florida City, Florida 33035

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. William A. Passetti, Chief
Department of Health
Bureau of Radiation Control
2020 Capital Circle, SE, Bin #C21
Tallahassee, Florida 32399-1741

Mr. Craig Fugate, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100