

3.2 POWER DISTRIBUTION LIMITS

3.2.1 Heat Flux Hot Channel Factor (F<sub>Q</sub>(Z))

LCO 3.2.1 F<sub>Q</sub>(Z), as approximated by F<sub>Q</sub><sup>C</sup>(Z) and F<sub>Q</sub><sup>W</sup>(Z), shall be within the limits specified in the COLR.

APPLICABILITY: MODE 1.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>-----                      - NOTE -                      Required Action A.4 shall                      be completed whenever                      this Condition is entered                      -----</p>	<p>A.1 Reduce THERMAL POWER                      ≥ 1% RTP for each 1%                      F<sub>Q</sub><sup>C</sup>(Z) exceeds limit.</p>	<p>15 minutes after                      each F<sub>Q</sub><sup>C</sup>(Z)                      determination</p>
	<u>AND</u>	
<p>A. F<sub>Q</sub><sup>C</sup>(Z) not within limit.</p>	<p>A.2 Reduce Power Range                      Neutron Flux - High trip                      setpoints ≥ 1% for each 1%                      F<sub>Q</sub><sup>C</sup>(Z) exceeds limit.</p>	<p>72 hours after each                      F<sub>Q</sub><sup>C</sup>(Z)                      determination</p>
	<u>AND</u>	
	<p>A.3 Reduce Overpower ΔT trip                      setpoints ≥ 1% for each 1%                      F<sub>Q</sub><sup>C</sup>(Z) exceeds limit.</p>	<p>72 hours after each                      F<sub>Q</sub><sup>C</sup>(Z)                      determination</p>
	<u>AND</u>	
	<p>A.4 Perform SR 3.2.1.1 and SR                      3.2.1.2.</p>	<p>Prior to increasing                      THERMAL POWER                      above the limit of                      Required Action A.1</p>

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p style="text-align: center;">-----            - NOTE -            Required Action B.4 shall            be completed whenever            this Condition is entered.            -----</p>	<p>B.1 Reduce AFD limits <math>\geq 1\%</math> for each 1% F<sub>Q</sub><sup>W</sup>(Z) exceeds limit.</p>	<p>4 hours</p>
<p>B. F<sub>Q</sub><sup>W</sup>(Z) not within limits.</p>	<p><u>AND</u></p>	
	<p>B.2 Reduce Power Range Neutron Flux - High trip setpoints <math>\geq 1\%</math> for each 1% that the maximum allowable power of the AFD limits is reduced.</p>	<p>72 hours</p>
	<p><u>AND</u></p>	
	<p>B.3 Reduce Overpower <math>\Delta T</math> trip setpoints <math>\geq 1\%</math> for each 1% that the maximum allowable power of the AFD limits is reduced.</p>	<p>72 hours</p>
	<p><u>AND</u></p>	
	<p>B.4 Perform SR 3.2.1.1 and SR 3.2.1.2.</p>	<p>Prior to increasing THERMAL POWER above the maximum allowable power of the AFD limits</p>
<p>C. Required Action and associated Completion Time not met.</p>	<p>C.1 Be in MODE 2.</p>	<p>6 hours</p>

SURVEILLANCE REQUIREMENTS

- NOTE -

During power escalation at the beginning of each cycle, THERMAL POWER may be increased until an equilibrium power level has been achieved, at which a power distribution map is obtained.

SURVEILLANCE	FREQUENCY
SR 3.2.1.1      Verify $F_Q^C(Z)$ is within limit.	Once after each refueling prior to THERMAL POWER exceeding 75% RTP  <u>AND</u>  Once within 12 hours after achieving equilibrium conditions after exceeding, by $\geq 10\%$ RTP, the THERMAL POWER at which $F_Q^C(Z)$ was last verified  <u>AND</u>  31 EFPD thereafter

SURVEILLANCE	FREQUENCY
<p>SR 3.2.1.2</p> <p style="text-align: center;">- NOTE -</p> <p>If measurements indicate that the</p> <p style="text-align: center;">maximum over z [F<sub>Q</sub><sup>C</sup>(Z) / K(Z) ]</p> <p>has increased since the previous evaluation of F<sub>Q</sub><sup>C</sup>(Z):</p> <p>a. Increase F<sub>Q</sub><sup>W</sup>(Z) by the greater of a factor of 1.02 or by an appropriate factor specified in the COLR and reverify F<sub>Q</sub><sup>W</sup>(Z) is within limits or</p> <p>b. Repeat SR 3.2.1.2 once per 7 EFPD until either</p> <p style="padding-left: 20px;">a. above is met or two successive flux maps indicate that the</p> <p style="text-align: center;">maximum over z [F<sub>Q</sub><sup>C</sup>(Z) / K(Z) ]</p> <p style="text-align: center;">has not increased.</p> <hr style="border-top: 1px dashed black;"/> <p>Verify F<sub>Q</sub><sup>W</sup>(Z) is within limit.</p>	<p>Once after each refueling prior to THERMAL POWER exceeding 75% RTP</p> <p><u>AND</u></p> <p>Once within 12 hours after achieving equilibrium conditions after exceeding, by ≥ 10% RTP, the THERMAL POWER at which F<sub>Q</sub><sup>W</sup>(Z) was last verified</p> <p><u>AND</u></p> <p>31 EFPD thereafter</p>

3.2 POWER DISTRIBUTION LIMITS

3.2.3 AXIAL FLUX DIFFERENCE (AFD)

LCO 3.2.3 The AFD in % flux difference units shall be maintained within the limits specified in the COLR.

-----  
- NOTE -  
-----

The AFD shall be considered outside limits when two or more OPERABLE excore channels indicate AFD to be outside limits.  
-----

APPLICABILITY: MODE 1 with THERMAL POWER  $\geq$  50% RTP.

ACTIONS

CONDITION		REQUIRED ACTION	COMPLETION TIME
A.	AFD not within limits.	A.1 Reduce THERMAL POWER to < 50% RTP.	30 minutes

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.2.3.1	Verify AFD within limits for each OPERABLE excore channel.	7 days

3.2 POWER DISTRIBUTION LIMITS

3.2.4 QUADRANT POWER TILT RATIO (QPTR)

LCO 3.2.4 The QPTR shall be  $\leq 1.02$ .

APPLICABILITY: MODE 1 with THERMAL POWER > 50% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. QPTR not within limit.	A.1 Reduce THERMAL POWER $\geq 3\%$ from RTP for each 1% of QPTR > 1.00.	2 hours after each QPTR determination
	<u>AND</u>	
	A.2 Determine QPTR	Once per 12 hours
	<u>AND</u>	
	A.3 Perform SR 3.2.1.1, SR 3.2.1.2 and SR 3.2.2.1.	24 hours after achieving equilibrium conditions from a THERMAL POWER reduction per Required Action A.1
	<u>AND</u>	Once per 7 days thereafter
	<u>AND</u>	
	A.4 Reevaluate safety analyses and confirm results remain valid for the duration of operation under this condition.	Prior to increasing THERMAL POWER above the limit of Required Action A.1
	<u>AND</u>	

CONDITION	REQUIRED ACTION	COMPLETION TIME
	<p>A.5</p> <p>- NOTE -</p> <p>1. Perform Required Action A.5 only after Required Action A.4 is completed.</p> <p>2. Required Action A.6 shall be completed whenever Required Action A.5 is performed</p> <p>- NOTE -</p> <p>Normalize excore detectors to restore QPTR to within limit.</p> <p><u>AND</u></p> <p>A.6</p> <p>- NOTE -</p> <p>Perform Required Action A.6 only after Required Action A.5 is completed.</p> <p>Perform SR 3.2.1.1, SR 3.2.1.2, and SR 3.2.2.1.</p>	<p>Prior to increasing THERMAL POWER above the limit of Required Action A.1</p> <p>Within 24 hours after achieving equilibrium conditions at RTP not to exceed 48 hours after increasing THERMAL POWER above the limit of Required Action A.1</p>
B. Required Action and associated Completion Time of Condition A not met.	B.1 Reduce THERMAL POWER to $\leq 50\%$ RTP.	4 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.2.4.1</p> <p style="text-align: center;">----- - NOTE - -----</p> <ol style="list-style-type: none"> <li>1. With input from one Power Range Neutron Flux channel inoperable and THERMAL POWER <math>\leq</math> 75% RTP, the remaining three power range channels can be used for calculating QPTR.</li> <li>2. SR 3.2.4.2 may be performed in lieu of this Surveillance.</li> </ol> <p style="text-align: center;">-----</p> <p>Verify QPTR is within limit by calculation.</p>	<p>7 days</p>
<p>SR 3.2.4.2</p> <p style="text-align: center;">----- - NOTE - -----</p> <p>Not required to be performed until 24 hours after input from one or more Power Range Neutron Flux channels are inoperable with THERMAL POWER &gt; 75% RTP.</p> <p style="text-align: center;">-----</p> <p>Perform SR 3.2.1.1, SR 3.2.1.2 and SR 3.2.2.1.</p>	<p>24 hours</p>



3.3 INSTRUMENTATION

3.3.1 Reactor Trip System (RTS) Instrumentation

LCO 3.3.1 The RTS instrumentation for each Function in Table 3.3.1-1 shall be OPERABLE.

APPLICABILITY: According to Table 3.3.1-1.

ACTIONS

- NOTE -

Separate Condition entry is allowed for each Function.

CONDITION		REQUIRED ACTION		COMPLETION TIME
A.	One or more Functions with one channel inoperable.  <u>OR</u>  Two source range channels inoperable.	A.1	Enter the Condition referenced in Table 3.3.1-1 for the channel(s).	Immediately
B.	As required by Required Action A.1 and referenced by Table 3.3.1-1.	B.1	Restore channel to OPERABLE status.	48 hours
C.	Required Action and associated Completion Time of Condition B not met.	C.1	Be in MODE 3.	6 hours
		<u>AND</u>		
		C.2	Initiate action to fully insert all rods.	6 hours
		<u>AND</u>		
		C.3	Place Control Rod Drive System in a condition incapable of rod withdrawal.	7 hours



CONDITION		REQUIRED ACTION		COMPLETION TIME
G.	Required Action and associated Completion Time of Condition D, E, or F is not met.	G.1	Be in MODE 3.	6 hours
H.	As required by Required Action A.1 and referenced by Table 3.3.1-1.	H.1	Restore at least one channel to OPERABLE status upon discovery of two inoperable channels.	1 hour from discovery of two inoperable channels
		<u>AND</u>		
		H.2	Suspend operations involving positive reactivity additions.	Immediately
I.	Required Action and associated Completion Time of Condition H not met.	<u>AND</u>		
		H.3	Restore channel to OPERABLE status.	48 hours
		I.1	Initiate action to fully insert all rods.	Immediately
J.	As required by Required Action A.1 and referenced by Table 3.3.1-1.	I.2	Place the Control Rod Drive System in a condition incapable of rod withdrawal.	1 hour
		J.1	Suspend operations involving positive reactivity additions.	Immediately
		<u>AND</u>		
		J.2	Perform SR 3.1.1.1.	12 hours
		<u>AND</u>		
				Once per 12 hours thereafter

CONDITION		REQUIRED ACTION	COMPLETION TIME
K.	As required by Required Action A.1 and referenced by Table 3.3.1-1.	<p>K.1</p> <p>----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels. -----</p> <p>Place channel in trip.</p>	6 hours
L.	Required Action and associated Completion Time of Condition K not met.	L.1 Reduce THERMAL POWER to < 8.5% RTP.	6 hours
M.	As required by Required Action A.1 and referenced by Table 3.3.1-1.	<p>M.1</p> <p>----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels. -----</p> <p>Place channel in trip.</p>	6 hours
N.	As required by Required Action A.1 and referenced by Table 3.3.1-1.	N.1 Restore channel to OPERABLE status.	6 hours
O.	Required Action and associated Completion Time of Condition M or N not met.	O.1 Reduce THERMAL POWER to < 50% RTP.	6 hours
P.	As required by Required Action A.1 and referenced by Table 3.3.1-1.	<p>P.1</p> <p>----- - NOTE - The inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels. -----</p> <p>Place channel in trip.</p>	6 hours

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>Q. Required Action and Associated Completion Time of Condition P not met.</p>	<p>Q.1 Reduce THERMAL POWER to &lt; 50% RTP.</p> <p><u>AND</u></p> <p>Q.2.1 Verify Steam Dump System is OPERABLE.</p> <p><u>OR</u></p> <p>Q.2.2 Reduce THERMAL POWER to &lt; 8% RTP.</p>	<p>6 hours</p> <p>7 hours</p> <p>7 hours</p>
<p>R. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>R.1</p> <p>----- - NOTE - One train may be bypassed for up to 4 hours for surveillance testing provided the other train is OPERABLE. -----</p> <p>Restore train to OPERABLE status.</p>	<p>6 hours</p>
<p>S. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>S.1 Verify interlock is in required state for existing plant conditions.</p> <p><u>OR</u></p> <p>S.2 Declare associated RTS Function channel(s) inoperable.</p>	<p>1 hour</p> <p>1 hour</p>

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>T. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>T.1</p> <p style="text-align: center;">----- - NOTE - -----</p> <p>1. One train may be bypassed for up to 2 hours for surveillance testing, provided the other train is OPERABLE.</p> <p>2. One RTB may be bypassed for up to 6 hours for maintenance on undervoltage or shunt trip mechanisms, provided the other train is OPERABLE.</p> <p style="text-align: center;">-----</p> <p>Restore train to OPERABLE status.</p>	<p>1 hour</p>
<p>U. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>U.1 Restore at least one trip mechanism to OPERABLE status upon discovery of two RTBs with inoperable trip mechanisms.</p> <p><u>AND</u></p> <p>U.2 Restore trip mechanism to OPERABLE status.</p>	<p>1 hour from discovery of two inoperable trip mechanisms</p> <p>48 hours</p>
<p>V. Required Action and associated Completion Time of Condition R, S, T, or U not met.</p>	<p>V.1 Be in MODE 3.</p>	<p>6 hours</p>
<p>W. As required by Required Action A.1 and referenced by Table 3.3.1-1.</p>	<p>W.1 Restore at least one trip mechanism to OPERABLE status upon discovery of two RTBs with inoperable trip mechanisms.</p> <p><u>AND</u></p>	<p>1 hour from discovery of two inoperable trip mechanisms</p>

CONDITION		REQUIRED ACTION	COMPLETION TIME
		W.2 Restore trip mechanism or train to OPERABLE status.	48 hours
X.	Required Action and associated Completion Time of Condition W not met.	X.1 Initiate action to fully insert all rods.	Immediately
		<u>AND</u>	
		X.2 Place the Control Rod Drive System in a Condition incapable of rod withdrawal.	1 hour

SURVEILLANCE REQUIREMENTS

- NOTE -

Refer to Table 3.3.1-1 to determine which SRs apply for each RTS Function.

SURVEILLANCE		FREQUENCY
SR 3.3.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.1.2	<p>- NOTE -</p> <p>Required to be performed within 12 hours after THERMAL POWER is <math>\geq 50\%</math> RTP.</p> <p>Compare results of calorimetric heat balance calculation to Nuclear Instrumentation System (NIS) channel output and adjust if calorimetric power is <math>&gt; 2\%</math> higher than indicated NIS power.</p>	24 hours
SR 3.3.1.3	<p>- NOTE -</p> <ol style="list-style-type: none"> <li>Required to be performed within 7 days after THERMAL POWER is <math>\geq 50\%</math> RTP but prior to exceeding 90% RTP following each refueling and if the Surveillance has not been performed within the last 31 EFPD.</li> <li>Performance of SR 3.3.1.6 satisfies this SR.</li> </ol> <p>Compare results of the incore detector measurements to NIS AFD and adjust if absolute difference is <math>\geq 3\%</math>.</p>	31 effective full power days (EFPD)

SURVEILLANCE		FREQUENCY
SR 3.3.1.4	Perform TADOT.	31 days on a STAGGERED TEST BASIS
SR 3.3.1.5	Perform ACTUATION LOGIC TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.1.6	<p>-----            - NOTE -            Not required to be performed until 7 days after THERMAL POWER is <math>\geq</math> 50% RTP, but prior to exceeding 90% RTP following each refueling.            -----</p> <p>Calibrate excore channels to agree with incore detector measurements.</p>	92 EFPD
SR 3.3.1.7	<p>-----            - NOTE -            Not required to be performed for source range instrumentation prior to entering MODE 3 from MODE 2 until 4 hours after entering MODE 3.            -----</p> <p>Perform COT.</p>	92 days
SR 3.3.1.8	<p>-----            - NOTE -            1. Not required for power range and intermediate range instrumentation until 4 hours after reducing power &lt; 6% RTP.            2. Not required for source range instrumentation until 4 hours after reducing power &lt; 5E-11 amps.            -----</p> <p>Perform COT.</p>	92 days
SR 3.3.1.9	<p>-----            - NOTE -            Setpoint verification is not required.            -----</p> <p>Perform TADOT.</p>	92 days



SURVEILLANCE		FREQUENCY
SR 3.3.1.10	<p>-----                      - NOTE -                      Neutron detectors are excluded.                      -----</p> <p>Perform CHANNEL CALIBRATION.</p>	24 months
SR 3.3.1.11	Perform TADOT.	24 months
SR 3.3.1.12	<p>-----                      - NOTE -                      Setpoint verification is not required.                      -----</p> <p>Perform TADOT.</p>	Prior to reactor startup if not performed within previous 31 days
SR 3.3.1.13	Perform COT.	24 months

Table 3.3.1-1  
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
1. Manual Reactor Trip	1, 2, 3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	2	B,C	SR 3.3.1.11	NA
2. Power Range Neutron Flux					
a. High	1, 2	4	D,G	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.10	≤ 112.27% RTP
b. Low	1 <sup>(c)</sup> , 2	4	D,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.10	≤ 29.28% RTP
3. Intermediate Range Neutron Flux	1 <sup>(c)</sup> , 2	2	E,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.10	(d)
4. Source Range Neutron Flux	2 <sup>(e)</sup>	2	F,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.10	(d)
	3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	2	H,I	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	(d)
	3 <sup>(f)</sup> , 4 <sup>(f)</sup> , 5 <sup>(f)</sup>	1	J	SR 3.3.1.1 SR 3.3.1.10	NA
5. Overtemperature ΔT	1, 2	4	D,G	SR 3.3.1.1 SR 3.3.1.3 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.10	Refer to Note 1
6. Overpower ΔT	1, 2	4	D,G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	Refer to Note 2

Table 3.3.1-1  
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
7. Pressurizer Pressure					
a. Low	1(g)	4	K,L	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 1791.3 psig
b. High	1, 2	3	D,G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≤ 2396.2 psig
8. Pressurizer Water Level-High	1, 2	3	D,G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≤ 96.47%
9. Reactor Coolant Flow-Low					
a. Single Loop	1(h)	3 per loop	M,O	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 89.86%
b. Two Loops	1(i)	3 per loop	K,L	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 89.86%
10. Reactor Coolant Pump (RCP) Breaker Position					
a. Single Loop	1(h)	1 per RCP	N,O	SR 3.3.1.11	NA
b. Two Loops	1(i)	1 per RCP	K,L	SR 3.3.1.11	NA
11. Undervoltage- Bus 11A and 11B	1(g)	2 per bus	K,L	SR 3.3.1.9 SR 3.3.1.10	(d)
12. Underfrequency- Bus 11A and 11B	1(g)	2 per bus	K,L	SR 3.3.1.9 SR 3.3.1.10	≥ 57.5 HZ

Table 3.3.1-1  
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
13. Steam Generator (SG) Water Level- Low Low	1, 2	3 per SG	D,G	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≥ 13.88%
14. Turbine Trip					
a. Low Autostop Oil Pressure	1 <sup>(k)(l)</sup>	3	P,Q	SR 3.3.1.10 SR 3.3.1.12	(d)
b. Turbine Stop Valve Closure	1 <sup>(k)(l)</sup>	2	P,Q	SR 3.3.1.12	NA
15. Safety Injection (SI) Input from Engineered Safety Feature Actuation System (ESFAS)	1, 2	2	R,V	SR 3.3.1.11	NA

Table 3.3.1-1  
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	LIMITING SAFETY SYSTEM SETTINGS <sup>(a)</sup>
16. Reactor Trip System Interlocks					
a. Intermediate Range Neutron Flux, P-6	2 <sup>(e)</sup>	2	S,V	SR 3.3.1.10 SR 3.3.1.13	≥ 5E-11 amp
b. Low Power Reactor Trips Block, P-7	1 <sup>(g)</sup>	4 (power range only)	S,V	SR 3.3.1.10 SR 3.3.1.13	≤ 8.0% RTP
c. Power Range Neutron Flux, P-8	1 <sup>(h)</sup>	4	S,V	SR 3.3.1.10 SR 3.3.1.13	≤ 49.0% RTP
d. Power Range Neutron Flux, P-9	1 <sup>(l)</sup>	4	S,V	SR 3.3.1.10 SR 3.3.1.13	≤ 50.0% RTP
	1 <sup>(k)</sup>	4	S,V	SR 3.3.1.10 SR 3.3.1.13	≤ 8.0% RTP
e. Power Range Neutron Flux, P-10	1 <sup>(c)</sup> , 2	4	S,V	SR 3.3.1.10 SR 3.3.1.13	≥ 6.0% RTP
17. Reactor Trip Breakers <sup>(m)</sup>	1, 2 3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	2 trains 2 trains	T,V W,X	SR 3.3.1.4 SR 3.3.1.4	NA NA
18. Reactor Trip Breaker Undervoltage and Shunt Trip Mechanisms	1, 2 3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	1 each per RTB 1 each per RTB	U,V W,X	SR 3.3.1.4 SR 3.3.1.4	NA NA
19. Automatic Trip Logic	1, 2 3 <sup>(b)</sup> , 4 <sup>(b)</sup> , 5 <sup>(b)</sup>	2 trains 2 trains	R,V W,X	SR 3.3.1.5 SR 3.3.1.5	NA NA

(a)

A channel is OPERABLE when both of the following conditions are met:

1. The absolute difference between the as-found Trip Setpoint (TSP) and the previous as-left TSP is within the COT Acceptance Criteria. The COT Acceptance Criteria is defined as:

$$|\text{as-found TSP} - \text{previous as-left TSP}| \leq \text{COT uncertainty}$$

The COT uncertainty shall not include the calibration tolerance.

2. The as-left TSP is within the established calibration tolerance band about the nominal TSP. The nominal TSP is the desired setting and shall not exceed the Limiting Safety System Setting (LSSS). The LSSS and the established calibration tolerance band are defined in accordance with the Ginna Instrument Setpoint Methodology. The channel is considered operable even if the as-left TSP is non-conservative with respect to the LSSS provided that the as-left TSP is within the established calibration tolerance band.

- (b) With Control Rod Drive (CRD) System capable of rod withdrawal or all rods not fully inserted.
- (c) THERMAL POWER < 6% RTP.
- (d) UFSAR Table 7.2-3.
- (e) Both Intermediate Range channels < 5E-11 amps.
- (f) With CRD System incapable of withdrawal and all rods fully inserted. In this condition, the Source Range Neutron Flux function does not provide a reactor trip, only indication.
- (g) THERMAL POWER  $\geq$  8.5% RTP.
- (h) THERMAL POWER  $\geq$  50% RTP.
- (i) THERMAL POWER  $\geq$  8.5% RTP and Reactor Coolant Flow-Low (Single Loop) trip Function blocked.
- (j) THERMAL POWER  $\geq$  8.5% RTP and RCP Breaker Position (Single Loop) trip Function blocked.
- (k) THERMAL POWER > 8% RTP, and either no circulating water pump breakers closed, or condenser vacuum  $\leq$  20".
- (l) THERMAL POWER  $\geq$  50% RTP, 1 of 2 circulating water pump breakers closed, and condenser vacuum > 20".
- (m) Including any reactor trip bypass breakers that are racked in and closed for bypassing an RTB.

Table 3.3.1-1 (Note 1)  
Overtemperature  $\Delta T$

- NOTE -

The Overtemperature  $\Delta T$  Function Limiting Safety System Setting is defined by:

$$\text{Overtemperature } \Delta T \leq \Delta T_0 \{K_1 + K_2 (P-P') - K_3 (T-T') [(1+\tau_1 s) / (1+\tau_2 s)] - f_1(\Delta I)\}$$

Where:

$\Delta T$  is measured RCS  $\Delta T$ , °F.

$\Delta T_0$  is the indicated  $\Delta T$  at RTP, °F.

$s$  is the Laplace transform operator,  $\text{sec}^{-1}$ .

$T$  is the measured RCS average temperature, °F.

$T'$  is the nominal  $T_{\text{avg}}$  at RTP, °F.

$P$  is the measured pressurizer pressure, psig.

$P'$  is the nominal RCS operating pressure, psig.

$K_1$  is the Overtemperature  $\Delta T$  reactor trip setpoint, [\*].

$K_2$  is the Overtemperature  $\Delta T$  reactor trip depressurization setpoint penalty coefficient, [\*]/psi.

$K_3$  is the Overtemperature  $\Delta T$  reactor trip heatup setpoint penalty coefficient, [\*]/°F.

$\tau_1$  is the measured lead time constant, [\*] seconds.

$\tau_2$  is the measured lag time constant, [\*] seconds.

$f(\Delta I)$  is a function of the indicated difference between the top and bottom detectors of the Power Range Neutron Flux channels where  $q_t$  and  $q_b$  are the percent power in the top and bottom halves of the core, respectively, and  $q_t + q_b$  is the total THERMAL POWER in percent RTP.

$$f_1(\Delta I) = [*] \{[*] - (q_t - q_b)\} \quad \text{when } q_t - q_b \leq [*]\% \text{ RTP}$$

$$f_1(\Delta I) = 0\% \text{ of RTP} \quad \text{when } [*]\% \text{ RTP} < q_t - q_b \leq [*]\% \text{ RTP}$$

$$f_1(\Delta I) = [*] \{(q_t - q_b) - [*]\} \quad \text{when } q_t - q_b > [*]\% \text{ RTP}$$

\* These values denoted with [\*] are specified in the COLR.

Table 3.3.1-1 (Note 2)  
Overpower  $\Delta T$

- NOTE -

The Overpower  $\Delta T$  Function Limiting Safety System Setting is defined by:

$$\text{Overpower } \Delta T \leq \Delta T_0 \{K_4 - K_5 (T-T') - K_6 [(\tau_3 s T) / (\tau_3 s + 1)] - f_2(\Delta I)\}$$

Where:

$\Delta T$  is measured RCS  $\Delta T$ , °F.

$\Delta T_0$  is the indicated  $\Delta T$  at RTP, °F.

$s$  is the Laplace transform operator,  $\text{sec}^{-1}$ .

$T$  is the measured RCS average temperature, °F.

$T'$  is the nominal  $T_{\text{avg}}$  at RTP, °F.

$K_4$  is the Overpower  $\Delta T$  reactor trip setpoint, [\*].

$K_5$  is the Overpower  $\Delta T$  reactor trip heatup setpoint penalty coefficient which is:  
[\*]/°F for  $T < T'$  and;  
[\*]/°F for  $T \geq T'$ .

$K_6$  is the Overpower  $\Delta T$  reactor trip thermal time delay setpoint penalty which is:  
[\*]/°F for increasing  $T$  and;  
[\*]/°F for decreasing  $T$ .

$\tau_3$  is the measured impulse/lag time constant, [\*] seconds.

$$f_2(\Delta I) = [*]$$

\* These values denoted with [\*] are specified in the COLR.



5.0 ADMINISTRATIVE CONTROLS

5.6 Reporting Requirements

---

---

The following reports shall be submitted in accordance with 10 CFR 50.4.

5.6.1 Deleted

5.6.2 Annual Radiological Environmental Operating Report

The Annual Radiological Environmental Operating Report covering the operation of the plant during the previous calendar year shall be submitted by May 15 of each year. The report shall include summaries, interpretations, and analyses of trends of the results of the radiological environmental monitoring activities for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual (ODCM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

The Annual Radiological Environmental Operating Report shall include the results of analyses of all radiological environmental samples and of all environmental radiation measurements taken during the period pursuant to the locations specified in the table and figures in the ODCM, as well as summarized and tabulated results of these analyses and measurements in the format of the table in the Radiological Assessment Branch Technical Position, Revision 1, November 1979. In the event that some individual results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.

5.6.3 Radioactive Effluent Release Report

The Radioactive Effluent Release Report covering the operation of the plant shall be submitted in accordance with 10 CFR 50.36a. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the plant. The material provided shall be consistent with the objectives outlined in the ODCM and in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

5.6.4 Deleted

## 5.6.5

CORE OPERATING LIMITS REPORT (COLR)

The following administrative requirements apply to the COLR:

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:

2.1,	"Safety Limits (SLs)";
LCO 3.1.1,	"SHUTDOWN MARGIN (SDM)";
LCO 3.1.3,	"MODERATOR TEMPERATURE COEFFICIENT (MTC)";
LCO 3.1.5,	"Shutdown Bank Insertion Limit";
LCO 3.1.6,	"Control Bank Insertion Limits";
LCO 3.2.1,	"Heat Flux Hot Channel Factor ( $F_Q(Z)$ )";
LCO 3.2.2,	"Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ )";
LCO 3.2.3,	"AXIAL FLUX DIFFERENCE (AFD)";
LCO 3.3.1,	"Reactor Protection System (RPS) Instrumentation";
LCO 3.4.1,	"RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits"; and
LCO 3.9.1,	"Boron Concentration."

- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:

1. WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.  
(Methodology for 2.1, LCO 3.1.1, LCO 3.1.3, LCO 3.1.5, LCO 3.1.6, LCO 3.2.1, LCO 3.2.2, LCO 3.2.3, and LCO 3.9.1.)
2. WCAP-13677-P-A, "10 CFR 50.46 Evaluation Model Report: WCOBRA/TRAC Two-Loop Upper Plenum Injection Model Updates to Support ZIRLO™ Cladding Option," February 1994.  
(Methodology for LCO 3.2.1.)

3. WCAP-10216-P-A, Rev. 1A, "Relaxation of Constant Axial Control / FQ Surveillance Technical Specification," February 1994.  
(Methodology for LCO 3.2.1 and LCO 3.2.3.)
  4. WCAP-12610-P-A, "VANTAGE + Fuel Assembly Reference Core Report," April 1995.  
(Methodology for LCO 3.2.1.)
  5. WCAP 11397-P-A, "Revised Thermal Design Procedure," April 1989.  
(Methodology for LCO 3.4.1 when using RTDP.)
  6. WCAP-10054-P-A and WCAP-10081-A, "Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code," August 1985.  
(Methodology for LCO 3.2.1.)
  7. WCAP-10924-P-A, Volume 1, Revision 1, "Westinghouse Large-Break LOCA Best-Estimate Methodology, Volume 1: Model Description and Validation Responses to NRC Questions," and Addenda 1,2,3, December 1988.  
(Methodology for LCO 3.2.1.)
  8. WCAP-10924-P-A, Volume 2, Revision 2, "Westinghouse Large-Break LOCA Best-Estimate Methodology, Volume 2: Application to Two-Loop PWRs Equipped with Upper Plenum Injection," and Addendum 1, December 1988.  
(Methodology for LCO 3.2.1.)
  9. WCAP-10924-P-A, Volume 1, Revision 1, Addendum 4, "Westinghouse Large-Break LOCA Best-Estimate Methodology, Volume 1: Model Description and Validation, Addendum 4: Model Revisions," March 1991.  
(Methodology for LCO 3.2.1.)
  10. WCAP-8745, "Design Basis for the Thermal Overpower Delta T and Thermal Overtemperature Delta T Trip Functions," March 1977.  
(Methodology for LCO 3.3.1.)
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

## 5.6.6

Reactor Coolant System (RCS) PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)

The following administrative requirements apply to the PTLR:

- a. RCS pressure and temperature limits for heatup, cooldown, criticality, and hydrostatic testing as well as heatup and cooldown rates shall be established and documented in the PTLR for the following:

LCO 3.4.3, "RCS Pressure and Temperature (P/T) Limits"

- b. The power operated relief valve lift settings required to support the Low Temperature Overpressure Protection (LTOP) System, and the LTOP enable temperature shall be established and documented in the PTLR for the following:

LCO 3.4.6, "RCS Loops - MODE 4";

LCO 3.4.7, "RCS Loops - MODE 5, Loops Filled";

LCO 3.4.10, "Pressurizer Safety Valves"; and

LCO 3.4.12, "LTOP System."

- c. The analytical methods used to determine the RCS pressure and temperature and LTOP limits shall be those previously reviewed and approved by the NRC in NRC letter, "R.E. Ginna - Acceptance for Referencing of Pressure Temperature Limits Report, Revision 2 (TAC No. M96529)," dated November 28, 1997. Specifically, the methodology is described in the following documents:

1. Letter from R.C. Mecredy, Rochester Gas and Electric Corporation (RG&E), to Document Control Desk, NRC, Attention: Guy S. Vissing, "Application for Facility Operating License, Revision to Reactor Coolant System (RCS) Pressure and Temperature Limits Report (PTLR) Administrative Controls Requirements," Attachment VI, September 29, 1997, as supplemented by letter from R.C. Mecredy, RG&E, to Guy S. Vissing, NRC, "Corrections to Proposed Low Temperature Overpressure Protection System Technical Specification," October 8, 1997.
2. WCAP-14040-NP-A, "Methodology used to Develop Cold Overpressure Mitigating System Setpoints and RCS Heatup and Cooldown Limit Curves," Sections 1 and 2, January, 1996.

- d. The PTLR shall be provided to the NRC upon issuance for each reactor vessel fluence period and for revisions or supplement thereto.
-