



COMPONENTS SUBJECT TO AMR

█ FIRE PROTECTION - CO2 SYSTEM AMRM-18

- NOTES:
- UNLESS OTHERWISE NOTED ALL INSTRUMENT TAG NUMBERS SHALL BE PREFIXED BY SYSTEM NO. 115.
 - THE MECHANICAL LOCK ON THE MANUAL LEVER PREVENTS INITIATING A MANUAL CO2 DISCHARGE FROM THIS LOCATION.
 - THE MANUAL RELEASE STATION IS PADLOCKED. A KEY MUST BE OBTAINED FROM THE CONTROL ROOM IN ORDER TO MANUALLY DISCHARGE THE CO2 SYSTEM.
 - DISCHARGE DELAY TIMER SUPPLY TUBING HEAT TRACED. REFERENCE CWD 1851
 - PROTECTIVE COVER INSTALLED OVER BLEEDER VALVES TO PREVENT INTRODUCTION OF WATER AND DEBRIS.

- REFERENCES:
- 5920-11896 SH. 1 THRU 5.

5	REVISED PER MI 2003-03B, JO 2003-0083	3-15-04	3-18-04	3-22-04	NL	WD	GSB
6	REVISED PER CU 2004-010	6-14-04	6-14-04	6-16-04	NL	WD	GSB
REV	DESCRIPTION	BY	CHKD.	APPD.			
<p>ENTERGY NUCLEAR VERMONT YANKEE VERNON, VERMONT</p> <p>FLOW DIAGRAM FIRE PROTECTION SYSTEM LOW PRESSURE CO2</p> <p>DRAWING NO. G-191163 SH. 3</p>							

0	4-1-05						
NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP	
REVISIONS							
LRA-G-191163-SH-03-0							
CWD FILE LRA-G-191163-SH-03_06.DGN							
PLOT FILE N/A							

D-20