

- D. The facility has been granted certain exemptions from the requirements of Section III.G of Appendix R of 10 CFR Part 50, "Fire Protection Program for Nuclear Power Facilities Operating Prior to January 1, 1979."

This section relates to fire protection features for ensuring the systems and associated circuits used to achieve and maintain safe shutdown are free of fire damage. These exemptions were granted and sent to the licensee in letters dated March 24, 1986 and June 25, 1990.

The facility has also been granted certain exemptions from the requirements of Section III.J of Appendix R to 10 CFR Part 50, "Fire Protection Program for Nuclear Power Facilities Operating Prior to January 1, 1979." This section relates to emergency lighting that shall be provided in all areas needed for operation of safe shutdown equipment and in access and egress routes thereto. This exemption was granted and sent to the licensee in a letter dated February 12, 1990.

In addition, the facility has been granted certain exemptions from Section 55.45(b)(2)(iii) and (iv) of 10 CFR Part 55, "Operators' Licenses." These sections contain requirements related to site-specific simulator certification and require that operating tests will not be administered on other than a certified or an approved simulation facility after May 26, 1991. These exemptions were granted and sent to the licensee in a letter dated March 25, 1991.

These exemptions granted pursuant to 10 CFR 50.12 are authorized by law, will not present an undue risk to the public health and safety, and are consistent with the common defense and security. With these exemptions, the facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission.

- E. Deleted.