March 02, 2006

Mr. R. T. Ridenoure Vice President - Chief Nuclear Officer Omaha Public Power District Fort Calhoun Station FC-2-4 Adm. Post Office Box 550 Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION RELATED TO THE USE OF M5 FUEL CLADDING (TAC NO. MC8096)

Dear Mr. Ridenoure:

By letter dated August 11, 2005, Omaha Public Power District (OPPD/the licensee) submitted a license amendment request for the Fort Calhoun Station, Unit 1. The licensee requested a technical specification change that would permit the use of AREVA (Framatome ANP) M5 advanced alloy for fuel rod cladding and other structural components in the reactor core, beginning with Refueling Cycle 24.

The Nuclear Regulatory Commission (NRC) staff has completed a preliminary review of OPPD's submittal. The NRC staff has determined that additional information is needed to complete our review. A request for additional information (RAI) is enclosed. This request was discussed with Thomas Byrne of your staff on February 9, 2006, and it was agreed that a response would be provided within 30 days of receipt of this letter.

If you have any questions, please contact me at (301) 415-1445.

Sincerely,

/**RA**/

Alan B. Wang, Project Manager Plant Licensing Branch IV Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: RAI

cc w/encl: See next page

Mr. R. T. Ridenoure Vice President - Chief Nuclear Officer Omaha Public Power District Fort Calhoun Station FC-2-4 Adm. Post Office Box 550 Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION RELATED TO THE USE OF M5 FUEL CLADDING (TAC NO. MC8096)

Dear Mr. Ridenoure:

By letter dated August 11, 2005, Omaha Public Power District (OPPD/the licensee) submitted a license amendment request for the Fort Calhoun Station, Unit 1. The licensee requested a technical specification change that would permit the use of AREVA (Framatome ANP) M5 advanced alloy for fuel rod cladding and other structural components in the reactor core, beginning with Refueling Cycle 24.

The Nuclear Regulatory Commission (NRC) staff has completed a preliminary review of OPPD's submittal. The NRC staff has determined that additional information is needed to complete our review. A request for additional information (RAI) is enclosed. This request was discussed with Thomas Byrne of your staff on February 9, 2006, and it was agreed that a response would be provided within 30 days of receipt of this letter.

If you have any questions, please contact me at (301) 415-1445.

Sincerely,

/**RA**/

Alan B. Wang, Project Manager Plant Licensing Branch IV Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC LPLIV R/F RidsNrrDorlLplg (DTerao) RidsNrrDpr RidsNrrPMAWang RidsNrrLALFeizollahi RidsOgcRp RidsNrrAcrsAcnwMailCenter RidsRgn4MailCenter (DGraves) Tford

ACCESSION NO. ML060550294

| OFFICE | LPL4/PM | LPL4/LA | LPL4/BC |
|--------|---------|-------------|---------|
| NAME | AWang | LFeizollahi | DTerao |
| DATE | | | |

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION

REGARDING THE USE OF M5 FUEL CLADDING

OMAHA PUBLIC POWER DISTRICT

FORT CALHOUN STATION

DOCKET NO. 50-285

By letter dated August 11, 2005, Omaha Public Power District (OPPD/the licensee) submitted a a license amendment request for the Fort Calhoun Station, Unit 1. The licensee requested a technical specification change that would permit the use of AREVA (Framatome ANP) M5 advanced alloy for fuel rod cladding and other structural components in the reactor core, beginning with Refueling Cycle 24. The Nuclear Regulatory Commission (NRC) staff has completed a preliminary review of OPPD's submittal. The NRC staff has determined that the following additional information is needed to complete our review.

- 1. Provide the calculated peak clad temperatures for both the M5 cladding (Mark-B-HTP fuel design) and the co-resident Zircaloy-4 cladding.
- 2. Does the loss-of-coolant accident (LOCA) Evaluation Model consider both the pre-LOCA and LOCA oxidation in demonstrating compliance with 10 CFR 50.46 requirements?
- 3. Is the non-M5 fuel cladding oxidation bounded by a number which is less than or equal to the 10 CFR 50.46 acceptance criteria of 17 percent?

Ft. Calhoun Station, Unit 1

cc: Winston & Strawn ATTN: James R. Curtiss, Esq. 1400 L Street, N.W. Washington, DC 20005-3502

Chairman Washington County Board of Supervisors P.O. Box 466 Blair, NE 68008

Mr. John Hanna, Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 310 Fort Calhoun, NE 68023

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011-4005

Ms. Julia Schmitt, Manager Radiation Control Program Nebraska Health & Human Services R & L Public Health Assurance 301 Centennial Mall, South P.O. Box 95007 Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager Fort Calhoun Station Omaha Public Power District Fort Calhoun Station FC-1-1 Plant P.O. Box 550 Fort Calhoun, NE 68023-0550

Mr. Joe L. McManis Manager - Nuclear Licensing Omaha Public Power District Fort Calhoun Station FC-2-4 Adm. P.O. Box 550 Fort Calhoun, NE 68023-0550 Mr. Daniel K. McGhee Bureau of Radiological Health Iowa Department of Public Health Lucas State Office Building, 5th Floor 321 East 12th Street Des Moines, IA 50319